



Hazardous Area Enclosures High Voltage Junction Boxes Electrical Enclosures Cable Glands and Adaptors

How to Contact Abtech



If you require any additional information regarding our products, please contact us at one of the listed locations. Alternatively, our website includes detailed product information along with the ability to download certificates, software and drawings.

Other Products Available from Abtech...

Cable Glands and Adaptors



A range of cable glands, adaptors, reducers and stopping plugs manufactured from brass and suitable for use in hazardous area Zone 1 and Zone 2.

Please see the Glands Section of this catalogue on page 208.

Hazardous Area Lighting



A range of hazardous area lighting products from Ablux (an Abtech Group company). The product line includes various floodlights and luminaires suitable for both Zone 1 and Zone 2 areas hazardous areas along with associated specialist lighting components. Ablux are also able to provide custom lighting solutions designed to the customer's specifications.





North America

▲ A.B Controls & Technology Inc.

1813 Rotary Drive Humble Texas USA TX77338

+001 281 5483424 Tel· Fax: +001 281 5483624 Fmail: sales@abtech-inc.com

Europe

▲ Abtech Limited

199 Newhall Road Lower Don Valley Sheffield. South Yorkshire S9 2QJ

United Kingdom Tel:

+44 (0) 114 244 2424 ¥44 (0) 114 243 4312 Fax: Email: 📐 sales@abtech.eu

Abtech Scotland

46 Telford Road Lenziemill Cumbernauld G67 2AX

▲ Abtech GmBH

Dünner Kirchweg 11

Fax: +49 (0) 522 375019 Email: sales@abtech.de

Located in the following countries;

Worldwide Agents

Belgium Denmark Finland France Italy Russia Sweden Oman. Oatar Saudi Arabia

Turkey

Australia Ćhina Hong Kong Indonesia Malaysia Taiwan Thailand Vietnam Pakistan

ÙÀE

32257, Bünde, Germany Tel: +49 (0) 522 375016

▲ Abtech Nederland BV

Glasblazerstraat 1 2984 BL Ridderkerk. Nederland

Tel: +31 (0) 180 428417 +31 (0) 180 431668 Fax: Email: sales@abtech.nl

Asia

▲ Abtech S.E Asia Pte Ltd

Blk 3015A Ubi Road 1 #07-13 Singapore 408705

Tel: +65 631 66413 Fax: +65 631 63243 Email: sales@abtechasia.com

▲ Abtech Korea

Astar Apt #101-2801 Dong-Rae Gu On-Chen Dong, Busan South Korea

Tel· +82 708807 2137 Fax: +82 51553 2137 Email: sales@abtech-korea.com

www.abtech.eu

Since the first ABTECH sheet steel enclosure was manufactured in the 1970's the company has never lost sight of it's goal, to become a leading supplier of quality electrical enclosures and junction boxes suitable for both industrial and hazardous area markets. This we believe has been achieved through innovation, market leading design, rigorous testing and adherence to quality.



In recent years ABTECH have extended their range of enclosures to cope with ever increasing customer demands for unique solutions to their problems. These solutions include high current connection boxes (up to 3000Amps), high temperature junction boxes (up to 950°C for 3 hours) and IP68 enclosures (up to 120ft depth)

ABTECH rose to the challenge when the Channel Tunnel was being constructed and produced over 12,500 junction boxes and emergency lighting actuators to the most exacting of standards. With the emphasis on reliability and safety, ABTECH designed a solution that more than met the rigorous specification laid down by Eurotunget.



The new millennium has seen ABTECH once more expanding their range of products and services to help their customers cope with the need to meet ever changing international standards.

In addition to fulfilling the requirements of the ATEX legislation, the majority of ABTECH products also comply with the IEC Ex scheme and are certified for use in Category 2 (Zone 1) and Category 3 (Zone 2) areas for both gas and dust hazards.



ABTECH operate in the global market place as the nature of the Oil & Gas & Petrochemical industry demands and to meet this requirement ABTECH operate at an International level. With the headquarters based in Sheffield, UK and factories and offices in USA, Germany, Netherlands, South Korea and Singapore and a network of agents covering over 40 countries worldwide, ABTECH have the coverage to manage any project. Indeed over the last 25 years, ABTECH have been involved in many projects throughout the world. Please refer to our Major Projects List in the Appendix section of this catalogue.



ABTECH also manufacture restricted breathing enclosures (EEx'nR') which are capable of housing sparking and hot components and are suitable for use in Zone 2 areas and can often be a cost effective alternative to flameproof enclosures (EEx'd').

The durability of our products is measured in decades. Whether the product is for an industrial or hazardous area application, ABTECH place the utmost importance on quality as would be expected from a leading manufacturer. The success of the company has been built on this dedication to total quality control and with over 30 years history of supply to the leading oil & gas companies throughout the world it is a policy that has been proven to work.

With approvals such as BS EN ISO 9001:2000, certification to British, European and International standards and approvals from certifying authorities in the UK, USA, Canada and Russia, the company's commitment to quality ensures that safety is never compromised.

polycarbonate and ABS are suitable for a wide range of industrial and OEM applications and we have the facilities to modify the standard enclosure to meet the customer's requirements.

These services include machining painting, silk

Enclosures manufactured in stainless steel, mild

steel, glass reinforced polyester, aluminum,

These services include machining, painting, silk screen printing and electro-pollshing. We are also able to mould any of the plastic range of enclosures in a wide range of colours (subject to minimum order quantity).





Technical support at ABTECH begins long before the order is placed. Our dedicated sales staff based at our regional offices can offer advice on enclosure type, terminal selection, cable entry placement and any other requirements that might dictate the eventual selection. Technical assistance is also available at any time during the order process or indeed after the equipment is installed, and ABTECH staff will be only too happy to help with any questions you may have.

The ABTECH range of products are suitable for both industrial and hazardous area applications.

ABTECH Enclosure Calculator

One of the most difficult and time consuming steps in the selection of a suitable enclosure to meet your particular requirements is trying to calculate if the size chosen will accommodate the terminals and cable entries you require. At ABTECH we have, for many years, been using our Enclosure Calculation software which was designed specifically for use with our enclosures.



Some years ago we decided to make this program available to all our customers, free of charge, and this has been a tremendous success. The software allows users to easily design complex arrangements of entries and generates a drawing which ABTECH can subsequently use for manufacturing purposes.




The program also incorporates a terminal calculation program which lets you see at a glance whether or not the desired number of terminals can be accommodated within your chosen enclosure and as with the Entry Calculator will print a drawing of your finished design.

The software greatly simplifies the enclosure design process. The latest version will also produce general arrangement drawings which can printed or emailed as required.



The program can be used on any Windows based RC and is simple to install and use. It includes a comprehensive help menu to allow users to—start using the software immediately without the need of expert tutition. The ABTECH Enclosure Calculator CD can be obtained by contacting our sales desk or for immediate download from our website at www.abtech.eu



Contents

| | Stainless Steel and Mild Steel Enclosures | 1 |
|----------|---|------|
| | SX and MSX | |
| | |)) ~ |
| | Glass Reinforced Polyester Enclosures | / 42 |
| | BPG and BPGC | |
| | | |
| | Assembled GRP Junction Boxes | 82 |
| _ | BPGA | |
| | | |
| | Die-Cast Aluminium Enclosures | 88 |
| _ | ZAG and ZAGR | |
| | | |
| | High Voltage/Enclosures | 132 |
| | MJB, DRJB, HVJB, LR and Busbar | 102 |
| | Wisb, Stob, NVSb, Et and Basbar | |
| | Fire Rated Enclosures | 148 |
| _ | \$X and BPG | 140 |
| | Skallabra | |
| | Debis substitution of ADC Free leavings | 152 |
| | Polycarbonate and ABS Enclosures | 152 |
| 7 | ZP, ZPS and ZPT | |
| 1 | Others Free Leaving Breedwate | 10/ |
| <u> </u> | Other Enclosure Products | 196 |
| , | GRN8, BPC/SXC Control Stations and Submersible Enclosures | |
| _ | | |
| | Cable Glands, Adaptors and Reducers | 208 |
| | ASG and AAG Glands ABAD Adaptors | |
| | ABRE Reducers | |
| | Appendix | 222 |
| | ··- | |
| | Technical Information Gland Clearances | |
| | Abtech Project List | |
| | Index | |



Stainless Steel and Mild Steel Enclosures



The SX range comprises 14 sizes of enclosure manufactured in either stainless steel or mild steel. 11 sizes are available in depths of 140 or 200mm and 8 sizes are available in depths of 140, 200 or 300mm. The majority of the range can be fitted with removable gland plates on any or all of the four sides. The SX Range is available with a number of paint options (most RAL colours are available) and anti-corrosion finishes. Further advice on surface finishes can be sought from the ABTECH sales office.



The stainless steel range (SSX) is manufactured in 316 grade stainless steel to give the maximum environmental protection.

The main body is manufactured from 2mm thick sheet and the mounting straps and gland plates from 3mm thick plate. Cable entries can be drilled in the enclosure door or sides or through the gland plates, if littled, Entries may also be drilled through the rear face of the enclosure (EEx'e' versions also.)

Another important teature of the SX range is the hinged, lift-off door, which is held to the enclosure by at least 4 captive stainless steel screws. Which also maintain the correct compression on the gasket. The hinges are solid block machined oversize to enable the screws control the closing of the door, not the hinge, its only function being to support the door when opened. The hinges allow easy removal of the door with only minimal opening required before removal (less than 10°).

Earthing is accomplished by means of an internal /external earth stud fitted as standard which can be connected to the terminal mounting rail or component mounting plate.

Optionally, earth studs can be fitted to the door and gland plates. Rail mounted earth terminals or proprietary earth bars can be fitted inside the enclosure and ABTECH Sales staff will be happy to advise on this. The SX range is suitable for a wide range of ambient conditions. Hazardous Area certified enclosures are suitable for -50°C to + 175°C. Non-Ex versions are suitable from -60°C to + 200°C.

The SX range of enclosures are suitable for use in hazardous areas and can be supplied with a number of certificates. ATEX EEx'e' to BS EN 50019 (Zone 1 & 2), EEx'nA' to BS EN50021 (Zone 2), NEMA 4X (CSA), UL & FM class 1, div 2), IEC Ex and GOS1. The range can be supplied fitted with any component approved terminal to apparatus level or can be supplied empty as component approved for the clients own certification requirements.

The SX range was specifically designed to meet the rigours of the North Sea environment and is capable of achieving IP66 and IP67. It has also undergone and passed the Shell/ERA deluge test which was devised to adequately test enclosures and electrical equipment which is routinely subjected to ships deck conditions or fire deluge systems.

IP68 enclosures are also available for depths up to 120 ft to special order. Further information on submersible enclosures is available in Section 8 of this catalogue.




The SX range has many features which lend itself to a wide variety applications, not least of which is the ability to be constructed to almost any dimension due to its fabricated nature. This can also be applied to EEx'e' enclosures where the certification allows oversize enclosures to be manufactured whilst retaining the next smallest sized enclosure's power rating.

The SX range is also suitable for fire resistance applications and when fitted with ceramic terminals meets the requirements of IEC 331 (750°C (1382°F) for 3 hours) and also BS6387/1983 (950°C (1742°F) for 3 hours). Further details are available in Section 6 of this catalogue.



Other applications include junction boxes, both industrial and hazardous area, OEM applications, fire protection systems, tunnel wiring, IP68 applications, etc.

Abtech also offers bespoke solutions for Ex nR restricted breathing applications.



SX Range Features

- Wide Operating Temperature (-50°C to + 175°C) (-58°F to +347°F)
- Ingress Protection up to IP68
- Fire Resistant to IEC331
- Impact Resistant > 10 Nm.
- Corrosion Resistant
- Gland plates can be fitted to any or all four sides (size SX66 and above)
- Certification for use in Zone 1 and 2
- UL, CSA, IEC Ex, ATEX, FM, InMetro and TR CU Approvals
- Ideal for Petrochemical and Marine applications

Certification and Coding

| 15 | Zone 0 | Zone 20 | Zone 1 | Zone 21 | Zone 2 | Zone 22 |
|----------|--------|---------|--------|---------|--------|---------|
| -Ex e | | | • | • | • | • |
| Ex ai | • | • | • | • | • | • |
| Ex ab | | | • | • | • | • |
| Ex op is | • | • | • | • | • | • |
| Ex nA | | | | | • | • |
| Ex nR | | | | | • | • |

Available with Apparatus or Component certification

Accessories and Options

The following table is a list of the available accessories suitable for particular standard sizes of SX enclosures. Care should be taken when ordering accessories for use with enclosures intended for hazardous areas to ensure that compliance with certification is retained.

| Part Number (see note 1) | Width (mm) (see note 2) | Height (mm) (see note 2) | Depth (mm) (see note 2) | 140mm Depth | 200mm Depth | 300mm Depth | Gland Plates (on any or all four sides) | EP – Electro-polished external surfaces (SX only) | LB - Label Bracket Welded to Door | ES - Earth Stud fitted to Door and Gland Plates | EB - Internal Earthing Bar | BD - Breather Drain (see note 3) | TP - Tamper Proof Lid Fixing Screws | MP - Component Mounting Plate (Steel /Stainless Steel) | RF – RFI Protection (see note 4) |
|--------------------------|-------------------------|--------------------------|-------------------------|-------------|-------------|---------------|--|--|--------------------------------------|--|----------------------------|-------------------------------------|--|---|-------------------------------------|
| SX45 | 114 | 114 | 51 | | | | | | | | | | | | |
| SX64 | 102 | 152 | 63 | | | | | 9(| | 0 | | | | | |
| SX66 | 152 | 152 | 102 | | | | • (| | 3 | | | | | | |
| SXO | 152 | 229 | | | | | No. | 7 | | | | | | | |
| SX0.5 | 184 | 274 | | | • | (\) | | | | | | | | | |
| SX1 | 234 | 324 | | | | | | | | | | | | | |
| SX1.5 | 306 | 306 | | • < | | | | | | | | | | | |
| SX2 | 372 | 324 | | | 8 | > 0 | | | | | | | | | |
| SX3 | 372 | 448 | | | | | | | | | | | | | |
| SX4 | 372 | 510 | | | | | | | | | | | | | |
| SX5 | 510 | 510 | | | | | | | | | | | | | |
| SX6 | 510 | 780 | | | | | | | | | | | | | |
| SX7 | 650 | 950 | | | | | | | | | | | | | |
| SX8 | 800> | 1250 | | | | | | | | | | | | | |

Ordering Example;

SX1.5 300 4GP LB EB

(Stainless Steel SX1.5 300mm deep, 4 gland plates, label bracket on door and internal earthing bar

- The range is available either in stainless steel 316 (SX variants) or mild steel (MSX variants).
- 2. Manufacturing tolerances are +/- 3mm on overall dimensions and +/-0.5mm on fixing hole centres.
- 3. Breather drain available in IP66 stainless steel or plastic.
- 4. Radio Frequency Interference (RFI) gasket may reduce IP rating.



Full width, full height Gland Plates (can be fitted to any or all sides)




Earth Stud fitted to door, and gland plates




Label Bracket (welded to door)



Electro-polished (external surfaces on SX range only)



Internal Earthing bar (can be fitted with clamps)



Component Mounting Plate (steel or stainless steel 316)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

8.00W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | |
|-----------|-----------|
| SAK 2.5 | 7 |
| SAK 4 | 7 |
| SAK 6 | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 |
| SAK 35 | 0 |
| SAK 70 | 0 |
| WDU 2.5 | 0 |
| WDU 4 | 0 |
| WDU 6 | 0 (|
| WDU 10 | \ 0 \ \ \ |
| WDU 16 | 0 |
| , | |
| | |
| | |
| | |
| , 4 |)) |

| This life required not be of re | | | | |
|---------------------------------|------|---|--|--|
| Phoenix | | _ | | |
| UK 2.5 N | ۶/ (| | | |
| UK 3 N | 9 | _ | | |
| UK 5 N | | \ | | |
| UK 10 N _ | 4 | | | |
| UK 16 N | 3 | | | |
| UK 35 N | ₹>0 | | | |
| | | | | |
| | | | | |
| 7 | | | | |
| | | | | |
| 7 | | | | |
| $\langle \rangle$ | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| / N | |
|------------|---|
| Wago | |
| 280-992 | 8 |
| 280-999 | 0 |
| 281-691 | 7 |
| 281-992 | 7 |
| 281-993 | 0 |
| 282-691 | 0 |
| 284-691 | 0 |
| 283-691 | 0 |
| 285-691 | 0 |
| 280-998 | 8 |
| 281-998 | 0 |
| 264-120 | 7 |
| 264-220 | 4 |
| 264-132(2) | 1 |
| 264-134(4) | 1 |
| 262-132(2) | 1 |
| 264-134(4) | 1 |

Drilling Envelope Dimensions (mm)


| | | Side A - C | Side B - D |
|-------|----|------------|------------|
| Width | ١ | 114 | 114 |
| Heigh | ı† | 51 | 51 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 4 |
| M20 | 2 | 2 |
| M25 | 2 | 2 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------|------------|-------------|------------|------------|
| SX45 | Stainless Steel | 114 | 114 | 51 | 1200 |
| MSX45 | Mild Steel | 114 | 114 | 51 | 1200 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

SX64 / MSX64

Application

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TRANSE (Class 1 Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

10.258W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| _ | |
|-----------|--------|
| Weidmulle | r |
| SAK 2.5 | 15 |
| SAK 4 | 15 |
| SAK 6 | 11 |
| SAK 10 | 9 |
| SAK 16 | 0 |
| SAK 35 | 0 |
| SAK 70 | 0 |
| WDU 2.5 | 0 |
| WDU 4 | 0 |
| WDU 6 | 0 |
| WDU 10 | 0 |
| WDU 16 | 0 |
| | |
| < | |
| | |
| (| > // , |
| | |
| | // |

| | THOCHK | |
|---|----------|-----|
| | UK 2.5 N | 17 |
| | UK 3 N | 17(|
| | UK 5 N | 15 |
| | UK 10 N | 9 |
| | UK 16 N | 7 🛇 |
| | UK 35 N | D |
| | | |
| | | (|
| | (12) | |
| A | | |
| / | | |
| 1 | 7/ | |
| 7 | | |
| 7 | 7 | |
| | | |
| | | |
| | | |
| | | |

| 7. 77 | |
|------------|----|
| Wago | |
| 280-992 | 18 |
| 280-999 | 0 |
| 281-691 | 15 |
| 281-992 | 15 |
| 281-993 | 0 |
| 282-691 | 0 |
| 284-691 | 0 |
| 283-691 | 0 |
| 285-691 | 0 |
| 280-998 | 18 |
| 281-998 | 15 |
| 264-120 | 15 |
| 264-220 | 9 |
| 264-132(2) | 3 |
| 264-134(4) | 2 |
| 262-132(2) | 3 |
| 264-134(4) | 2 |
| | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 102 | 152 |
| Height | 63 | 63 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 8 |
| M20 | 3 | 4 |
| M25 | 2 | 3 |
| M32 | 1 | 2 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| 1 | SX64 | Stainless Steel | 102 | 152 | 63 | 1500 |
| 1 | MSX64 | Mild Steel | 102 | 152 | 63 | 1500 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

SX66 / MSX66

Application

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

14.287W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending (àdius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | | | | |
|------------|------------|--|--|--|--|
| SAK 2.5 | 15 | | | | |
| SAK 4 | 15 | | | | |
| SAK 6 | 11 | | | | |
| SAK 10 | 9 | | | | |
| SAK 16 | 7 | | | | |
| SAK 35 | 6 | | | | |
| SAK 70 | 0 | | | | |
| WDU 2.5 | 17 | | | | |
| WDU 4 | 15 | | | | |
| WDU 6 | 11 | | | | |
| WDU 10 | 9 〈 | | | | |
| WDU 16 | \7 <u></u> | | | | |
| < | | | | | |
| | | | | | |
| | > // / | | | | |
| | | | | | |
| | | | | | |
| . <- | 11 | | | | |

| Phoenix | |
|-----------|------|
| UK 2.5 N | 17 |
| UK 3 N | 121 |
| UK 5 N | . 14 |
| UK 10 N | 9 |
| UK 16 N < | ZŽ |
| UK 35 N | 8 |
| | |
| (2) | |
| | 1 |
| | |
| 12 | |
| | |
| \supset | |
| | |
| | |
| | |
| | |

| Wago | |
|------------|----|
| 280-992 | 18 |
| 280-999 | 18 |
| 281-691 | 15 |
| 281-992 | 15 |
| 281-993 | 15 |
| 282-691 | 11 |
| 284-691 | 10 |
| 283-691 | 7 |
| 285-691 | 0 |
| 280-998 | 18 |
| 281-998 | 15 |
| 264-120 | 16 |
| 264-220 | 10 |
| 264-132(2) | 3 |
| 264-134(4) | 2 |
| 262-132(2) | 3 |
| 264-134(4) | 2 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 152 | 152 |
| Height | 102 | 102 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 4 |
| M20 | 2 | 2 |
| M25 | 2 | 2 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------|------------|-------------|------------|------------|
| SX66 | Stainless Steel | 152 | 152 | 102 | 2200 |
| MSX66 | Mild Steel | 152 | 152 | 102 | 2200 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

SXO / MSXO

Application

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

19.874W



Terminal Populations (Maximum Number of Rails/\$)1)

UK

UK UK UK

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending daily's and that the earth stud and entry location will permit the required number of terminals to be, fitted

| Weidmulle | |
|-----------|------|
| SAK 2.5 | 21 |
| SAK 4 | 19 |
| SAK 6 | 16 |
| SAK 10 | 12 |
| SAK 16 | 10 |
| SAK 35 | 7 |
| SAK 70 | 5 |
| WDU 2.5 | 25 |
| WDU 4 | 21 |
| WDU 6 | 16 |
| WDU 10 | 12 〈 |
| WDU 16 | (10- |
| | |
| | |
| | |
| | |
| | |

| ine require | sa nomber o | . 7 | DATILITORS TO DECIL | neu |
|-------------|----------------|-----|---------------------|-----|
| noenix | | (| Wago | |
| 2.5 N | 25 | | 280-992 | 24 |
| 3 N | 25 | | 280-999 | 24 |
| 5 N | 21 | (| 281-691 | 20 |
| 10 N | 12 | | 281-992 | 20 |
| 16 N 🤇 | 10 | | 281-993 | 20 |
| 35 N | 8 | | 282-691 | 15 |
| | () | | 284-691 | 12 |
| 16 | | | 283-691 | 0 |
| | | | 285-691 | 0 |
| 3) | | | 280-998 | 24 |
| | | | 281-998 | 20 |
| 7 | | | 264-120 | 21 |
| | | | 264-220 | 12 |
| | | | 264-132(2) | 4 |
| | | | 264-134(4) | 3 |
| | | | 262-132(2) | 4 |
| | | | 264-134(4) | 3 |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side B - D | | |
|--------|------------|-----|------------|-----|--|
| | 140 | 200 | 140 | 200 | |
| Width | 87 | 87 | 144 | 144 | |
| Height | 75 | 135 | 75 | 135 | |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side B - D | | |
|------|------|-------|------------|-----|--|
| 320 | 140 | 200 | 140 | 200 | |
| M16 | 4 | 9 | 8 | 16 | |
| M20 | 2 | 6 | 6 | 9 | |
| M25 | 1 | 4 | 3 | 6 | |
| M32 | 1 | 2 | 2 | 4 | |
| M40 | 1 | 1 | 2 | 2 | |

^{*} Using standard gland clearances

| 7 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| | SX0.140 | Stainless Steel | 152 | 229 | 140 | 3200 |
| | SX0.200 | Stainless Steel | 152 | 229 | 200 | 4000 |
| | MSX0.140 | Mild Steel | 152 | 229 | 140 | 3200 |
| | MSX0.200 | Mild Steel | 152 | 229 | 200 | 4000 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Ratina

19.874W



Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | |
|-----------|----------------------------|
| SAK 2.5 | 56 |
| SAK 4 | 52 |
| SAK 6 | 42 |
| SAK 10 | 34 |
| SAK 16 | 14 |
| SAK 35 | 10 |
| SAK 70 | 7 |
| WDU 2.5 | 67 |
| WDU 4 | 56 |
| WDU 6 | 42 |
| WDU 10 | √34 |
| WDU 16 | 14 |
| | |
| | |
| < | |
| | $\langle \diamond \rangle$ |

| Phoenix | |
|---------------|------|
| UK 2.5 N | 68 |
| UK 3 N | 68 |
| UK 5 N | △ 56 |
| UK 10 N | 34 |
| UK 16 N | 14 |
| UK 35 W | 2/11 |
| | 7 |
| 169 | |
| | |
| | |
| \Rightarrow | |
| | |
| 7 | |
| | |
| | |
| | |
| | |

| minals to be titted | | | | | |
|---------------------|----|--|--|--|--|
| Wago | | | | | |
| 280-992 | 31 | | | | |
| 280-999 | 31 | | | | |
| 281-691 | 27 | | | | |
| 281-992 | 27 | | | | |
| 281-993 | 27 | | | | |
| 282-691 | 21 | | | | |
| 284-691 | 16 | | | | |
| 283-691 | 28 | | | | |
| 285-691 | 0 | | | | |
| 280-998 | 31 | | | | |
| 281-998 | 27 | | | | |
| 264-120 | 56 | | | | |
| 264-220 | 32 | | | | |
| 264-132(2) | 12 | | | | |
| 264-134(4) | 8 | | | | |
| 262-132(2) | 12 | | | | |
| 244 134(4) | Ω | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side B - D | |
|--------|------------|-----|------------|-----|
| | 140 | 200 | 140 | 200 |
| Width | 119 | 119 | 189 | 189 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side B - D | | |
|------|------|-------|------------|-----|--|
| Size | 140 | 200 | 140 | 200 | |
| M16 | 6 | 12 | 10 | 20 | |
| M20 | 4 | 9 | 8 | 12 | |
| M25 | 2 | 6 | 4 | 9 | |
| M32 | 2 | 4 | 3 | 6 | |
| M40 | 1 | 2 | 2 | 4 | |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| | \$X0.5.140 | Stainless Steel | 184 | 274 | 140 | 5000 |
| J | SX0.5.200 | Stainless Steel | 184 | 274 | 200 | 6000 |
| Y | MSX0.5.140 | Mild Steel | 184 | 274 | 140 | 5000 |
| I | MSX0.5.200 | Mild Steel | 184 | 274 | 200 | 6000 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

29.206W



Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and thigh the earth stud and entry location will permit the required number of fernifinals to be fitted

| Weidmulle | |
|-----------|----|
| SAK 2.5 | 72 |
| SAK 4 | 66 |
| SAK 6 | 54 |
| SAK 10 | 44 |
| SAK 16 | 18 |
| SAK 35 | 14 |
| SAK 70 | 10 |
| WDU 2.5 | 86 |
| WDU 4 | 72 |
| WDU 6 | 54 |
| WDU 10 | |
| WDU 16 | 18 |
| | |
| | |
| | |
| | |
| 71 | 7) |

| Phoenix | |
|-----------|----|
| UK 2.5 N | 86 |
| UK 3 N | 86 |
| UK 5 N | |
| UK 10 N _ | 44 |
| UK 16 N | 18 |
| UK 35 W | 14 |
| | 7 |
| 164 | |
| | |
| | |
| 3 | |
| | |
| 7 | |
| | |
| | |
| | |
| | |

| minas to be lined | | | | | |
|-------------------|----|--|--|--|--|
| Wago | | | | | |
| 280-992 | 41 | | | | |
| 280-999 | 41 | | | | |
| 281-691 | 34 | | | | |
| 281-992 | 34 | | | | |
| 281-993 | 34 | | | | |
| 282-691 | 27 | | | | |
| 284-691 | 21 | | | | |
| 283-691 | 18 | | | | |
| 285-691 | 12 | | | | |
| 280-998 | 41 | | | | |
| 281-998 | 34 | | | | |
| 264-120 | 72 | | | | |
| 264-220 | 42 | | | | |
| 264-132(2) | 14 | | | | |
| 264-134(4) | 10 | | | | |
| 262-132(2) | 14 | | | | |
| 264-134(4) | 10 | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side B - D | |
|--------|------------|-----|------------|-----|
| | 140 | 200 | 140 | 200 |
| Width | 169 | 169 | 239 | 239 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side B - D | | |
|------|------|-------|------------|-----|--|
| Size | 140 | 200 | 140 | 200 | |
| M16 | 10 | 20 | 14 | 28 | |
| M20 | 6 | 12 | 10 | 18 | |
| M25 | 3 | 9 | 5 | 12 | |
| M32 | 2 | 4 | 4 | 8 | |
| M40 | 2 | 2 | 3 | 6 | |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------|------------|-------------|------------|------------|
| SX1.140 | Stainless Steel | 234 | 324 | 140 | 6300 |
| SX1.200 | Stainless Steel | 234 | 324 | 200 | 7200 |
| MSX1.140 | Mild Steel | 234 | 324 | 140 | 6300 |
| MSX1.200 | Mild Steel | 234 | 324 | 200 | 7200 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

SX1.5 / MSX1.5 Stainless Steel and Mild Steel Enclosures

Application

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Ratina

32.284W



Terminal Populations (Maximum Number of Rails = 3)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | r |
|-----------|-------------------|
| SAK 2.5 | 99 |
| SAK 4 | 93 |
| SAK 6 | 75 |
| SAK 10 | 60 |
| SAK 16 | 34 |
| SAK 35 | 24 |
| SAK 70 | 20 |
| WDU 2.5 | 118 |
| WDU 4 | 99 |
| WDU 6 | 75 |
| WDU 10 | 60 |
| WDU 16 | 34 |
| | |
| < | |
| | 11 11 |
| < | > // |
| | $\langle \rangle$ |
| 17 | // |

| | Phoenix | | | |
|---|----------|--------|---|-----|
| | UK 2.5 N | 120 | / | 1.1 |
| | UK 3 N | 120 | | 1 |
| | UK 5 N | 99 | |). |
| | UK 10 N | √ 60 | / | 1 |
| | UK 16 N | \\34 ○ | | , |
| | UK 35 N | 26 | | |
| | | 7/ | | |
| | | } | | |
| | 12/ | | | |
| À | | | | |
| / |) | | | |
| - | 7) | | | |
| 7 | | | | |
| | 7 | | | |
| | | | | |
| | | | | |
| | | | | |

| Musicile 10 De illied | | | | | |
|-----------------------|----|--|--|--|--|
| Wago | | | | | |
| 280-992 | 74 | | | | |
| 280-999 | 74 | | | | |
| 281-691 | 64 | | | | |
| 281-992 | 64 | | | | |
| 281-993 | 64 | | | | |
| 282-691 | 48 | | | | |
| 284-691 | 38 | | | | |
| 283-691 | 32 | | | | |
| 285-691 | 11 | | | | |
| 280-998 | 74 | | | | |
| 281-998 | 64 | | | | |
| 264-120 | 99 | | | | |
| 264-220 | 60 | | | | |
| 264-132(2) | 21 | | | | |
| 264-134(4) | 15 | | | | |
| 262-132(2) | 21 | | | | |
| 264-134(4) | 15 | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side B - D | |
|--------|------------|-----|------------|-----|
| | 140 | 200 | 140 | 200 |
| Width | 241 | 241 | 221 | 221 |
| Height | 75 | 135 | 75 | 135 |


^{*} With alandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side B - D | | |
|------|------|-------|------------|-----|--|
| 3120 | 140 | 200 | 140 | 200 | |
| M16 | 14 | 28 | 12 | 25 | |
| M20 | 10 | 18 | 10 | 16 | |
| M25 | 5 | 12 | 4 | 12 | |
| M32 | 4 | 8 | 3 | 6 | |
| M40 | 3 | 6 | 3 | 4 | |

^{*} Using standard gland clearances

| 2 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| | SX1.5.740 | Stainless Steel | 306 | 306 | 140 | 7300 |
| Ì | SX1.5.200 | Stainless Steel | 306 | 306 | 200 | 8800 |
| | SX1.5.300 | Stainless Steel | 306 | 306 | 300 | 11300 |
| Ì | MSX1.5.140 | Mild Steel | 306 | 306 | 140 | 7300 |
| | MSX1.5.200 | Mild Steel | 306 | 306 | 200 | 8800 |
| | MSX1.5.300 | Mild Steel | 306 | 306 | 300 | 11300 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

36,500W



Calculations do not include the use of end stops, end plates and separarfars. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of ferningists to be fitted

| SAK 2.5 132 SAK 4 123 SAK 6 99 SAK 10 78 SAK 16 66 SAK 35 42 SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 WDU 16 66 | Weidmuller | | | | |
|---|------------|------|--|--|--|
| SAK 6 99 SAK 10 78 SAK 16 66 SAK 35 42 SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 2.5 | 132 | | | |
| SAK 10 78 SAK 16 66 SAK 35 42 SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 4 | 123 | | | |
| SAK 16 66 SAK 35 42 SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 6 | 99 | | | |
| SAK 35 42 SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 10 | 78 | | | |
| SAK 70 24 WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 16 | 66 | | | |
| WDU 2.5 129 WDU 4 132 WDU 6 99 WDU 10 78 | SAK 35 | 42 | | | |
| WDU 4 132 WDU 6 99 WDU 10 78 | SAK 70 | 24 | | | |
| WDU 6 99 WDU 10 78 | WDU 2.5 | 129 | | | |
| WDU 10 78 | WDU 4 | 132 | | | |
| | WDU 6 | 99 | | | |
| WDU 16 66 | WDU 10 | 78 | | | |
| | WDU 16 | △66~ | | | |
| | | | | | |
| | , | | | | |
| | | | | | |
| | | | | | |
| \Diamond | | | | | |

| | Phoenix | |
|---|-----------|-------|
| | UK 2.5 N | 156 |
| | UK 3 N | 156 (|
| | UK 5 N | 132 |
| | UK 10 N | √ 78 |
| | UK 16 N _ | 86 |
| | UK 35 N | 54 |
| | | 7/ |
| | | |
| | " La | |
| 4 | | |
| / | | |
| 7 | 3) | |
| 7 | , | |
| | | |
| | | |
| | | |
| | | |

| 150 |
|-----|
| 150 |
| 126 |
| 126 |
| 84 |
| 99 |
| 78 |
| 44 |
| 30 |
| 150 |
| 126 |
| 132 |
| 78 |
| 27 |
| 18 |
| 27 |
| 18 |
| |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side | B - D |
|--------|------------|-----|------|-------|
| | 140 | 200 | 140 | 200 |
| Width | 307 | 307 | 239 | 239 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side A - C | | Side B - D | |
|------|------------|-----|------------|-----|
| Size | 140 | 200 | 140 | 200 |
| M16 | 18 | 36 | 14 | 28 |
| M20 | 14 | 24 | 10 | 18 |
| M25 | 6 | 18 | 6 | 12 |
| M32 | 5 | 10 | 4 | 8 |
| M40 | 4 | 8 | 3 | 6 |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| 1 | SX2.140 | Stainless Steel | 372 | 324 | 140 | 9500 |
| | SX2.200 | Stainless Steel | 372 | 324 | 200 | 11300 |
| | SX2.300 | Stainless Steel | 372 | 324 | 300 | 14300 |
| ĺ | MSX2.140 | Mild Steel | 372 | 324 | 140 | 9500 |
| | MSX2.200 | Mild Steel | 372 | 324 | 200 | 11300 |
| | MSX2.300 | Mild Steel | 372 | 324 | 300 | 14300 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22)
CSA Ex e (Class 1 Zone 1 & Zone 2)
FM AEx e(Class 1 Zone 1 & Zone 2)
TR AEX e(Class 1 Zone 1 & Zone 2)
NEMA 4X (CSA, UL & FM)
Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating 42.289W

Terminal Populations (Maximum Number of Rails = 3)

Calculations do not include the use of end stops, end plates and separators, Check that the enclosure can accommodate the cable bending radius and that/the earth stud and entry location will permit the required number of terminals/sp be/fitted.

| Weidmulle | |
|-----------|------|
| SAK 2.5 | 168 |
| SAK 4 | 156 |
| SAK 6 | 126 |
| SAK 10 | 102 |
| SAK 16 | 84 |
| SAK 35 | 63 |
| SAK 70 | 45 |
| WDU 2.5 | 201 |
| WDU 4 | 168 |
| WDU 6 | 126 |
| WDU 10 | 102 |
| WDU 16 | 84 〈 |
| | |
| | |
| | |
| 4 | |
| | |

| | Phoenix | | | _\ |
|---|--------------------------|------|------|------------|
| | UK 2.5 N | 201 | | 28 |
| | UK 3 N | 201/ | [] | 28 |
| | UK 5 N | 168 | |)2) |
| | UK 10 N | 102 |) "/ | 2 8 |
| | UK 16 N | 84 | ` | 28 |
| | UK 35 N 🤇 | 69 | | 28 |
| | | | | 28 |
| | | 7) | | 28 |
| | 16 | | | 28 |
| , | | | | 28 |
| < | | | | 28 |
| _ | | | | 20 |
| / | } | | | 2 |
| _ | $\langle \gamma \rangle$ | | | 20 |
| | | | | 20 |
| | | | | 20 |
| | | | | 20 |

| Wago | |
|------------|-----|
| 280-992 | 189 |
| 280-999 | 189 |
| 281-691 | 162 |
| 281-992 | 162 |
| 281-993 | 108 |
| 282-691 | 126 |
| 284-691 | 99 |
| 283-691 | 56 |
| 285-691 | 38 |
| 280-998 | 189 |
| 281-998 | 162 |
| 264-120 | 168 |
| 264-220 | 99 |
| 264-132(2) | 36 |
| 264-134(4) | 24 |
| 262-132(2) | 36 |
| 264-134(4) | 24 |

Drilling Envelope Dimensions (mm)

| | Side A - C | | Side | B - D |
|--------|------------|-----|------|-------|
| | 140 | 200 | 140 | 200 |
| Width | 307 | 307 | 363 | 363 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side A - C | | Side B - D | |
|------|------------|-----|------------|-----|
| SIZE | 140 | 200 | 140 | 200 |
| M16 | 16 | 36 | 20 | 45 |
| M20 | 12 | 24 | 16 | 28 |
| M25 | 7 | 15 | 8 | 21 |
| M32 | 5 | 10 | 6 | 12 |
| M40 | 4 | 8 | 5 | 8 |

^{*} Using standard gland clearances

| S | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| _ | SX3.140 | Stainless Steel | 372 | 448 | 140 | 11300 |
| | SX3,200 | Stainless Steel | 372 | 448 | 200 | 13300 |
| | SX3.300 | Stainless Steel | 372 | 448 | 300 | 16600 |
| | MSX3.140 | Mild Steel | 372 | 448 | 140 | 11300 |
| | MSX3.200 | Mild Steel | 372 | 448 | 200 | 13300 |
| | MSX3.300 | Mild Steel | 372 | 448 | 300 | 16600 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating 44.726W



Terminal Populations (Maximum Number of Rails = 3)

Calculations do not include the use of end stops, end plates and separators, Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | | | |
|------------|------|--|--|--|
| SAK 2.5 | 198 | | | |
| SAK 4 | 183 | | | |
| SAK 6 | 150 | | | |
| SAK 10 | 120 | | | |
| SAK 16 | 99 | | | |
| SAK 35 | 75 | | | |
| SAK 70 | 54 | | | |
| WDU 2.5 | 237 | | | |
| WDU 4 | 198 | | | |
| WDU 6 | 150 | | | |
| WDU 10 | 120 | | | |
| WDU 16 | 99 〈 | | | |
| | 10 | | | |
| < | | | | |
| | | | | |
| (| | | | |
| | | | | |
| | | | | |

| | | _ |
|-----------|------|---|
| Phoenix | | |
| UK 2.5 N | 237 | / |
| UK 3 N | 237 | |
| UK 5 N | 198 | |
| UK 10 N | 102 | Ţ |
| UK 16 N | 99 🛇 | ` |
| UK 35 N 🔷 | 81 | |
| 4 | | |
| | 7) | |
| (| | |
| | | |
| | | |
| 7/ | | |
| | | |
| \supset | | |
| | | |
| | | |
| | | |

| /,// | |
|------------|-----|
| Wago | |
| 280-992 | 222 |
| 280-999 | 222 |
| 281-691 | 189 |
| 281-992 | 189 |
| 281-993 | 126 |
| 282-691 | 147 |
| 284-691 | 117 |
| 283-691 | 66 |
| 285-691 | 44 |
| 280-998 | 222 |
| 281-998 | 189 |
| 264-120 | 198 |
| 264-220 | 117 |
| 264-132(2) | 42 |
| 264-134(4) | 30 |
| 262-132(2) | 42 |
| 264-134(4) | 30 |

Drilling Envelope Dimensions (mm)

| | Side A - C 140 200 | | Side B - D | |
|--------|-----------------------|-----|------------|-----|
| | | | 140 | 200 |
| Width | 307 | 307 | 425 | 425 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C Side B - [| | B - D |
|------|------|------------------|-----|-------|
| 3120 | 140 | 200 | 140 | 200 |
| M16 | 18 | 36 | 26 | 52 |
| M20 | 14 | 24 | 20 | 36 |
| M25 | 6 | 18 | 10 | 24 |
| M32 | 5 | 10 | 7 | 14 |
| M40 | 4 | 8 | 6 | 10 |

^{*} Using standard gland clearances

| \rangle | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-----------|-------------|-----------------|------------|-------------|------------|------------|
| | SX4.140 | Stainless Steel | 372 | 510 | 140 | 12700 |
| | SX4.200 | Stainless Steel | 372 | 510 | 200 | 14800 |
| \ | SX4.300 | Stainless Steel | 372 | 510 | 300 | 18300 |
| | MSX4.140 | Mild Steel | 372 | 510 | 140 | 12700 |
| | MSX4.200 | Mild Steel | 372 | 510 | 200 | 14800 |
| | MSX4.300 | Mild Steel | 372 | 510 | 300 | 18300 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

50.328W



Terminal Populations (Maximum Number of Rails = 4)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | r |
|-----------|-------|
| SAK 2.5 | 264 |
| SAK 4 | 244 |
| SAK 6 | 200 |
| SAK 10 | 160 |
| SAK 16 | 132 |
| SAK 35 | 100 |
| SAK 70 | 72 |
| WDU 2.5 | 316 |
| WDU 4 | 264 |
| WDU 6 | 200 |
| WDU 10 | 160 |
| WDU 16 | 132 🤇 |
| | 00 |
| < | |
| | |
| _ | |
| | |

| | Phoenix | | ١. |
|---|---------------|---------------|----|
| | UK 2.5 N | 316 | ۱ |
| | UK 3 N | 316 | |
| | UK 5 N | 264 | |
| | UK 10 N | 160 | |
| | UK 16 N | 132 △ | |
| | UK 35 N 🔍 | 108 | |
| | | | |
| | | 1) | |
| | | | |
| 7 | | | |
| | | | |
| | | | |
| \ | 7 | | |
| 1 | \rightarrow | | |
| | | | |
| | | | |
| | | | |

| Wago | |
|------------|-----|
| 280-992 | 296 |
| 280-999 | 296 |
| 281-691 | 252 |
| 281-992 | 252 |
| 281-993 | 189 |
| 282-691 | 196 |
| 284-691 | 156 |
| 283-691 | 99 |
| 285-691 | 66 |
| 280-998 | 296 |
| 281-998 | 252 |
| 264-120 | 264 |
| 264-220 | 156 |
| 264-132(2) | 56 |
| 264-134(4) | 40 |
| 262-132(2) | 56 |
| 264-134(4) | 40 |

Drilling Envelope Dimensions (mm)

| | Side A - C 140 200 | | Side | B - D |
|--------|-----------------------|-----|------|-------|
| | | | 140 | 200 |
| Width | 445 | 445 | 425 | 425 |
| Height | 75 | 135 | 75 | 135 |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C Side B - | | B - D |
|------|------|----------------|-----|-------|
| Size | 140 | 200 | 140 | 200 |
| M16 | 26 | 55 | 26 | 52 |
| M20 | 20 | 36 | 20 | 36 |
| M25 | 10 | 27 | 10 | 24 |
| M32 | 7 | 14 | 7 | 14 |
| M40 | 6 | 12 | 6 | 10 |

^{*} Using standard gland clearances

| 2 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| / | SX5_140 | Stainless Steel | 510 | 510 | 140 | 17000 |
| Ì | SX5.200 | Stainless Steel | 510 | 510 | 200 | 20000 |
| / | SX5.300 | Stainless Steel | 510 | 510 | 300 | 25000 |
| Ì | MSX5.140 | Mild Steel | 510 | 510 | 140 | 17000 |
| | MSX5.200 | Mild Steel | 510 | 510 | 200 | 20000 |
| | MSX5.300 | Mild Steel | 510 | 510 | 300 | 25000 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR CU Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

-50°C to +175°C Hazardous Area: Non Hazardous: -60°C to +200°C

Power Rating

57.383W



Terminal Populations (Maximum Number of Rails = 4)

U

U U U

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | r |
|-----------|-------|
| SAK 2.5 | 440 |
| SAK 4 | 404 |
| SAK 6 | 332 |
| SAK 10 | 264 |
| SAK 16 | 220 |
| SAK 35 | 168 |
| SAK 70 | 120 |
| WDU 2.5 | 528 |
| WDU 4 | 440 |
| WDU 6 | 332 |
| WDU 10 | 264 |
| WDU 16 | 220 < |
| | |
| < | |
| | |
| | |
| | |

| noenix | | | wago | |
|-----------|--------|-----------|------------|--|
| K 2.5 N | 524 | (| 280-992 | |
| K 3 N | 524 | | 280-999 | |
| K 5 N | 440 | | 281-691 | |
| K 10 N | 264 | \bigvee | 281-992 | |
| K 16 N | ⟨229 △ | | 281-993 | |
| K 35 N 🧷 | 176 | | 282-691 | |
| | | | 284-691 | |
| | 2) | | 283-691 | |
| 16 | | | 285-691 | |
| | | | 280-998 | |
| 7 | | | 281-998 | |
| | | | 264-120 | |
| \supset | | | 264-220 | |
| | | | 264-132(2) | |
| | | | 264-134(4) | |
| | | | 262-132(2) | |
| | | | 264-134(4) | |

Drilling Envelope Dimensions (mm)

| | Side A - C 140 200 | | Side | B - D |
|--------|-----------------------|-----|------|-------|
| | | | 140 | 200 |
| Width | 445 | 445 | 695 | 695 |
| Height | 75 | 135 | 75 | 135 |

^{*} With glandplate fitted

496


496

Gland Entry Matrix *

| Size | Side A - C | | Side B - D | |
|------|------------|-----|------------|-----|
| SIZE | 140 | 200 | 140 | 200 |
| M16 | 26 | 55 | 42 | 85 |
| M20 | 20 | 36 | 34 | 60 |
| M25 | 10 | 27 | 18 | 42 |
| M32 | 7 | 14 | 11 | 22 |
| M40 | 6 | 12 | 10 | 18 |

^{*} Using standard gland clearances

| J | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| | SX6_140 | Stainless Steel | 510 | 780 | 140 | 24000 |
| Ī | SX6.200 | Stainless Steel | 510 | 780 | 200 | 27000 |
| 1 | SX6.300 | Stainless Steel | 510 | 780 | 300 | 32000 |
| Ì | MSX6.140 | Mild Steel | 510 | 780 | 140 | 24000 |
| | MSX6.200 | Mild Steel | 510 | 780 | 200 | 27000 |
| | MSX6.300 | Mild Steel | 510 | 780 | 300 | 32000 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR AEX e(Class 1 Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating 68.000W



Terminal Populations (Maximum Number of Rails = 5)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmulle | r |
|-----------|-------|
| SAK 2.5 | 685 |
| SAK 4 | 635 |
| SAK 6 | 520 |
| SAK 10 | 415 |
| SAK 16 | 345 |
| SAK 35 | 260 |
| SAK 70 | 150 |
| WDU 2.5 | 822 |
| WDU 4 | 685 |
| WDU 6 | 520 |
| WDU 10 | 415 |
| WDU 16 | 345 🥎 |
| | 1 |
| < | |
| | |
| _ | |
| | |

| Phoenix | | | Wago | |
|------------|--------------------------|--------|------------|-----|
| IK 2.5 N | 820 | (| 280-992 | 775 |
| IK 3 N | 820 | | 280-999 | 775 |
| IK 5 N | 685 | | 281-691 | 660 |
| IK 10 N | 415 | \leq | 281-992 | 660 |
| IK 16 N | ⟨345 ८⟩ | | 281-993 | 528 |
| IK 35 N 🤇 | 280 | | 282-691 | 510 |
| | | | 284-691 | 410 |
| | $\langle \gamma \rangle$ | | 283-691 | 272 |
| 16 | | | 285-691 | 188 |
| | | | 280-998 | 775 |
| 7) | | | 281-998 | 660 |
| | | | 264-120 | 685 |
| \searrow | | | 264-220 | 410 |
| | | | 264-132(2) | 145 |
| | | | 264-134(4) | 100 |
| | | | 262-132(2) | 145 |
| | | | 264-134(4) | 100 |

Drilling Envelope Dimensions (mm)

| | Side | A - C | Side B - D | | |
|--------|------|-------|------------|-----|--|
| | 140 | 200 | 140 | 200 | |
| Width | 585 | 585 | 865 | 865 | |
| Height | 75 | 135 | 75 | 135 | |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side B - D | | |
|------|---------|-------|------------|-----|--|
| SIZE | 140 200 | | 140 | 200 | |
| M16 | 36 | 72 | 54 | 110 | |
| M20 | 28 | 48 | 42 | 72 | |
| M25 | 14 | 36 | 22 | 54 | |
| M32 | 10 | 20 | 14 | 28 | |
| M40 | 8 | 16 | 12 | 24 | |

^{*} Using standard gland clearances

| ζ, | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|----|-------------|-----------------|------------|-------------|------------|------------|
| / | SX7.140 | Stainless Steel | 650 | 950 | 140 | 35000 |
| Ì | SX7.200 | Stainless Steel | 650 | 950 | 200 | 39000 |
| / | SX7.300 | Stainless Steel | 650 | 950 | 300 | 45000 |
| Ì | MSX7.140 | Mild Steel | 650 | 950 | 140 | 35000 |
| | MSX7.200 | Mild Steel | 650 | 950 | 200 | 39000 |
| | MSX7.300 | Mild Steel | 650 | 950 | 300 | 45000 |



Hazardous and Industrial areas

Protection Degree IP66 or 67

Certification

ATEX & IECEx (Zone 0, 1 & 2; Zone 20, 21 & 22) CSA Ex e (Class 1 Zone 1 & Zone 2) FM AEx e(Class 1 Zone 1 & Zone 2) TR AEX e(Class 1 Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Stainless steel 316 (1.4404) or Mild steel

Temperature Rating

Hazardous Area: -50°C to +175°C Non Hazardous: -60°C to +200°C

Power Rating

119.462W

Terminal Populations (Maximum Number of Rails = 5)

U

U

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| SAK 4 63 | 95 35 |
|------------|----------|
| | 35 |
| | |
| SAK 6 52 | 20 |
| SAK 10 41 | 15 |
| SAK 16 34 | 45 |
| SAK 35 26 | 50 |
| SAK 70 15 | 50 |
| WDU 2.5 15 | 54 |
| WDU 4 12 | 95 |
| WDU 6 52 | 20 |
| WDU 10 41 | 15 |
| WDU 16 34 | 45 🤇 |
| | |
| 1 | // |
| | |
| | 7_ |
| | \vee |

| hoenix | | 6 | Wago | |
|----------|--------------------------|--------|------------|-----|
| K 2.5 N | 820 | (| 280-992 | 775 |
| K 3 N | 820 | | 280-999 | 775 |
| K 5 N | 685 | | 281-691 | 660 |
| K 10 N | 415 | \leq | 281-992 | 660 |
| K 16 N | 345 🔿 | ` | 281-993 | 528 |
| K 35 N 🤇 | 280 | | 282-691 | 510 |
| | | | 284-691 | 410 |
| | $\langle \gamma \rangle$ | | 283-691 | 272 |
| [[| | | 285-691 | 188 |
| | | | 280-998 | 775 |
| 4) | | | 281-998 | 660 |
| 1 | | | 264-120 | 685 |
| \ | | | 264-220 | 410 |
| | | | 264-132(2) | 145 |
| | | | 264-134(4) | 100 |
| | | | 262-132(2) | 145 |
| | | | 264-134(4) | 100 |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side | A - C | Side B - D | | | |
|--------|------|-------|------------|------|--|--|
| | 140 | 200 | 140 | 200 | | |
| Width | 735 | 735 | 1165 | 1165 | | |
| Height | 75 | 135 | 75 | 135 | | |


^{*} With glandplate fitted

Gland Entry Matrix *

| Size | Side | A - C | Side | B - D |
|------|---------|-------|------|-------|
| SIZE | 140 200 | | 140 | 200 |
| M16 | 45 | 90 | 72 | 150 |
| M20 | 36 | 60 | 58 | 100 |
| M25 | 18 | 45 | 30 | 72 |
| M32 | 12 | 24 | 20 | 40 |
| M40 | 10 | 20 | 17 | 32 |

^{*} Using standard gland clearances

| ı | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------|------------|-------------|------------|------------|
| 1 | SX8_140 | Stainless Steel | 800 | 1250 | 140 | 40000 |
| | SX8.200 | Stainless Steel | 800 | 1250 | 200 | 52000 |
| 1 | SX8.300 | Stainless Steel | 800 | 1250 | 300 | 72000 |
| | MSX8.140 | Mild Steel | 800 | 1250 | 140 | 40000 |
| | MSX8.200 | Mild Steel | 800 | 1250 | 200 | 52000 |
| | MSX8.300 | Mild Steel | 800 | 1250 | 300 | 72000 |





Glass Reinforced Polyester Enclosures



The BPG range comprises 16 sizes of enclosure manufactured in glass reinforced polyester (GRP). This material is highly resistant to contamination from oils, fats, aliphatic and aromatic carbohydrates, bacteria and enzymes. It is also suitable for LSOH (low smoke zero halogen) applications.

Polyester gives excellent mechanical strength and life expectancy. The wall thickness is sufficient to allow tapped entry holes to be machined in the walls of the enclosure and it provides a very good alternative to aluminium or cast iron.



ABTECH mould the BPC range from SMC material rather than DMC which is the most common form of GRP. In this method the glass reinforcement takes the form of sheets rather than short strands. This gives much greater mechanical strength and also in the event of the enclosure being exposed to fire conditions the structure holds together even if the resin is depleted due to the elevated emperatures. This is demonstrated by the fact that the BPG range when fitted with ceramic terminals meets the requirements of IEC 331 (750°C (1382°F) for 3 hours) and also BS6387/1983 (950°C (1742°F) for 3 hours - flame only). Further information about this testing procedure can be found in Section 6 of this catalogue.



Due to the enclosure's labyrinth seal system, whereby the seal is protected from external forces, the BPG range has excellent ingress protection qualities which mean that the enclosures are tested to and passed IP66/67. They have also undergone and passed the Shell/ERA deluge test which was devised to dequately test enclosures and electrical equipment which is routinely subjected to ship decks conditions or fire deluge systems.

The mounting holes, although contained within the profile of the enclosure, sit outside the seal and all external fasteners and fixings are manufactured from 316 grade stainless steel to ensure reliability.

The BPG range has many features which lend itself to a whole host of applications including both industrial and hazardous area junction boxes, OEM applications, fire protection systems, tunnel wiring etc.


The BPG range can be machined, drilled, tapped with various thread forms, painted and of course it can be moulded in a variety of colours which gives a much improved durability of colour over painting.

The BPG range is also available carbon loaded (BPGC) which helps to reduce the surface resistance of the material and consequently reduce the risk of spark from static build up.

Earthing can be accomplished by various means. Internal / external earth stud which in turn can be connected to the terminal mounting rail or component mounting plate, an earth continuity plate (ECP) can be fitted around the inner walls to provide continuity for cable glands and various rail mounted earth terminals or proprietary earth bars can be fitted inside the enclosure.

The BPG range is suitable for a wide range of ambient conditions. Hazardous Area certified enclosures are suitable for -65°C to $+130^{\circ}\text{C}$. Non-Ex versions are suitable from -60°C to $+130^{\circ}\text{C}$. For certified apparatus contact the ABTECH Sales department for ambient operating temperatures.

The BPG and BPGC enclosures are suitable for use in hazardous areas and can be supplied with a number of certificates, specifically ATEX EEx'e' to BS EN 50019 (zone 1 & 2) EEx'nA' to BS EN50021 (zone 2) and NEMA 4X (CSA, UL & FM class 1, div 2).



The BPG range can be supplied fitted with any component approved terminal to apparatus level or can be supplied empty as component approved for the clients own certification requirements.

BPG Range Features

- Wide Operating Temperature (-60°C to + 130°C) (-76°F to +266°F)
- Ingress Protection up to IP67
- Fire Resistant to IEC331
- Impact Resistant > 7Nm/
- UV Resistant
- Can be drilled and tapped to accommodate most thread forms (NPT for example).
- UL, CSA, IEC Ex, ATEX, InMetro and TR CU Approvals
- Ideal for Petrochemical and Marine applications

Certification and Coding

| 75 | Zone 0 | Zone 20 | Zone 1 | Zone 21 | Zone 2 | Zone 22 |
|-------|--------|---------|--------|---------|--------|---------|
| -Ex e | | | • | • | • | • |
| Ex ai | • | • | • | • | • | • |
| Ex ab | | | • | • | • | • |
| Ex nA | | | | | • | • |
| Ex nR | | | | | • | • |

Available with Apparatus or Component certification

Accessories and Options

The following table is a list of the available accessories suitable for particular standard sizes of BPG enclosures. Care should be taken when ordering accessories for use with enclosures intended for hazardous areas to ensure that compliance with certification is retained.


| Part Number | Width (mm) | Height (mm) | Depth (mm) | C - Carbon Loaded (see note 1) | EX - Ex Certified (see note 2) | EC - Earth Continuity Plate | ES - Earth Stud | AS - Allen Head Fixing Screws | TP - Tamper Proof Screws | EH - External Hinges | MP - Component Mounting Plate | MF - External Mounting Feet | EB - Internal Earthing Bar | MR - DIN Standard Mounting Rail | RF - RFI Protection (see note 4) |
|-------------|------------|-------------|------------|--|---------------------------------------|---------------------------------------|-----------------|----------------------------------|--------------------------|----------------------|----------------------------------|---------------------------------------|----------------------------|------------------------------------|--|
| BPG1 | 80 | 75 | 55 | | | | | 0 | 6 | R | | | | | |
| BPG2 | 110 | 75 | 55 | | | | | | | 19. | | | | | |
| BPG3 | 160 | 75 | 55 | | | | | | | | | | | | |
| BPG4 | 190 | 75 | 55 | | | 7 | . ((| | • | | | | | | |
| BPG4.5 | 190 | 75 | 75 | | | S | | | | | | | | | |
| BPG5 | 230 | 75 | 55 | | | 24 | | | | | | | | | |
| BPG6 | 122 | 120 | 90 | | | | | | | | | | | | |
| BPG7 | 220 | 120 | 90 | % | No. | 3 | | | | | | | | | |
| BPG8 | 160 | 160 | 90 | | 7 | | | | | | | | | | |
| BPG9 | 260 | 160 | 90 | | 7 | | | | | | | | | | |
| BPG10 | 360 | 160 | 90 | γ 🌕 | | | | | | | | | | | |
| BPG11 | 560 | 160 | (A) | | | | | | | | | | | | |
| BPG12 | 255 | 250 | 120 | | | | | | | | | | | | |
| BPG13 | 400 | 250 | 120 | | | | | | | | | | | | |
| BPG13.5 | 400 | 250 | 160 | | | | | | | | | | | | |
| BPG14 | 600 | 250 | 120 | | | | | | | | | | | | |
| BPG15 | 400 | 405 | 120 | | | | | | | | | | | | |

Ordering Example;

BPG8 EX EC EB MR

(BPG8 EX Certified with Earth Continuity Plate, Internal Earthing Bar and DIN standard Mounting Rail)

- 1.Carbon loading gives a surface tracking value of between $10M\Omega$ and $10G\Omega$. Surface colour is black.
- 2. EEx'e' certification may be component or apparatus certified please specify your requirements.
- 3. Radio Frequency Interference (RF) gasket may reduce IP rating. Enclosure may also be internally coated with RFI material.




Copper earth continuity plate (must also be fitted with earth stud)



Earth Stud (either brass or stainless steel)



Allen Head fixing screws (grade 316)



Tamper-proof screws



External hinges



Component mounting plate (tufnol as standard, steel an option)



External mounting feet (stainless steel 316)



Internal Earthing bar (can be fitted with clamps)



DIN standard mounting rail (TS15, TS32 or TS35)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

8.390W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | |
|---------------|------------|---|
| BK4 (4 way) | 2 | |
| BK6 (6 way) | 1 | |
| BK12 (12 way) | 1 | |
| MK 6/3 | 1 | |
| MK 6/4 | 1 | |
| MK 6/6 | 1 | |
| SAK 2.5 | 0 | |
| SAK 4 | 0 | |
| SAK 6N | 0 | / |
| SAK 10 | 0 | |
| SAK 16 | 0 < | |
| SAK 35 | Q | / |
| | | 1 |
| | | |
| | | |
| | | |
| | \Diamond | |

| | | | Wago |
|--------------------|-----|---|------------|
| MA2.5/5 | 9/ | | 280-992 |
| M4/6 | ζ6(| \ | 280-999 |
| M6/8 | 0 | | 281-691 |
| M10/10 | 0 ^ | | 281-992 |
| M16/12 | 0 | | 281-993 |
| M35/16 | 9 | | 282-691 |
| 47 | | | 284-691 |
| | | | 283-691 |
| 163 | | | 285-691 |
| | | | 280-998 |
| | | | 281-998 |
| \circlearrowleft | | | 264-120 |
| \rangle | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 50 | 26 |
| Height | 36 | 30 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 1 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |
| | | |

^{*} Using standard gland clearances

Specifications

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG1 | GRP | 80 | 75 | 55 | 230 |
| ١ | BPGC1 | Carbon Loaded GRP | 80 | 75 | 55 | 230 |

0

0

0

0

0

0

0

0

0

0

0


12

7

2

1

2



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

Hazardous Area: -65°C to +130°C -70°C to +130°C Non Hazardous:

Power Rating

8.551W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending adjus and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 1 |
| BK12 (12 way) | 1 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 < |
| SAK 35 | 0 |
| | |
| | |
| | 1 0 |
| | |
| | \Diamond |

| Entrelec | | | Wage | |
|-----------|-------|---|------------|----|
| MA2.5/5 | 9/ | | 280-992 | 0 |
| M4/6 | ⟨ø⟨ | | 280-999 | 0 |
| M6/8 | 6 | _ | 281-691 | 0 |
| M10/10 🔷 | 0 ^ | | 281-992 | 0 |
| M16/12 | //0 ~ | | 281-993 | 0 |
| M35/16 | 9 | | 282-691 | 0 |
| 4 | | | 284-691 | 0 |
| | | | 283-691 | 0 |
| | | | 285-691 | 0 |
| <u> </u> | | | 280-998 | 0 |
| | | | 281-998 | 0 |
| \supset | | | 264-120 | 12 |
| > | | | 264-220 | 7 |
| | | | 264-132(2) | 2 |
| | | | 264-134(4) | 1 |
| | | | 262-132(2) | 2 |
| | | | 264-134(4) | 1 |
| | | | | |

Drilling Envelope Dimensions (mm)


| Side A - C | | Side B - D |
|------------|----|------------|
| Width | 80 | 26 |
| Height | 36 | 30 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 2 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |
| | | |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG2 | GRP | 110 | 75 | 55 | 230 |
| \ | BPGC2 | Carbon Loaded GRP | 110 | 75 | 55 | 230 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

Hazardous Area: -65°C to +130°C Non Hazardous: -70°C to +130°C

Power Rating

8.833W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of ferminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 3 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 2 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 < |
| SAK 35 | 0 \ |
| | |
| | |
| | |
| \Diamond | |
| | \Diamond |

| 0_ |
|-----|
| Ø(|
| 8 |
| 0 |
| 0 < |
| 70 |
| ` |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |

| Wago | |
|------------|----|
| 280-992 | 0 |
| 280-999 | 0 |
| 281-691 | 0 |
| 281-992 | 0 |
| 281-993 | 0 |
| 282-691 | 0 |
| 284-691 | 0 |
| 283-691 | 0 |
| 285-691 | 0 |
| 280-998 | 0 |
| 281-998 | 0 |
| 264-120 | 19 |
| 264-220 | 11 |
| 264-132(2) | 4 |
| 264-134(4) | 3 |
| 262-132(2) | 4 |
| 264-134(4) | 3 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 130 | 27 |
| Height | 36 | 29 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG3 | GRP | 160 | 75 | 55 | 405 |
| 1 | BPGC3 | Carbon Loaded GRP | 160 | 75 | 55 | 405 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

9.012W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 4 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 3 |
| MK 6/4 | 3 |
| MK 6/6 | 2 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 |
| SAK 35 | 0 |
| | |
| | |
| | |
| \Diamond | |
| | \Diamond |

| 0 |
|-------|
| 0 |
| 8 |
| 0 |
| (0 < |
| 70 |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |

| 7 / / | |
|------------|----|
| Wago | |
| 280-992 | 0 |
| 280-999 | 0 |
| 281-691 | 0 |
| 281-992 | 0 |
| 281-993 | 0 |
| 282-691 | 0 |
| 284-691 | 0 |
| 283-691 | 0 |
| 285-691 | 0 |
| 280-998 | 0 |
| 281-998 | 0 |
| 264-120 | 25 |
| 264-220 | 15 |
| 264-132(2) | 5 |
| 264-134(4) | 3 |
| 262-132(2) | 5 |
| 264-134(4) | 3 |

Drilling Envelope Dimensions (mm)


| Side A - C | | Side B - D |
|------------|-----|------------|
| Width | 160 | 27 |
| Height | 36 | 30 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|-------|------------|------------|
| M16 5 | | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| É | PG4 | GRP | 190 | 75 | 55 | 450 |
| E | BPGC4 | Carbon Loaded GRP | 190 | 75 | 55 | 450 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

9.260W



Drilling Envelope Dimensions (mm)

Side A - C Side B - D Width 55 52 160 19 Height

Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 4 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 1 |
| MK 6/3 | 3 |
| MK 6/4 | 3 |
| MK 6/6 | 2 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 < |
| SAK 35 | 0 |
| <u> </u> | |
| | |
| 1 | |
| \Diamond | |
| | \Diamond |
| | |


| Entrelec | | (| Wago | |
|--------------|-----|---|------------|----|
| ΛA2.5/5 | 0_ | \ | 280-992 | 0 |
| Λ4/6 | 0 | | 280-999 | 0 |
| <i>1</i> 6/8 | 8 | | 281-691 | 0 |
| ۸10/10 | 0 | \ | 281-992 | 0 |
| Λ16/12 \ | 0 < | > | 281-993 | 0 |
| л35/16 | 10 | | 282-691 | 0 |
| A | 1 | | 284-691 | 0 |
| | | | 283-691 | 0 |
| (15) | | | 285-691 | 0 |
| 7/ | | | 280-998 | 28 |
| | | | 281-998 | 24 |
| 4 | | | 264-120 | 25 |
| | | | 264-220 | 15 |
| | | | 264-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | 262-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | | |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 0 |
| M20 | 4 | 0 |
| M25 | 3 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| _ | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG4.5 | GRP | 190 | 75 | 75 | 529 |
| \ | BPGC4.5 | Carbon Loaded GRP | 190 | 75 | 75 | 529 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

9.260W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|-------------------|
| BK4 (4 way) | 0 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/3 | 4 |
| MK 6/4 | 4 |
| MK 6/6 | 2 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 < |
| SAK 35 | 0 |
| | |
| | |
| | |
| \Diamond | 11. |
| | \Diamond^{\vee} |

| Lillelec | | (| **ago | |
|----------|-----|-------------|------------|----|
| MA2.5/5 | 0 | \ | 280-992 | 0 |
| M4/6 | 9 | / | 280-999 | 0 |
| M6/8 | 8 | | 281-691 | 0 |
| M10/10 | 0 | \setminus | 281-992 | 0 |
| M16/12 | 0 < | > | 281-993 | 0 |
| M35/16 | 70 | | 282-691 | 0 |
| | | | 284-691 | 0 |
| | \ | | 283-691 | 0 |
| (12) | | | 285-691 | 0 |
| 7// | | | 280-998 | 0 |
| | | | 281-998 | 0 |
| 77 | | | 264-120 | 32 |
| \ | | | 264-220 | 19 |
| | | | 264-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | 262-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 90 | 23 |
| Height | 30 | 28 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------|------------|-------------|------------|------------|
| BPG5 | GRP | 230 | 75 | 55 | 529 |
| BPGC5 | Carbon Loaded GRP | 230 | 75 | 55 | 529 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

9.378W



Terminal Populations (Maximum Number of Rails = 1)

٨

٨

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 14 |
| SAK 4 | 13 |
| SAK 6N | 10 |
| SAK 10 | 8 |
| SAK 16 | 7 |
| SAK 35 | 5 |
| < | // |
| | |
| | / // |
| \Diamond | |
| | \Diamond |

| MA2.5/5 | 17_ | / | 280-992 | 15 |
|---------|-----|----------|------------|----|
| M4/6 | 1/4 | | 280-999 | 15 |
| M6/8 | 8/ | | 281-691 | 13 |
| M10/10 | 8 | \ | 281-992 | 13 |
| M16/12 | 7 🔾 | P | 281-993 | 13 |
| M35/16 | 25 | | 282-691 | 10 |
| | 7 | | 284-691 | 8 |
| | | | 283-691 | 6 |
| (12) | | | 285-691 | 0 |
| 7// | | | 280-998 | 15 |
| | | | 281-998 | 13 |
| 7/ | | | 264-120 | 13 |
| \ | | | 264-220 | 8 |
| ` | | | 264-132(2) | 3 |
| | | | 264-134(4) | 2 |
| | | | 262-132(2) | 3 |
| | | | 264-134(4) | 2 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 75 | 54 |
| Height | 60 | 53 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 2 | 1 |
| M20 | 1 | 1 |
| M25 | 1 | 1 |
| M32 | 1 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG6 | GRP | 122 | 120 | 90 | 750 |
| \ | BPGC6 | Carbon Loaded GRP | 122 | 120 | 90 | 750 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

Hazardous Area: -65°C to +130°C Non Hazardous: -70°C to +130°C

Power Ratina

10.500W



Terminal Populations (Maximum Number of Rails = 1)

7 7 7

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 5 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 2 |
| MK 6/3 | 4 |
| MK 6/4 | 4 |
| MK 6/6 | 2 |
| SAK 2.5 | 30 |
| SAK 4 | 28 |
| SAK 6N | 22 |
| SAK 10 | 18 |
| SAK 16 | 15 _ |
| SAK 35 | -11 < |
| | |
| | |
| | |
| \Diamond | 11. |
| | \Diamond |

| Entrelec | | (| Wago | |
|----------------|--------|---|------------|----|
| AA2.5/5 | 36 | \ | 280-992 | 34 |
| Λ4/6 | 30 | \ | 280-999 | 34 |
| 76/8 | 22 | | 281-691 | 29 |
| ۸10/10 | 18 | \ | 281-992 | 29 |
| л16/12 <u></u> | \ 15 < | > | 281-993 | 29 |
| N35/16 | 77 | | 282-691 | 22 |
| M | } | | 284-691 | 18 |
| | | | 283-691 | 15 |
| | | | 285-691 | 0 |
| 7/1 | | | 280-998 | 34 |
| $\overline{}$ | | | 281-998 | 29 |
| 4 | | | 264-120 | 30 |
| ~ | | | 264-220 | 18 |
| | | | 264-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | 262-132(2) | 6 |
| | | | 264-134(4) | 4 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 180 | 56 |
| Height | 60 | 53 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 10 | 1 |
| M20 | 4 | 1 |
| M25 | 3 | 1 |
| M32 | 3 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| ₹ | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG7 | GRP | 220 | 120 | 90 | 1060 |
| ĺ | BPGC7 | Carbon Loaded GRP | 220 | 120 | 90 | 1060 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

10.348W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 3 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 2 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 20 |
| SAK 4 | 19 |
| SAK 6N | 15 |
| SAK 10 | 12 |
| SAK 16 | 10 _ |
| SAK 35 | 7 < |
| | |
| | |
| | |
| \Diamond | 1/ , |
| | \Diamond |

| | | 1 ' |
|---------|--------|-----|
| MA2.5/5 | 24 | 1 |
| M4/6 | 20 | \ |
| M6/8 | 75 | |
| M10/10 | 12 | / |
| M16/12 | \ 10 ○ | , |
| M35/16 | 713 | |
| | | |
| | | |
| (64) | | |
| | | |
| | | |
| 7/ | | |
| \ | | |
| 7 | | |
| | | |
| | | |
| | | |
| | | |

| Wago | |
|------------|----|
| 280-992 | 22 |
| 280-999 | 22 |
| 281-691 | 19 |
| 281-992 | 19 |
| 281-993 | 19 |
| 282-691 | 15 |
| 284-691 | 12 |
| 283-691 | 10 |
| 285-691 | 0 |
| 280-998 | 22 |
| 281-998 | 19 |
| 264-120 | 20 |
| 264-220 | 12 |
| 264-132(2) | 4 |
| 264-134(4) | 3 |
| 262-132(2) | 4 |
| 264-134(4) | 2 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 108 | 78 |
| Height | 65 | 58 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 2 |
| M20 | 2 | 2 |
| M25 | 2 | 1 |
| M32 | 1 | 1 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| ζ | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG8 | GRP | 160 | 160 | 90 | 1060 |
| | BPGC8 | Carbon Loaded GRP | 160 | 160 | 90 | 1060 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

40

40

34

34

34

27

21

18

0

40

34

36

21

7

5

7

5

Application

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

11.933W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/3 | 4 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 36 |
| SAK 4 | 34 |
| SAK 6N | 27 |
| SAK 10 | 22 |
| SAK 16 | 18 ~ |
| SAK 35 | 14 |
| < | // |
| | |
| | |
| \Diamond | 11. |
| | \Diamond |

| MA2.5/5 | 43 | \ | 280-992 |
|---------|------|---|------------|
| M4/6 | 36 | \ | 280-999 |
| M6/8 | 27 | | 281-691 |
| M10/10 | 22 | \ | 281-992 |
| M16/12 | 18 🔾 | > | 281-993 |
| M35/16 | 214 | | 282-691 |
| | } | | 284-691 |
| | / | | 283-691 |
| (1997) | | | 285-691 |
| | | | 280-998 |
| | | | 281-998 |
| 1 | | | 264-120 |
| , | | | 264-220 |
| 7 | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |
| | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 210 | 80 |
| Height | 65 | 60 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 4 |
| M20 | 6 | 2 |
| M25 | 4 | 1 |
| M32 | 3 | 1 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------|------------|-------------|------------|------------|
| BPG9 | GRP | 260 | 160 | 90 | 1170 |
| BPGC9 | Carbon Loaded GRP | 260 | 160 | 90 | 1170 |



7

Application

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

13.793W



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 9 |
| BK6 (6 way) | 6 |
| BK12 (12 way) | 3 |
| MK 6/3 | 6 |
| MK 6/4 | 6 |
| MK 6/6 | 4 |
| SAK 2.5 | 52 |
| SAK 4 | 48 |
| SAK 6N | 40 |
| SAK 10 | 32 |
| SAK 16 | 26 ~ |
| SAK 35 | 20 < |
| | // |
| | |
| | |
| \Diamond | |
| | \Diamond |

| Entrelec | | (| Wago | |
|-------------|------|---|------------|---|
| 1A2.5/5 | 63 | \ | 280-992 | ſ |
| 14/6 | 52 | / | 280-999 | I |
| 16/8 | 40 | | 281-691 | I |
| ۸10/10 | 32 | / | 281-992 | |
| 416/12 \(\) | 26 🔾 | > | 281-993 | I |
| N35/16 | 20 | | 282-691 | |
| | } | | 284-691 | |
| | | | 283-691 | L |
| (12) | | | 285-691 | |
| 31/ | | | 280-998 | L |
| \sim | | | 281-998 | L |
| 4 | | | 264-120 | L |
| ~ | | | 264-220 | L |
| | | | 264-132(2) | L |
| | | | 264-134(4) | L |
| | | | 262-132(2) | Ĺ |
| | | | 264-134(4) | |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 312 | 82 |
| Height | 65 | 60 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 18 | 4 |
| M20 | 8 | 2 |
| M25 | 6 | 1 |
| M32 | 5 | 1 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Z | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| - | BPG10 | GRP | 360 | 160 | 90 | 2150 |
| | BPGC10 | Carbon Loaded GRP | 360 | 160 | 90 | 2150 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester

Temperature Rating

Hazardous Area: Non Hazardous:

-65°C to +130°C -70°C to +130°C

Power Rating

18.338W



Terminal Populations (Maximum Number of Rails = 1)

MA

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 14 |
| BK6 (6 way) | 10 |
| BK12 (12 way) | 5 |
| MK 6/3 | 11 |
| MK 6/4 | 11 |
| MK 6/6 | 7 |
| SAK 2.5 | 85 |
| SAK 4 | 78 |
| SAK 6N | 64 |
| SAK 10 | 51 |
| SAK 16 | 43 ~ |
| SAK 35 | 32 < |
| | |
| | |
| | |
| \Diamond | 1 |
| | \Diamond |

| | | () | Mago | |
|-----------|--------|-----|------------|----|
| A2.5/5 | 101 | / | 280-992 | 96 |
| 4/6 | 85 | \ | 280-999 | 96 |
| 5/8 | 84 | | 281-691 | 82 |
| 10/10 | 51 | \ | 281-992 | 82 |
| 16/12 | √ 43 ♦ | P | 281-993 | 82 |
| 35/16 | √32 | | 282-691 | 63 |
| |) | | 284-691 | 51 |
| | / | | 283-691 | 42 |
| 12/ | | | 285-691 | 0 |
| 7/ | | | 280-998 | 96 |
| \supset | | | 281-998 | 82 |
| | | | 264-120 | 85 |
| ~ | | | 264-220 | 51 |
| | | | 264-132(2) | 18 |
| | | | 264-134(4) | 12 |
| | | | 262-132(2) | 17 |
| | | | 264-134(4) | 12 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 242 | 80 |
| Height | 65 (x2) | 60 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 28 | 4 |
| M20 | 12 | 2 |
| M25 | 10 | 1 |
| M32 | 8 | 1 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Ş | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| 1 | BPG-11 | GRP | 560 | 160 | 90 | 3200 |
| | BPGC11 | Carbon Loaded GRP | 560 | 160 | 90 | 3200 |



Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester

Temperature Rating

Hazardous Area: -65°C to +130°C Non Hazardous: -70°C to +130°C

Power Rating

15.474W



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | |
|---------------|-------------------|---|
| BK4 (4 way) | 12 | |
| BK6 (6 way) | 8 | |
| BK12 (12 way) | 4 | |
| MK 6/3 | 8 | |
| MK 6/4 | 8 | |
| MK 6/6 | 6 | |
| SAK 2.5 | 70 | |
| SAK 4 | 66 | |
| SAK 6N | 54 | |
| SAK 10 | 42 | K |
| SAK 16 | 36 ~ | / |
| SAK 35 | 20 < | |
| | | 7 |
| | | |
| | | |
| \Diamond | | |
| | \Diamond^{\vee} | |

| 1A2.5/5 | 84 | / | 280-992 | 78 |
|---------|--------|---|------------|----|
| 14/6 | 70 | | 280-999 | 78 |
| 16/8 | 54 | | 281-691 | 66 |
| 110/10 | 42 | \ | 281-992 | 66 |
| 116/12 | √ 36 ♦ | | 281-993 | 66 |
| 135/16 | 26 | | 282-691 | 52 |
| M | } | | 284-691 | 42 |
| | / | | 283-691 | 17 |
| [[] | | | 285-691 | 12 |
| | | | 280-998 | 78 |
| \ | | | 281-998 | 66 |
| | | | 264-120 | 70 |
| , | | | 264-220 | 42 |
| | | | 264-132(2) | 14 |
| | | | 264-134(4) | 10 |
| | | | 262-132(2) | 14 |
| | | | 264-134(4) | 8 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D | | |
|--------|------------|------------|--|--|
| Width | 205 | 170 | | |
| Height | 90 | 85 | | |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 15 | 12 |
| M20 | 10 | 8 |
| M25 | 6 | 4 |
| M32 | 3 | 2 |
| M40 | 3 | 2 |

^{*} Using standard gland clearances

| 4 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG12 | GRP | 255 | 250 | 120 | 3200 |
| l | BPGC12 | Carbon Loaded GRP | 255 | 250 | 120 | 3200 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: Non Hazardous: -70°C to +130°C

Power Rating

20.867W



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | |
|---------------|------|---|
| BK4 (4 way) | 20 | |
| BK6 (6 way) | 14 | |
| BK12 (12 way) | 6 | |
| MK 6/3 | 14 | |
| MK 6/4 | 14 | |
| MK 6/6 | 10 | |
| SAK 2.5 | 118 | |
| SAK 4 | 108 | |
| SAK 6N | 88 | |
| SAK 10 | 72 | 1 |
| SAK 16 | 60 ~ | ľ |
| SAK 35 | 36 | |
| | 7 | |
| | | |
| | | |
| \Diamond | | |
| | | |

| MA2.5/5 | 140 | |
|---------|--------|--|
| M4/6 | 118 | |
| M6/8 | 88 | |
| M10/10 | 72 | |
| M16/12 | √ 60 ♦ | |
| M35/16 | 244 | |
| | \ | |
| | | |
| (12) | | |
| | | |
| | | |
| 7/ | | |
| \ | | |
| 7 | | |
| | | |
| | | |
| | | |
| | | |

| Wago | |
|------------|-----|
| 280-992 | 132 |
| 280-999 | 132 |
| 281-691 | 114 |
| 281-992 | 114 |
| 281-993 | 114 |
| 282-691 | 88 |
| 284-691 | 70 |
| 283-691 | 29 |
| 285-691 | 20 |
| 280-998 | 132 |
| 281-998 | 114 |
| 264-120 | 118 |
| 264-220 | 70 |
| 264-132(2) | 24 |
| 264-134(4) | 16 |
| 262-132(2) | 24 |
| 264-134(4) | 16 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 350 | 170 |
| Height | 89 | 84 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 30 | 12 |
| M20 | 16 | 8 |
| M25 | 14 | 4 |
| M32 | 6 | 2 |
| M40 | 5 | 2 |

^{*} Using standard gland clearances

| > | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| | BPG13 | GRP | 400 | 250 | 120 | 3650 |
| ı | BPGC13 | Carbon Loaded GRP | 400 | 250 | 120 | 3650 |



Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

Hazardous Area: -65°C to +130°C Non Hazardous: -70°C to +130°C

Power Rating

20.867W



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 20 |
| BK6 (6 way) | 14 |
| BK12 (12 way) | 6 |
| MK 6/3 | 14 |
| MK 6/4 | 14 |
| MK 6/6 | 10 |
| SAK 2.5 | 118 |
| SAK 4 | 108 |
| SAK 6N | 88 |
| SAK 10 | 72 |
| SAK 16 | 60 ~ |
| SAK 35 | 36 |
| | |
| | |
| | |
| \Diamond | // , |
| | \Diamond |

| | | 1 1 | |
|--------------|---------------|-----|------------|
| ΛA2.5/5 | 140 | / | 280-992 |
| Λ4/6 | 118 | | 280-999 |
| <i>1</i> 6/8 | 88 | | 281-691 |
| ۸10/10 💍 | 72 | / | 281-992 |
| Λ16/12 \ | √ 60 ♦ | 2 | 281-993 |
| N35/16 | 244 | | 282-691 |
| | | | 284-691 |
| | / | | 283-691 |
| (12) | | | 285-691 |
| 7/ | | | 280-998 |
| | | | 281-998 |
| 4 | | | 264-120 |
| - | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |
| | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 350 | 170 |
| Height | 89 | 84 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 30 | 12 |
| M20 | 16 | 8 |
| M25 | 14 | 4 |
| M32 | 6 | 2 |
| M40 | 5 | 2 |

^{*} Using standard gland clearances

Specifications

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| 1 | BPG13.5 | GRP | 400 | 250 | 160 | 4872 |
| | BPGC13.5 | Carbon Loaded GRP | 400 | 250 | 160 | 4872 |



Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

Hazardous Area: Non Hazardous:

-65°C to +130°C -70°C to +130°C

Power Rating

30.384W



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 30 |
| BK6 (6 way) | 22 |
| BK12 (12 way) | 12 |
| MK 6/3 | 22 |
| MK 6/4 | 22 |
| MK 6/6 | 14 |
| SAK 2.5 | 182 |
| SAK 4 | 168 |
| SAK 6N | 138 |
| SAK 10 | 110 |
| SAK 16 | 92 ~ |
| SAK 35 | 70 🖯 |
| (| |
| | |
| | |
| \Diamond | 1/ , |
| | \Diamond |

| Entrelec | | (| Wago | |
|---------------------|----------|---|------------|-----|
| 1A2.5/5 | 218 | \ | 280-992 | 132 |
| 14/6 | 182 | | 280-999 | 132 |
| 16/8 | 138 | | 281-691 | 114 |
| 410/10 _^ | 110 | \ | 281-992 | 114 |
| 116/12 | 92 < | > | 281-993 | 114 |
| N35/16 | 270 | | 282-691 | 88 |
| R | } | | 284-691 | 70 |
| | <i>)</i> | | 283-691 | 29 |
| (12) | | | 285-691 | 20 |
| 7/ | | | 280-998 | 132 |
| \sim | | | 281-998 | 114 |
| 4) | | | 264-120 | 118 |
| | | | 264-220 | 70 |
| | | | 264-132(2) | 24 |
| | | | 264-134(4) | 16 |
| | | | 262-132(2) | 24 |
| | | | 264-134(4) | 16 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 260 | 168 |
| Height | 90 (x2) | 85 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 42 | 12 |
| M20 | 24 | 8 |
| M25 | 20 | 4 |
| M32 | 8 | 2 |
| M40 | 6 | 2 |

^{*} Using standard gland clearances

| 4 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------|------------|-------------|------------|------------|
| 1 | BPG14 | GRP | 600 | 250 | 120 | 5235 |
| ĺ | BRGC14 | Carbon Loaded GRP | 600 | 250 | 120 | 5235 |



BPG15 / BPGc15 Glass Reinforced Polyester Enclosures

Application

Hazardous and Industrial areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22) TR CU

NEMA 4X (CSA, UL & FM) Class 1 Division 2

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-65°C to +130°C Hazardous Area: -70°C to +130°C Non Hazardous:

Power Rating

31.350W



Terminal Populations (Maximum Number of Rails = 3)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|-----------------|
| BK4 (4 way) | 30 |
| BK6 (6 way) | 21 |
| BK12 (12 way) | 9 |
| MK 6/3 | 21 |
| MK 6/4 | 21 |
| MK 6/6 | 15 |
| SAK 2.5 | 177 |
| SAK 4 | 162 |
| SAK 6N | 132 |
| SAK 10 | 108 |
| SAK 16 | 90 _~ |
| SAK 35 | 66 |
| | |
| | |
| | |
| \Diamond | 1. |
| | \Diamond |
| | \Diamond |

| | | 1 | - | |
|---------|------|---|------------|-----|
| 1A2.5/5 | 210 | \ | 280-992 | 198 |
| 14/6 | 1,77 | | 280-999 | 198 |
| 16/8 | 132 | | 281-691 | 171 |
| 110/10 | 108 | \ | 281-992 | 171 |
| 116/12 | 90 🗘 | P | 281-993 | 171 |
| 135/16 | 786 | | 282-691 | 132 |
| K I | } | | 284-691 | 105 |
| |) | | 283-691 | 58 |
| | | | 285-691 | 40 |
| 7/ | | | 280-998 | 198 |
| | | | 281-998 | 171 |
| , | | | 264-120 | 177 |
| | | | 264-220 | 101 |
| | | | 264-132(2) | 36 |
| | | | 264-134(4) | 24 |
| | | | 262-132(2) | 36 |
| | | | 264-134(4) | 24 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D | |
|--------|------------|------------|--|
| Width | 352 | 327 | |
| Height | 89 | 84 | |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 30 | 24 |
| M20 | 18 | 16 |
| M25 | 14 | 10 |
| M32 | 6 | 5 |
| M40 | 5 | 4 |

^{*} Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------|------------|-------------|------------|------------|
| BPG-15 | GRP | 400 | 405 | 120 | 5580 |
| BRGC15 | Carbon Loaded GRP | 400 | 405 | 120 | 5580 |







The ABTECH BPGA range comprises of three types of BPG enclosure in two different sizes. These enclosures are available pre-assembled and are readily available from stock. The BPGA enclosures are ideal for a range of uses such as lighting, power and instrument junction boxes.



As an option, we are also able to supply a post mounting bracket, allowing the user to install the BPGA range onto posts measuring between 50 and 100mm in diameter. All bracket components are manufactured from stainless steel, ensuring an extremely ong life span even in harsh environmental conditions. Please contact the Sales Department for further details.

These enclosures are manufactured in impact resistant glass-reinforced polyester which has an ingress protection rating of IP66/67 and are Shell/ERA deluge tested.

The enclosures come equipped with terminals as shown in the specification table for each individual box, copper earth continuity plate and are also fitted with a brass M6 internal/external earth stud.



Each enclosure comes pre-drilled with four M20 tapped cable entries and is supplied with certified planking plugs. The BPGA range of enclosures are ATEX and IECEx certified Ex'e' and are suitable for use in Category 2/Zone 1 & 21 and Category 3/Zone 2 & 22 areas according to EN 60079-14.



Application Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22)

Ex e IIC T6/T5 Gb, Ex tb IIIC T85°C/T100°C

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Ambient Temperature Rating -50°C to +40°C at T6

-50°C to +55°C at T5


Power Rating

9.378W

Fitted Components



| Entries | Blanking Plugs | Terminals | \Box | Earth | Continuity Plate | Earth Stud |
|-------------------------------------|------------------------|----------------------------------|--------|-------|------------------|--------------------|
| 4 x M20 (2 x Side A, 2 x Side C) | 4 off (Ex'e' rated) | 6 x SAK 2 5 (linked in pairs) | \sim | | Yes (Copper) | Yes (Brass, M6) |
| | | \wedge | |) | | |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------|------------|-------------|------------|------------|
| BPG6A120 | GRP (grey) | 122 | 120 | 90 | 1140 |
| BPGC6A120 | GRP (black) | 122 | 120 | 90 | 1140 |

BPGA125

Application

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22)

Coding

Ex e IIC T6/T5 Gb, Ex tb IIIC T85°C/T100°C

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Ambient Temperature Rating

-50°C to +40°C at T6 -50°C to +55°C at T5


Power Rating

9.378W

Fitted Components



| Entries | Blanking Plugs | Terminals | Earth Continuity Plate | Earth Stud |
|--------------------------|----------------|-------------------|------------------------|-------------|
| 4 x M20 | 4 off | 6 x WDU6 | Yes | Yes |
| (2 x Side A, 2 x Side C) | (Ex'e' rated) | (linked in pairs) | (Copper) | (Brass, M6) |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

| \ | > Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|---------------|-------------|------------|-------------|------------|------------|
| | BPG6A125 | GRP (grey) | 122 | 120 | 90 | 1062 |
| | BPGC6A125 | GRP (black) | 122 | 120 | 90 | 1062 |

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX & IECEx (Zone 1 & 2; Zone 21 & 22)

Ex e IIC T6/T5 Gb, Ex tb IIIC T85°C/T100°C

Material

Glass Reinforced Polyester (RAL7001 grey) or Carbon Loaded Glass Reinforced Polyester (Black)

Ambient Temperature Rating -50°C to +40°C at T6 -50°C to +55°C at T5


Power Rating

10.348W

Fitted Components




| Entries | Blanking Plugs | Terminals | Earth Continuity Plate | Earth Stud |
|--------------------------|----------------|--------------|------------------------|-------------|
| 4 x M20 | 4 off | 13 x SAK 2.5 | Yes | Yes |
| (2 x Side A, 2 x Side C) | (Ex'e' rated) | | (Copper) | (Brass, M6) |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------|------------|-------------|------------|------------|
| BPG8A160 | GRP (grey) | 160 | 160 | 90 | 1740 |
| BPGC8A160 | GRP (black) | 160 | 160 | 90 | 1740 |





The ZAG range of enclosures comprises of 19 different sizes of enclosures and is precision die cast in AL-Si 12 grade (LM24) aluminium alloy. This is considered to be the most suitable grade of aluminium for maximum corrosion resistance especially in salt laden atmospheres.

Additional optional protection methods such as alochrome, anodising and epoxy polyester painting coupled with the fitment of captive 316 grade stainless steel lid retaining screws further enhance the anti-corrosion properties of the enclosure.



The wall thickness is sufficient to allow tapped entry holes to be machined into the walls or the base of the enclosure.

Due to the enclosure's labyrinth seal system, similar to that of the BPG range of enclosures, whereby the seal is protected from external forces, the ZAG enclosure has excellent ingress protection qualities this means that the enclosure has been tested to and passed IP65/66/67.

The mounting holes although contained within the profile of the enclosure, sit outside the seal and all the external fasteners and fixings are manufactured from 316 grade stainless steel mounting feet are offered as an option.

The ZAG range has many features which lend itself to a whole host of applications including junction boxes, both industrial and hazardous area, and especially OEM applications, where the excellent machining qualities of aluminium come to the fore.

The ZAG range can be drilled and tapped with various thread forms and it readily accepts most paint finishes and colours.



The ZAG range is particularly suitable for the engraving of instructions and decals and this method provides excellent durability. Silk screen printing is also available.

All of this can be achieved even in relatively small batches which makes the ZAG range ideal for the small to medium size manufacturers who can achieve a custom enclosure economically.

Earthing of the enclosure can be accomplished by various means. Internal / external stainless steel earth studs which in turn can be connected to the terminal mounting rail or component plate and various rail mounted earth terminals or proprietary earth bars can be fitted inside the enclosure. Due to the fact that aluminium is an excellent conductor, earthing for cable glands is provided through contact with the enclosure wall with no further earthing required.



The ZAG range is suitable for a wide range of ambient conditions. Hazardous Area certified enclosures are suitable for -65°C to + 150°C (-85°F to +302°F). Please refer to the relevant Ex certificate for full details.



The ZAG enclosures are suitable for use in hazardous areas and can be supplied with a number of certificates:

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

ZAG Range Features

- Wide Operating Temperature (- 65°C to +150°C) (-85°F to +302°F)
- Ingress Protection up to IP67
- · Painted and Unpainted versions
- Impact Resistant > 7 Nm
- Corrosion Resistant
- Can be drilled and tapped to accommodate most thread forms (NPT for example)
- Certification for use in Zone 1 and 2
- UL, CSA, IEC Ex, ATEX, FM, InMetro and TR CU Approvals
- Ideal for Petrochemical and Marine applications



Accessories and Options

The following table is a list of the available accessories suitable for particular standard sizes of ZAG enclosures. Care should be taken when ordering accessories for use with enclosures intended for hazardous areas to ensure that compliance with certification is retained.

| Part Number | Width (mm) | Height (mm) | Depth (mm) | UP - Unpainted | EX - Ex Certified (see note 1) | AL - Alochromed | ES - Earth Stud | AS - Allen Head Fixing Screws | TP - Tamper Proof Screws | EH - External Hinges | MP - Component Mounting Plate | MF - External Mounting Feet | EB - Internal Earthing Bar | MR - DIN Standard Mounting Rail | RF - RFI Protection (see note 3) |
|-------------|------------|-------------|------------|-----------------------|---------------------------------------|-----------------|-----------------|---|------------------------------------|----------------------|----------------------------------|---------------------------------------|-------------------------------|------------------------------------|----------------------------------|
| ZAG1 | 50 | 45 | 30 | • | | • | | • | • | 7 | \Diamond | | | | • |
| ZAG2 | 58 | 64 | 34 | • | | | | • | | 7) |) | | | | • |
| ZAG3 | 98 | 64 | 34 | • | • | • | • | • (| | 17 | • | | | | • |
| ZAG4 | 150 | 64 | 34 | • | • | • | • | |) | | • | • | | | • |
| ZAG5 | 75 | 80 | 57 | • | • | • | \ | |))• | • | • | • | | | • |
| ZAG6 | 125 | 80 | 57 | • | • | \wedge | 3 | 9 | • | • | | • | | • | • |
| ZAG7 | 175 | 80 | 57 | • | • | 55 | >>/ | • | • | • | • | • | | • | • |
| ZAG8 | 250 | 80 | 56 | • | • (| | 7 | | • | • | | • | | • | • |
| ZAG9 | 122 | 120 | 80 | | | | • | | • | • | | | | | • |
| ZAG9/9 | 122 | 120 | 90 | | | | • | • | | | • | • | • | | |
| ZAG10 | 220 | 120 | 80 | | | | • | • | | | • | • | • | | |
| ZAG10/9 | 220 | 120 | 90 | | > <u> </u> | | • | • | | | • | • | • | | |
| ZAG11 | 160 | 160 | 90 | • | • | • | • | • | • | • | • | • | • | | • |
| ZAG12 | 260 | 160 | 90 | • | • | • | • | • | • | • | • | • | • | | • |
| ZAG13 | 360 | 160 | 90 | | | | • | • | | | • | • | • | | |
| ZAG14 | 560 | 160 | 90 | | | | • | • | | | • | • | • | | |
| ZAG15 | 202 | 230 | 110 | • | | • | • | • | • | | • | • | • | | • |
| ZAG16 | 330 | 230 | 110 | • | • | • | • | • | • | • | • | • | • | | • |
| ZAG21 | 1/20 | 360 | 80 | | • | • | • | • | | | • | • | • | | |

Ordering Example:

ZAG10 UP AS


(7AG 10 unpainted, Allen Head Fixing Screws

^{1.} ÉEx'e' certification may be component or apparatus certified - please specify your requirements.

^{2.} Radio Frequency Interference (RFI) gasket may reduce IP rating. Enclosure may also be internally coated with RFI material.




Unpainted (raw) finish



Earth Stud (either brass or stainless steel)



Allen Head fixing screws (grade 316)



Tamper-proof screws



External hinges



Component mounting plate (tufnol as standard, steel an option)



External mounting feet (stainless steel 316)



Internal Earthing bar (can be fitted with clamps)



DIN standard mounting rail (TS15, TS32 or TS35)

Application Industrial areas

Protection Degree IP65

Certification

Not applicable

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating -65° to 150° C (-85° to 302° F)

Power Rating Not Applicable



Terminal Populations (Maximum Number of Rails = 0)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|-----|
| BK4 (4 way) | 0 |
| BK6 (6 way) | 0 |
| BK12 (12 way) | 0 |
| MK 6/3 | 0 |
| MK 6/4 | 0 |
| MK 6/6 | 0 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 🔿 |
| SAK 35 | (a) |
| ^ | |
| | |
| | |
| | |
| | / > |

| | | _ \ | |
|-----------|-------|-----|------------|
| 1A2.5/5 | 0 | | 280-992 |
| 14/6 | 0 | ` | 280-999 |
| 16/8 | 0 | 7 | 281-691 |
| 110/10 | 0 ^ | | 281-992 |
| 116/12 | \\o | | 281-993 |
| 135/16 | 79 | | 282-691 |
| 47 | | | 284-691 |
| | | | 283-691 |
| | | | 285-691 |
| 3 | | | 280-998 |
| | | | 281-998 |
| \supset | | | 264-120 |
| | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |
| • | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 24 | 16 |
| Height | 21 | 21 |

Gland Entry Matrix *

| Side A - C | Side B - D |
|------------|---------------------------|
| 1 | 0 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| | Side A - C 1 0 0 0 0 0 0 |

^{*} Using standard gland clearances

| / | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| _ | ZAG1 | Painted Aluminium (RAL7001) | 50 | 45 | 30 | 75 |
| \ | ZAG1R | Unpainted Aluminium | 50 | 45 | 30 | 75 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Hazardous and Industrial areas

Protection Degree

IP65

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

0.900W



Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of ferminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 1 |
| BK6 (6 way) | 0 |
| BK12 (12 way) | 0 |
| MK 6/3 | 1 |
| MK 6/4 | 0 |
| MK 6/6 | 0 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 < |
| SAK 16 | Q |
| SAK 35 | 0 |
| | |
| | |
| | |
| | \Diamond |
| ()>. ~ | • |

| ntrelec | | | Wago | |
|-------------------------------|--------------|-----|------------|---|
| A2.5/5 | ₹6(| \ | 280-992 | (|
| 14/6 | 0 |) (| 280-999 | (|
| 6/8 | 0 ^ | | 281-691 | (|
| 110/10 | <u>\</u> 0 ~ | | 281-992 | (|
| 116/12 | 10 | | 281-993 | (|
| 35/16 | 0 < | | 282-691 | (|
| | | | 284-691 | (|
| | | | 283-691 | (|
| $\langle \mathcal{I} \rangle$ | | | 285-691 | (|
| | | | 280-998 | (|
| \supset | | | 281-998 | (|
| | | | 264-120 | (|
| | | | 264-220 | (|
| | | | 264-132(2) | (|
| | | | 264-134(4) | (|
| | | | 262-132(2) | (|
| | | | 264-134(4) | (|




| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 21 | 29 |
| Height | 20 | 20 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M12 | 1 | 1 |
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| _ | × × × / | | | | | | |
|---|-------------|-----------------------------|------------|-------------|------------|------------|--|
| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) | |
| \ | ZAG2 | Painted Aluminium (RAL7001) | 58 | 64 | 34 | 170 | |
| \ | ZAG2R | Unpainted Aluminium | 58 | 64 | 34 | 170 | |



Hazardous and Industrial areas

Protection Degree

IP65

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

1.200W

Terminal Populations (Maximum Number of Rails 70)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 1 |
| BK6 (6 way) | 1 |
| BK12 (12 way) | 0 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 _ |
| SAK 16 | _0 \ |
| SAK 35 | 10 |
| | |
| | |
| \Diamond | |
| | \Diamond |
| ()) | |

| Entrelec | | / | Wago |
|----------|----------|---|------------|
| MA2.5/5 | 1 | | 280-992 |
| M4/6 | 0 | | 280-999 |
| M6/8 | 0 ^ | | 281-691 |
| M10/10 | \ 0 \ | 1 | 281-992 |
| M16/12 | 10 | | 281-993 |
| M35/16 |) 0 | | 282-691 |
| | / | | 284-691 |
| 163 | | | 283-691 |
| | | | 285-691 |
| | | | 280-998 |
| 1) | | | 281-998 |
| | | | 264-120 |
| ~ | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |

| | Drilling | Envelope | Dimensions | (mm) |
|--|----------|----------|------------|------|
|--|----------|----------|------------|------|

| | | Side A - C | Side B - D |
|---|--------|------------|------------|
| l | Width | 68 | 19 |
| | Height | 21 | 21 |

Gland Entry Matrix *

0

0

0

0

0

0

0

0

0

0

0

0

0

0


0

0

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M12 | 3 | 1 |
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| \ | ZAG3 | Painted Aluminium (RAL7001) | 98 | 64 | 34 | 220 |
| \ | ZAG3R | Unpainted Aluminium | 98 | 64 | 34 | 220 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial and Hazardous areas

Protection Degree

IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Ratina

1.700W

Terminal Populations (Maximum Number of Rails/=0)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 3 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 3 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 / |
| SAK 16 | 0 |
| SAK 35 | 10 |
| | |
| | / / |
| \Diamond | |
| | \Diamond |
| . (()) | |

| | | | Wago | |
|---------|------------|---|------------|---|
| 1A2.5/5 | A (| | 280-992 | 0 |
| 14/6 | 0 | | 280-999 | 0 |
| 16/8 | 0 | | 281-691 | 0 |
| 110/10 | 0 < | 2 | 281-992 | 0 |
| 116/12 | 19 | | 281-993 | 0 |
| 135/16 | \ 0 | | 282-691 | 0 |
| | | | 284-691 | 0 |
| 12 | | | 283-691 | 0 |
| 77/ | | | 285-691 | 0 |
| \ | | | 280-998 | 0 |
| | | | 281-998 | 0 |
| | | | 264-120 | 0 |
| | | | 264-220 | 0 |
| | | | 264-132(2) | 0 |
| | | | 264-134(4) | 0 |
| | | | 262-132(2) | 0 |
| | | | 264-134(4) | 0 |


Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 120 | 20 |
| Height | 22 | 22 |

Gland Entry Matrix *

| Side A - C | Side B - D |
|------------|---------------------------------|
| 4 | 1 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| 0 | 0 |
| | Side A - C 4 0 0 0 0 0 0 |

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) | |
|-------------|-----------------------------|------------|-------------|------------|------------|--|
| ZAG4 | Painted Aluminium (RAL7001) | 150 | 64 | 34 | 330 | |
| ZAG4R | Unpainted Aluminium | 150 | 64 | 34 | 330 | |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial and Hazardous areas

Protection Degree

IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

1.500W

Terminal Populations (Maximum Number of Rails/=1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 1 |
| BK6 (6 way) | 0 |
| BK12 (12 way) | 0 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 0 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 / |
| SAK 16 | 0 |
| SAK 35 | 10 |
| | |
| | / / |
| \Diamond | |
| | \Diamond |
| 77 | |

| | | | Wago | |
|----------|----------|---|------------|---|
| AA2.5/5 | A | | 280-992 | 0 |
| Λ4/6 | 0 | | 280-999 | 0 |
| M6/8 △ | 0 | | 281-691 | 0 |
| M10/10 ~ | 0 < | 2 | 281-992 | 0 |
| M16/12 | 10 | | 281-993 | 0 |
| 135/16 | 0 | | 282-691 | 0 |
| | | | 284-691 | 0 |
| 12 | | | 283-691 | 0 |
| 77/ | | | 285-691 | 0 |
| \ ~ | | | 280-998 | 0 |
| | | | 281-998 | 0 |
| | | | 264-120 | 6 |
| | | | 264-220 | 3 |
| | | | 264-132(2) | 1 |
| | | | 264-134(4) | 0 |
| | | | 262-132(2) | 1 |
| | | | 264-134(4) | 0 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 41 | 39 |
| Height | 37 | 31 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 1 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| \ | ZAG5 | Painted Aluminium (RAL7001) | 75 | 80 | 57 | 290 |
| | ZAG5R | Unpainted Aluminium | 75 | 80 | 57 | 290 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial and Hazardous areas

Protection Degree IP67

Certification ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

2.200W

Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|---|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 1 |
| BK12 (12 way) | 1 |
| MK 6/3 | 2 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 |
| SAK 35 | \ \\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\ |
| | |
| | |
| \Diamond | |
| | \Diamond |
| 71 | |

| Entrelec | | | Wago | |
|-----------|--------------|---|------------|--|
| MA2.5/5 | ,d(| | 280-992 | |
| M4/6 | 0 | | 280-999 | |
| M6/8 | 0 0 | | 281-691 | |
| M10/10 | <u></u> √0 < | 7 | 281-992 | |
| M16/12 | 20 | | 281-993 | |
| M35/16 | 0 | | 282-691 | |
| | | | 284-691 | |
| 12 | | | 283-691 | |
| | | | 285-691 | |
| | | | 280-998 | |
| <u>4</u> | | | 281-998 | |
| \rangle | | | 264-120 | |
| | | | 264-220 | |
| | | | 264-132(2) | |
| | | | 264-134(4) | |
| | | | 262-132(2) | |
| | | | 264-134(4) | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 95 | 42 |
| Height | 38 | 31 |


Gland Entry Matrix *

3

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 2 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| [| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| 7 | ZAG6 | Painted Aluminium (RAL7001) | 125 | 80 | 57 | 435 |
| Ī | ZAG6R | Unpainted Aluminium | 125 | 80 | 57 | 435 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

ZAG7 / ZAG7R Die Cast Aluminium Enclosures

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

2.900W

Terminal Populations (Maximum Number of Rails/=1)

٨

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 4 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 1 |
| MK 6/3 | 3 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 _ |
| SAK 16 | 0 |
| SAK 35 | 10 |
| | |
| | 1 |
| \Diamond | |
| | \Diamond |
| . 4(7) | |

| | | | Wago | |
|---------|------------|---|------------|--|
| ΛA2.5/5 | A (| | 280-992 | |
| Λ4/6 | 0 | | 280-999 | |
| Λ6/8 | 0 | | 281-691 | |
| и10/10 | \\ 0 \ | 2 | 281-992 | |
| л16/12 | 79 | | 281-993 | |
| 135/16 | \ 0 | | 282-691 | |
| | | | 284-691 | |
| 12 | | | 283-691 | |
| 77/ | | | 285-691 | |
| \ ~ | | | 280-998 | |
| 7 | | | 281-998 | |
| , | | | 264-120 | |
| | | | 264-220 | |
| | | | 264-132(2) | |
| | | | 264-134(4) | |
| | | | 262-132(2) | |
| | | | 264-134(4) | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D | | |
|--------|------------|------------|--|--|
| Width | 141 | 39 | | |
| Height | 37 | 31 | | |

Gland Entry Matrix *


0 0

4

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------------------|------------|-------------|------------|------------|
| ZAG7 | Painted Aluminium (RAL7001) | 175 | 80 | 57 | 540 |
| ZAG7R | Unpainted Aluminium | 175 | 80 | 57 | 540 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial and Hazardous areas

Protection Degree

IP65

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

2.900W

Terminal Populations (Maximum Number of Rails/=1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/3 | 4 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 / |
| SAK 16 | 0 |
| SAK 35 | 10 |
| | |
| | //// |
| \Diamond | |
| | \Diamond |
| 2(7) | |

| | | / | Wago | |
|----------|------------|---|------------|----|
| AA2.5/5 | A (| | 280-992 | 0 |
| Λ4/6 | 0 | | 280-999 | 0 |
| M6/8 △ | 0 | | 281-691 | 0 |
| M10/10 _ | \ o < | > | 281-992 | 0 |
| M16/12 | 10 | | 281-993 | 0 |
| 135/16 | \ 0 | | 282-691 | 0 |
| | | | 284-691 | 0 |
| 12 | | | 283-691 | 0 |
| 77/ | | | 285-691 | 0 |
| \ | | | 280-998 | 0 |
| | | | 281-998 | 0 |
| | | | 264-120 | 35 |
| | | | 264-220 | 21 |
| | | | 264-132(2) | 7 |
| | | | 264-134(4) | 5 |
| | | | 262-132(2) | 7 |
| | | | 264-134(4) | 5 |

Drilling Envelope Dimensions (mm)


| Side A - C | | Side B - D | |
|------------|-----|------------|--|
| Width | 222 | 31 | |
| Height | 35 | 42 | |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| Ì | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| 1 | ZAG8 | Painted Aluminium (RAL7001) | 250 | 80 | 56 | 710 |
| | ZAG8R | Unpainted Aluminium | 250 | 80 | 56 | 710 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

IP67

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Ratina

3.400W

Terminal Populations (Maximum Number of Rails 7)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 14 |
| SAK 4 | 13 |
| SAK 6N | 10 |
| SAK 10 | 8 / |
| SAK 16 | 7 |
| SAK 35 | 5 |
| | |
| | / / |
| \Diamond | |
| | \Diamond |
| 2(7) | |

| Entrelec | | Wago |
|----------------------------|----|-------------|
| 1A2.5/5 | 17 | 280-992 |
| 14/6 | 14 | 280-999 |
| 16/8 | 8 | 281-691 |
| ۸10/10 ح | 8 | 281-992 |
| 116/12 | 1 | 281-993 |
| 135/16 | 5 | 282-691 |
| | | 284-691 |
| 163 | | 283-691 |
| 77/ | | 285-691 |
| \ | | 280-998 |
| $\stackrel{\circ}{\smile}$ | | 281-998 |
| | | 264-120 |
| | | 264-220 |
| | | 264-132(2) |
| | | 264-134(4) |
| | | 262-132(2) |
| | | 264-134(4) |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 82 | 56 |
| Height | 55 | 45 |


Gland Entry Matrix *

> 3 2

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 2 | 1 |
| M20 | 2 | 1 |
| M25 | 1 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------------------|------------|-------------|------------|------------|
| ZAG9 | Painted Aluminium (RAL7001) | 122 | 120 | 80 | 940 |
| ZAG9R | Unpainted Aluminium | 122 | 120 | 80 | 940 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

3 2

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

3.400W

Terminal Populations (Maximum Number of Rails/=1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|-------------------------------------|------------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/3 | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 14 |
| SAK 4 | 13 |
| SAK 6N | 10 |
| SAK 10 | 8 / |
| SAK 16 | 7 |
| SAK 35 | 5 |
| | |
| , 7 | / / |
| \bar{\bar{\bar{\bar{\bar{\bar{\bar{ | |
| | \Diamond |
| 11 | |

| Entrelec | | | Wago |
|--------------|-----|-------------|------------|
| лА2.5/5 | 17 | | 280-992 |
| Λ4/6 | 14 | | 280-999 |
| Λ6/8 <u></u> | 8 _ | \setminus | 281-691 |
| и10/10 📈 | 8 | 7 | 281-992 |
| и16/12 | | | 281-993 |
| N35/16 | 5 | | 282-691 |
| | | | 284-691 |
| 12 | | | 283-691 |
| 77/ | | | 285-691 |
| \ ~ | | | 280-998 |
| 3 | | | 281-998 |
| , | | | 264-120 |
| | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 82 | 56 |
| Height | 55 | 45 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 2 | 1 |
| M20 | 2 | 1 |
| M25 | 1 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| - 2 | | | | | | |
|-----|-------------|-----------------------------|------------|-------------|------------|------------|
| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
| 1 | ZAG9-9 | Painted Aluminium (RAL7001) | 122 | 120 | 90 | 965 |
| | ZAG9-9R | Unpainted Aluminium | 122 | 120 | 90 | 965 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Ratina

5.400W

Terminal Populations (Maximum Number of Rails 7)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 5 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 2 |
| MK 6/3 | 5 |
| MK 6/4 | 4 |
| MK 6/6 | 2 |
| SAK 2.5 | 30 |
| SAK 4 | 28 |
| SAK 6N | 22 |
| SAK 10 | 18,~ |
| SAK 16 | 15 |
| SAK 35 | \TT- |
| | |
| | |
| \Diamond | |
| | \Diamond |
| 2(7) | |

| | | \vee | wago | |
|---------------|---------------------|--------|------------|--|
| 1A2.5/5 | 36 | | 280-992 | |
| 14/6 | 30 |) | 280-999 | |
| 16/8 | 22 ្ | | 281-691 | |
| 110/10 | \18 ^{<} | , | 281-992 | |
| 116/12 | 1)5 | | 281-993 | |
| 135/16 | <u> </u> | | 282-691 | |
| | | | 284-691 | |
| 12 | | | 283-691 | |
| 77/ | | | 285-691 | |
| \ | | | 280-998 | |
| \Rightarrow | | | 281-998 | |
| | | | 264-120 | |
| | | | 264-220 | |
| | | | 264-132(2) | |
| | | | 264-134(4) | |
| | | | 262-132(2) | |
| | | | 264-134(4) | |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 178 | 46 |
| Height | 55 | 56 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 1 |
| M20 | 4 | 1 |
| M25 | 3 | 1 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| 7 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| / | ZAG10 | Painted Aluminium (RAL7001) | 220 | 120 | 80 | 1410 |
| \ | ZAG10R | Unpainted Aluminium | 220 | 120 | 80 | 1410 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150°C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

5.400W

Terminal Populations (Maximum Number of Rails 7)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 5 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 2 |
| MK 6/3 | 5 |
| MK 6/4 | 4 |
| MK 6/6 | 2 |
| SAK 2.5 | 30 |
| SAK 4 | 28 |
| SAK 6N | 22 |
| SAK 10 | 18 ~ |
| SAK 16 | 15 |
| SAK 35 | |
| | |
| | |
| \Diamond | |
| | \Diamond |
| . 4 7) | |

| Entrelec | |
|----------|----------|
| MA2.5/5 | 36 |
| M4/6 | 30 |
| M6/8 | 22 _ |
| M10/10 | ∖18 √ |
| M16/12 | 1)5 |
| M35/16 | <u> </u> |
| | |
| 163) | |
| | |
| | |
| > | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

| Wago | |
|------------|----|
| 280-992 | 34 |
| 280-999 | 34 |
| 281-691 | 29 |
| 281-992 | 29 |
| 281-993 | 29 |
| 282-691 | 22 |
| 284-691 | 18 |
| 283-691 | 15 |
| 285-691 | 0 |
| 280-998 | 34 |
| 281-998 | 29 |
| 264-120 | 30 |
| 264-220 | 18 |
| 264-132(2) | 6 |
| 264-134(4) | 4 |
| 262-132(2) | 6 |
| 264-134(4) | 4 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 178 | 46 |
| Height | 55 | 56 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 1 |
| M20 | 4 | 1 |
| M25 | 3 | 1 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-----------------------------|------------|-------------|------------|------------|
| ZAG10-9 | Painted Aluminium (RAL7001) | 220 | 120 | 90 | 1440 |
| ZAG10-9R | Unpainted Aluminium | 220 | 120 | 90 | 1440 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

22

19

19

19

15

12

10

0

22

19

20

12

4

3

4

2

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

5.400W

Terminal Populations (Maximum Number of Rails 7)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | ĺ |
|---------------|------|---|
| BK4 (4 way) | 3 | |
| BK6 (6 way) | 2 | |
| BK12 (12 way) | 1 | |
| MK 6/3 | 3 | |
| MK 6/4 | 2 | |
| MK 6/6 | 1 | |
| SAK 2.5 | 20 | |
| SAK 4 | 19 | |
| SAK 6N | 15 | < |
| SAK 10 | 12,~ | |
| SAK 16 | 10 | 1 |
| SAK 35 | 7 | |
| | | |
| | / // | |
| \Diamond | | |

| Entrelec | | / | Wago |
|---------------|---------------------|---|------------|
| MA2.5/5 | 24 | | 280-992 |
| M4/6 | 20 | | 280-999 |
| M6/8 | 15 | | 281-691 |
| M10/10 | \12 ^{<} | | 281-992 |
| M16/12 | 10 | | 281-993 |
| M35/16 | 7 | | 282-691 |
| | | | 284-691 |
| 163 | | | 283-691 |
| 34) | | | 285-691 |
| | | | 280-998 |
| <u>₹</u> | | | 281-998 |
| \rightarrow | | | 264-120 |
| | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |

| | Drilling Envelope Dimensions (mm) |
|---|-----------------------------------|
| Т | |


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 110 | 80 |
| Height | 65 | 56 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 2 |
| M20 | 2 | 2 |
| M25 | 2 | 1 |
| M32 | 1 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| \ | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| _ | ZAG11 | Painted Aluminium (RAL7001) | 160 | 160 | 90 | 1410 |
| \ | ZAG11R | Unpainted Aluminium | 160 | 160 | 90 | 1410 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

ZAG12/ZAG12R Die Cast Aluminium Enclosures

Application

Industrial and Hazardous areas

Protection Degree IP67

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Ratina

8.000W

Terminal Populations (Maximum Number of Rails 7)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/3 | 5 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 36 |
| SAK 4 | 34 |
| SAK 6N | 27 |
| SAK 10 | 22 _~ |
| SAK 16 | 18 |
| SAK 35 | 14 |
| | |
| - / | 1 |
| \Diamond | |
| | \Diamond |

| MA2.5/5 | 43 |
|--------------------------|----------------------|
| M4/6 | 36 |
| M6/8 | 27 _ |
| M10/10 | _22 ^{<} |
| M16/12 | 18 |
| M35/16 | 14 |
| | |
| 163) | |
| | |
| | |
| $\langle \gamma \rangle$ | |
| | |
| 2 | |
| | |
| | |
| | |
| | |
| | |

| Wago | |
|------------|----|
| 280-992 | 40 |
| 280-999 | 40 |
| 281-691 | 34 |
| 281-992 | 34 |
| 281-993 | 34 |
| 282-691 | 27 |
| 284-691 | 21 |
| 283-691 | 18 |
| 285-691 | 0 |
| 280-998 | 40 |
| 281-998 | 34 |
| 264-120 | 36 |
| 264-220 | 21 |
| 264-132(2) | 7 |
| 264-134(4) | 5 |
| 262-132(2) | 7 |
| 264-134(4) | 5 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 210 | 80 |
| Height | 65 | 56 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 2 |
| M20 | 6 | 2 |
| M25 | 4 | 1 |
| M32 | 3 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

| | $\overline{}$ | | | | | |
|---|---------------|-----------------------------|------------|-------------|------------|------------|
| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
| \ | ZAG12 | Painted Aluminium (RAL7001) | 260 | 160 | 90 | 1960 |
| | ZAG12R | Unpainted Aluminium | 260 | 160 | 90 | 1960 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

10

Application

Industrial and Hazardous areas

Protection Degree

IP65

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150°C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

10.400W

Terminal Populations (Maximum Number of Rails/=2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 9 |
| BK6 (6 way) | 6 |
| BK12 (12 way) | 3 |
| MK 6/3 | 7 |
| MK 6/4 | 6 |
| MK 6/6 | 4 |
| SAK 2.5 | 52 |
| SAK 4 | 48 |
| SAK 6N | 40 |
| SAK 10 | 32 ~ |
| SAK 16 | 26 |
| SAK 35 | 20 |
| | |
| 7 | |
| \Diamond | |
| | \Diamond |
| 2() | |

| Entrelec | | / | Wago | İ |
|----------|----------------------|---|------------|---|
| лА2.5/5 | 63 | | 280-992 | |
| M4/6 | 52 | | 280-999 | |
| M6/8 ∧ | 40 | / | 281-691 | |
| и10/10\ | _32 ^{<} | | 281-992 | |
| M16/12 | 26 | | 281-993 | |
| M35/16 | 20 | | 282-691 | |
| | | | 284-691 | |
| (12) | | | 283-691 | |
| 71/ . | | | 285-691 | |
| | | | 280-998 | |
| 4 | | | 281-998 | |
| | | | 264-120 | |
| | | | 264-220 | |
| | | | 264-132(2) | |
| | | | 264-134(4) | |
| | | | 262-132(2) | |
| | | | 264-134(4) | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 314 | 80 |
| Height | 65 | 56 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 18 | 2 |
| M20 | 8 | 2 |
| M25 | 6 | 1 |
| M32 | 5 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| Ì | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| | ZAG13 | Painted Aluminium (RAL7001) | 360 | 160 | 90 | 2550 |
| | ZAG13R | Unpainted Aluminium | 360 | 160 | 90 | 2550 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

18 12

Application

Industrial and Hazardous areas

Protection Degree

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

10.400W

Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 14 |
| BK6 (6 way) | 10 |
| BK12 (12 way) | 5 |
| MK 6/3 | 12 |
| MK 6/4 | 11 |
| MK 6/6 | 7 |
| SAK 2.5 | 85 |
| SAK 4 | 78 |
| SAK 6N | 64 |
| SAK 10 | 51 ~ |
| SAK 16 | 43 |
| SAK 35 | 32 |
| | |
| | 1 1 |
| \Diamond | |
| | \Diamond |
| . 2()) | |

| Entrelec | | / | Wago |
|----------|----------------------|---|------------|
| MA2.5/5 | 161 | | 280-992 |
| M4/6 | 85 | | 280-999 |
| M6/8 | 64 | | 281-691 |
| M10/10 | \\51 ^{<} | 2 | 281-992 |
| M16/12 | 43 | | 281-993 |
| M35/16 | > 32 | | 282-691 |
| | | | 284-691 |
| 12 | | | 283-691 |
| 34) | | | 285-691 |
| | | | 280-998 |
| 7 | | | 281-998 |
| > | | | 264-120 |
| | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |
| | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 240 | 56 |
| Height | 65 (x2) | 80 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 28 | 2 |
| M20 | 12 | 2 |
| M25 | 10 | 1 |
| M32 | 8 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| _ | \ | | | | | |
|----|-------------|-----------------------------|------------|-------------|------------|------------|
| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
| | ZAG14 | Painted Aluminium (RAL7001) | 560 | 160 | 90 | 4310 |
| | ZAG14R | Unpainted Aluminium | 560 | 160 | 90 | 4310 |



12 8

Application

Industrial and Hazardous areas

Protection Degree

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

- -65° to 150° C (-85° to 302° F)*
- *Refer to certificate for further details

Power Ratina

9.500W

Terminal Populations (Maximum Number of Rails 3)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 10 |
| BK6 (6 way) | 8 |
| BK12 (12 way) | 4 |
| MK 6/3 | 10 |
| MK 6/4 | 8 |
| MK 6/6 | 4 |
| SAK 2.5 | 62 |
| SAK 4 | 58 |
| SAK 6N | 48 |
| SAK 10 | 38 _~ |
| SAK 16 | 32 |
| SAK 35 | 24 |
| | |
| | |
| \Diamond | |
| | \Diamond |
| | |

| Entrelec | | / | Wago |
|----------|-------|---|------------|
| ΛA2.5/5 | 76 | | 280-992 |
| Λ4/6 | 62 | _ | 280-999 |
| Λ6/8 | 48 | | 281-691 |
| и10/10 | ∖38 < | 2 | 281-992 |
| л16/12 | 32 | | 281-993 |
| N35/16 | > 24 | | 282-691 |
| | | | 284-691 |
| 12 | | | 283-691 |
| 34) | | | 285-691 |
| \ ~ | | | 280-998 |
| 7 | | | 281-998 |
| , | | | 264-120 |
| | | | 264-220 |
| | | | 264-132(2) |
| | | | 264-134(4) |
| | | | 262-132(2) |
| | | | 264-134(4) |
| | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 150 | 150 |
| Height | 85 | 76 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 9 | 8 |
| M20 | 6 | 6 |
| M25 | 4 | 3 |
| M32 | 2 | 2 |
| M40 | 2 | 2 |

^{*} Using standard gland clearances

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) | | |
|---|-------------|-----------------------------|------------|-------------|------------|------------|--|--|
| \ | ZAG15 | Painted Aluminium (RAL7001) | 202 | 230 | 110 | 2750 | | |
| \ | ZAG15R | Unpainted Aluminium | 202 | 230 | 110 | 2750 | | |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Application

Industrial and Hazardous areas

Protection Degree

IP66

Certification

ATEX and IECEx:

- Ex ia (Zone 0) and Ex ta (Zone 20)
- Ex e Ex ib (Zone 1) and Ex tb (Zone 21)
- Ex nA (Zone 2) and Ex tc (Zone 22)

CSA Ex e (Class 1, Zone 1)

FM AEx e (Class 1, Zone 1)

TYPE 4X (CSA, FM, UL)

TR CU

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

14.000W

Terminal Populations (Maximum Number of Rails=3)

V V

Calculations do not include the use of end stops, end platés and separators. Check that the enclosure can accommodate the cable bending radius and thigh the earth stud and entry location will permit the required number of términals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 16 |
| BK6 (6 way) | 12 |
| BK12 (12 way) | 6 |
| MK 6/3 | 14 |
| MK 6/4 | 12 |
| MK 6/6 | 8 |
| SAK 2.5 | 96 |
| SAK 4 | 88 |
| SAK 6N | 72 |
| SAK 10 | 58 / |
| SAK 16 | 48 |
| SAK 35 | 36 |
| | |
| | // // |
| \Diamond | |
| | \Diamond |
| 7/ | |

| Entrelec | | | Wago | |
|----------------|----------------------|----|------------|----|
| лА2.5/5 | W4 | | 280-992 | 10 |
| Λ4/6 | 96 | ١. | 280-999 | 10 |
| Λ6/8 | 72 . | | 281-691 | 92 |
| и10/10 <u></u> | _58 ^{<} | ? | 281-992 | 92 |
| л16/12 | 48 | | 281-993 | 92 |
| N35/16 | 36 | | 282-691 | 72 |
| | 7 | | 284-691 | 56 |
| 163 | | | 283-691 | 24 |
| 34/ | | | 285-691 | 16 |
| | | | 280-998 | 10 |
| 3 | | | 281-998 | 92 |
| > | | | 264-120 | 96 |
| | | | 264-220 | 56 |
| | | | 264-132(2) | 20 |
| | | | 264-134(4) | 14 |
| | | | 262-132(2) | 20 |
| | | | 264-134(4) | 12 |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 284 | 150 |
| Height | 85 | 76 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 21 | 8 |
| M20 | 14 | 6 |
| M25 | 10 | 3 |
| M32 | 4 | 2 |
| M40 | 4 | 2 |

^{*} Using standard gland clearances

| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| \ | ZAG16 | Painted Aluminium (RAL7001) | 330 | 230 | 110 | 4270 |
| \ | ZAG16R | Unpainted Aluminium | 330 | 230 | 110 | 4270 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Application

Industrial areas

Protection Degree

IP66

Certification Not applicable

Material

Precision Cast AISI12 (LM24) Aluminium Alloy

Temperature Rating

-65° to 150° C (-85° to 302° F)*

*Refer to certificate for further details

Power Rating

8.000W



Terminal Populations (Maximum Number of Rails/=3)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 9 |
| BK6 (6 way) | 6 |
| BK12 (12 way) | 3 |
| MK 6/3 | 6 |
| MK 6/4 | 6 |
| MK 6/6 | 4 |
| SAK 2.5 | 52 |
| SAK 4 | 48 |
| SAK 6N | 40 |
| SAK 10 | 32 / |
| SAK 16 | 26 |
| SAK 35 | 10 |
| | |
| | |
| \Diamond | |
| | \Diamond |
| ~(7) | |

| Entrelec | | _ | Wago | |
|----------|-------|----|------------|----|
| MA2.5/5 | 63 | | 280-992 | 58 |
| M4/6 | 52 | L, | 280-999 | 58 |
| M6/8 △ | 40 | | 281-691 | 50 |
| м10/10 | √32 < | ľ | 281-992 | 50 |
| M16/12 | 26 | | 281-993 | 50 |
| M35/16 |) 0 | | 282-691 | 39 |
| | | | 284-691 | 31 |
| 163 | | | 283-691 | 26 |
| 31) | | | 285-691 | 0 |
| \ ~ | | | 280-998 | 58 |
| 3 | | | 281-998 | 50 |
| > | | | 264-120 | 52 |
| | | | 264-220 | 31 |
| | | | 264-132(2) | 11 |
| | | | 264-134(4) | 7 |
| | | | 262-132(2) | 10 |
| | | | 264-134(4) | 7 |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 320 | 60 |
| Height | 56 | 47 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 1 |
| M20 | 8 | 1 |
| M25 | 7 | 1 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

| 2 | | | | | | |
|---|-------------|-----------------------------|------------|-------------|------------|------------|
| | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
| \ | ZAG21 | Painted Aluminium (RAL7001) | 120 | 360 | 80 | 2050 |
| \ | ZAG21R | Unpainted Aluminium | 120 | 360 | 80 | 2050 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)






For many years, ABTECH have been at the forefront in the design and manufacture of high voltage connection solutions for use in hazardous areas.



Through constantly listening to customers needs the range has been developed and expanded to the five major ranges shown in this section. Different sizes and options result in more than 50 combinations to choose from.



All ABTECH high voltage enclosures are manufactured in 316 grade stainless steel and have an IP rating of IP66 as standard. IP67 versions are also available.

All enclosures are ATEX certified for use in a Category 2/Zone 1 areas and Category 3/Zone 2 areas. Where appropriate IECEX is also available.

The entire range offers flexibility in terms of both connection options and mounting arrangements.

New variations are continually being added to the High Voltage range. For example, we can now offer Category—2/Zone 1 high voltage enclosures capable of operation at 45kV.

Whatever your requirement may be for high voltage connections in hazardous areas, call ABTECH for the solution.

Our High Voltage ranges currently consist of the following types;

MJB Range

The MJB range provides a simple, low cost but effective solution for the connection of cables. Used primarily for joining cables or as a connection box. Maximum voltage 8.3kV.



DPJB Range

The original high voltage 'down hole pump' connection box which has been used by many customers all over the world.



HVJB Range

The latest in the High Voltage range affering enhanced flexibility over the choice of cables, entries and cable terminations. Maximum voltage 45kV with the 4TJB enclosure.



LR Range

The LR range was originally designed for a specialist application for a specific customer. However, this type of enclosure has since been used in more general applications where a need for the flexible connection arrangements is required. Maximum voltage 3.3kV



Busbar Box

A busbar enclosure with a maximum voltage of NkV, a current capacity of 3200A per phase and a fault rating of 90kA for 1 second. Capable of connecting 3 phase & neutral and up to 6 cables per phase.



SX125 Box

A unique solution to the termination of umbilical cables to offshore platform or on-shore distribution systems. A power conductor compartment is provided for use at up to 11 kV and a separate control compartment for terminating optical fibres and/or control conductors.

MJB Range

Application

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 ATEX Ex nA (Zone 2) to BS EN 60079-15 ATEX Ex nR (Zone 2) to BS EN60079-15 NEMA 4X (CSA, UL & FM) Class 1 Division 2 Deluge Tested to DTS-01

Material

Stainless steel 316 (1.4404)

Temperature Rating


Standard: -50° C to 65° C (-58° to 149° F)

Maximum Voltage

8.3 kV



| Part Number | Width (mm) (Dimension B) | Height (mm) (Dimension A) | Depth (mm) | Dimension C | Dimension D (mm) | Power Rating (W) | Maximum Voltage (kV) | Maximum Ways | Maximum Conductor Size (mm²) |
|-------------|-----------------------------|------------------------------|------------|-------------|---------------------|---------------------|-------------------------|-----------------|------------------------------------|
| MJB5 | 510 | 510 | 200/300 | 560 | 360 | 16 | 6.6 | 3 | 120 |
| MJB5/3 | 510 | 510 | 300 | 560 | 360 | 16 | 8.3 | 3 | 35 |
| MJB6 | 510 | 780 | 200/300 | 560 | 580 | 23 | 6.6 | 3 | 120 |
| MJB6/3 | 510 | 780 | \\300 ♦ | 560 | 580 | 23 | 8.3 | 3 | 35 |
| MJB7 | 650 | 950 | 290/300 | 700 | 750 | 33 | 6.6 | 4 | 240 |
| MJB7/3 | 650 | 950 | 300 | 700 | 750 | 33 | 8.3 | 4 | 240 |
| MJB8 | 800 | 1250 | 200/300 | 850 | 1050 | 50 | 6.6 | 4 | 240 |
| MJB8/3 | 800 | 1250 | 200/300 | 850 | 1050 | 50 | 8.3 | 4 | 240 |



DPJB Range

Application

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 NEMA 4X (CSA, UL & FM) Class 1 Division 2 Deluge Tested to DTS-01

Material

Stainless steel 316 (1.4404)

Temperature Rating

Standard: -20° to 55° C (-4° to 131° F)

Maximum Voltage

11 kV

Fault Rating

50kA for 1 second




Specifications

| Part Number | Width (mm) (Dimension B) | Height (mm) (Dimension A) | Depth (mm) | Power Rating (W) | Maximum Voltage (kV) | Maximum Ways | Max. Conductor Size (mm²) | | | | |
|-------------|-----------------------------|------------------------------|------------|---------------------|-------------------------|--------------|---------------------------------|--|--|--|--|
| DPJB1 | 650 | 950 🗸 🤇 | 200 | 48.6 | 6.6 | 3 | 630 | | | | |
| DPJB3 | 650 | 950 | 200 | 48.6 | 6.6 | 4 | 630 | | | | |
| DPJB5 | 800 | 1250 | 300 | 48.6 | 6.6 | 3 | 630 | | | | |
| DPJB7 | 800 | 1250 | 300 | 48.6 | 6.6 | 4 | 630 | | | | |
| DPJB9 | 800 | 1250 | 300 | 48.6 | 11 | 3 | 630 | | | | |
| DPJB11 | 800 | 1250 | 300 | 48.6 | 11 | 4 | 630 | | | | |
| DPJB2 | 650 _ | 950 | 200 | 50.0 | 6.6 | 4 | 120 | | | | |

Notes

The DPJB utilises the SX7 and SX8 enclosures in either 200 or 300mm depth, depending on the operating voltage. By using the SX range design the same benefits are afforded to the DPJB range. These benefits include: ingress protection to IP66 as standard with IP67 available as an option, enclosure tested to the Shell/ERA deluge specification, heavy duty construction, padlock facility and internal/external earth stud fitted as standard. A double compartment version is available with a separate compartment which can be used to terminate control cables or fibre optic cables. This allows access to the low voltage/ fibre compartment without having to de-energise the high voltage compartment. Versions are also available with purge protection for use in Class 1/Division 2 areas. Phase segregation is fitted as standard. The DPJB range can be used as either a through box or with both the incoming and outgoing cable entering via one end. In the later instance it is important to consider the bending radii of the cables to ensure the enclosure is large enough

Spare copper crimp lugs are available from ABTECH to allow repairs or re-use of the enclosure. Please contact the Sales Department for further details.



HVJB Range

Application

Hazardous areas

Protection Degree IP66 or 67

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 IECEx Ex e (Zone 1 & Zone 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2 Deluge Tested to DTS-01

Material

Stainless steel 316 (1.4404)

Temperature Rating

Standard: -20° to 40° C (-4° to 104° F) Option: -50° to 55° C (-58° to 131° F)

Maximum Voltage


11 kV

Specifications



| <u> </u> | | | | | | |
|----------------|------------------------|-------------------------|-----------------|------------|------------------|---------------------------------|
| Part Number | Maximum Current (A) | Maximum Voltage (kV) | Maximum Ways | Top Cables | Bottom Cables | Max. Conductor Size (mm²) |
| Pa | žő | ž > | Žβ | To | BC C, | Siz |
| HVJB x3 (0-2) | 980 | 11/\ | 3 | 0 | 2 | 630 |
| HVJB x3 (0-3) | 980 | 11 | 3 | 0 | 3 | 630 |
| HVJB x3 (2-0) | 980 | 11((| 3 | 2 | 0 | 630 |
| HVJB x3 (3-0) | 980 | 11 | Э з | 3 | 0 | 630 |
| HVJB x3 (1-1) | 980 | (11) | 3 | 1 | 1 | 630 |
| HVJB x3 (1-2) | 980 | 11 | 3 | 1 | 2 | 630 |
| HVJB x3 (2-1) | 980 < | 11 | 3 | 2 | 1 | 630 |
| HVJB x3 (2-2) | 980 | 91 | 3 | 2 | 2 | 630 |
| HVJB x3 (1-3) | 980 | 11 | 3 | 1 | 3 | 630 |
| HVJB x3 (3-1) | 980 | 11 | 3 | 3 | 1 | 630 |
| HVJB x3 (2-3) | 980 | 11 | 3 | 2 | 3 | 630 |
| HVJB x3 (3-2) | 980 | 11 | 3 | 3 | 2 | 630 |
| HVJB x3 (3-3) | 980 | 11 | 3 | 3 | 3 | 630 |
| HVJB x4 (0-2) | 980 | 11 | 4 | 0 | 2 | 630 |
| HVJB x4 (0-3) | 980 | 11 | 4 | 0 | 3 | 630 |
| HVJB x4 (2-0) | 980 | 11 | 4 | 2 | 0 | 630 |
| HVJB x4 (3-0) | 980 | 11 | 4 | 3 | 0 | 630 |
| HVJB x4 (1-1) | 980 | 11 | 4 | 1 | 1 | 630 |
| HVJB x4 (1-2) | 980 | 11 | 4 | 1 | 2 | 630 |
| HVJB x4 (2-1) | 980 | 11 | 4 | 2 | 1 | 630 |
| 14VJB x4 (2-2) | 980 | 11 | 4 | 2 | 2 | 630 |
| HVJB x4 (1-3) | 980 | 11 | 4 | 1 | 3 | 630 |
| HVJB x4 (3/1) | 980 | 11 | 4 | 3 | 1 | 630 |
| HVJB x4 (2-3) | 980 | 11 | 4 | 2 | 3 | 630 |
| HVJB x4 (3-2) | 980 | 11 | 4 | 3 | 2 | 630 |
| HVJB x4 (3-3) | 980 | 11 | 4 | 3 | 3 | 630 |

The letter 'x' in the Part Number above should be replaced with the number 7 or 8 depending on the size of enclosure required. 7 refers to an SX7 size enclosure measuring 650 x 950 x 300mm. 8 refers to an SX8 enclosure measuring 800 x 1250 x 300mm. If cables greater than 300mm² are used it is advisable to use the SX8 size enclosure. For voltages greater than 11kV enclosures are available to special order – please contact our Sales Department for further information.



LR Range

Application

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 NEMA 4X (CSA, UL & FM) Class 1 Division 2 Deluge Tested to DTS-01

Materia

Stainless steel 316 (1.4404)

Temperature Rating

T3: -50° to 55° C (-58° to 131° F) T4: -50° to 40° C (-58° to 104° F)

Maximum Voltage

3.3 kV



Specifications

| | | | (v | / \ _ / | | | |
|-------------|------------|-------------|------------|------------------------|-------------------------|-----------------|---------------------------------|
| Part Number | Width (mm) | Height (mm) | Depth (mm) | Maximum Current (A) | Maximum Voltage (kV) | Maximum Ways | Max. Conductor Size (mm²) |
| LR52(200) | 510 | 510 | 200 | 1250 | 3.3 | 2 | 630 |
| LR52(300) | 510 | 510 | 300 | 1250 | 3.3 | 2 | 630 |
| LR73(200) | 650 | 950 | 200 | 1250 | 3.3 | 3 | 630 |
| LR73(300) | 650 | 950 | 300 | 1250 | 3.3 | 3 | 630 |

The LR52 version ATEX certification is based on the SX5-3GP-200 (3 gland plates, 200mm deep) and SX5-3GP-300 (3 gland plates, 300mm deep).

The LR73 version ATEX certification is based on the SX7-3GP-200 (3 gland plates, 200mm deep) and SX7-3GP-300 (3 gland plates, 300mm deep).

Other sizes are available on request.



Busbar Box

Application

Hazardous areas

Protection Degree

IP66 or 67

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 IECEX Ex e (Zone 1 & 2) NEMA 4X (CSA, UL & FM) Class 1 Division 2 Deluge Tested to DTS-01

Material

Stainless steel 316 (1.4404)

Temperature Rating

T5: -40° to 40° C (-40° to 104° F) T6: -40° to 60° C (-40° to 149° F)

Maximum Voltage

11 kV



Specifications


| | | | | / , / | | | | | |
|-------------|-----------------------|------------------------|------------------------|------------------------|-------------------------|--------------|----------------------------------|--------------|------------------------------|
| Part Number | Maximum Width (mm) | Maximum Height (mm) | Maximum Depth (m/m) | Maximum Current (A) | Maximum Voltage (kV) | Maximum Ways | Maximum Conductors per Way | Maximum Ways | Max. Conductor Size (mm²) |
| Busbar Box | 770 | 770 < | (1250) | 3000 | 11 | 4 | 6 | 4 | 1000 |

Notes

The ABTECH Busbar box is used for the connection of cables or equipment where the conductor size and number of cables being connected would make it very difficult in any other ABTECH High Voltage range.

The Bus-Bay box is ideally suited for conductor sizes over 400mm², as the design allows cables to enter the enclosure and be terminated onto the busbar without having to be bent. This makes for quick and easy installation in applications which have normally been considered difficult to accomplish.

Although not based on a particular size of standard enclosure, the Bus-Bar box utilises the SX range features and is consequently afforded the same benefits from the use of these. These benefits include: ingress protection to IP66 as standard with IP67 available as an option, heavy duty construction, padlock facility and an internal/external earth stud fitted as standard. Additionally, the Bus-Bar box incorporates heavy duty mounting facilities which can be adapted to suit the customer's requirements.



SX125 Range

Application
Hazardous areas

Protection Degree IP66

Certification

ATEX Ex e (Zone 1 & Zone 2) to BS EN 60079-7 NEMA 4X (CSA, UL & FM) Class 1 Division 2

Vlateria


Stainless steel 316 (1.4404)

Temperature Rating

Standard: -20° to 55° C (-4° to 131° F)

Maximum Voltage

11 kV



Notes

The SX125 provides a unique solution to the termination of umbilical cables to offshore platform or onshore distribution systems. Based on the successful and service proven SX range, they are available as either a left hand or right hand configuration. A power conductor compartment is provided for use at up to 15 kV and a separate control compartment for terminating optical fibres and/or control conductors. For voltages greater than 15kV enclosures are available to special order – please contact our Sales Department for further information


Each compartment gives independent protection to IP 66. This facilitates working on the optical fibres or control conductors without the need to isolate the feed to the power compartment.


The SX125 is available with either 3 couplers of Couplers, each capable of connecting up to 3 power conductors. In the control compartment there is the option to mount the optical fibre splice cassettes either directly onto a chassis plate or inside an additional Ex'e' certified enclosure for increased environmental protection. Terminals for control conductors can be treated in the same manner as optical fibres. For higher voltage applications, the SX125 is available with a purging system.


HVJB 125


For high current applications the HVJB 125 was developed as an extension to the SX125 range.

Offering all the facilities of the SX125 the HVJB 125 adds the facility for a suitably certified anticondensation heater.











Fire Testing of Junction Boxes

When installing essential systems such as emergency lighting or fire safety controls, great emphasis is placed upon the fire survivability of the critical components such as fire dampers, actuators and cables that are contained in the area. Often the specification of the junction boxes is neglected with respect to fire survival. On the basis that any system is only as good as the weakest part, it is important that attention is paid to the junction boxes being utilised for essential systems. ABTECH have many years experience of ensuring the fire survival of junction boxes using both the SX and BPG ranges. We have supplied major projects worldwide with fire rated junction boxes including the Channel Tunnel. Dartford Tunnel and the Tenaiz Oil Refinery in Kazahkstan to name but a few.

Since there are no recognised tests applicable to junction boxes, it was decided to test the enclosures to the same specification as the cable. At the time of the test (1990) the two main tests for electrical cables were IEC331/1970 and BS6387/1983.

In IEC331 a cable test is conducted in which the samples are subjected to flame at a temperature of 750°C (1382°F) for a period of 3 hours with the electrical system fully functional before, during, and after the test. This test was carried out on both the SX (stainless steel) and BPG (glass reinforced polyester) ranges containing nylon, melamine and ceramic terminals.




After the test it was found that the body of the nylon terminals had disappeared completely, the melamine body had taken on the appearance of biscuit (because the wood filling had burnt away) and only the ceramic bodied terminal appeared to be intact.

Without cleaning or disturbing the terminals in any way, a flash potential of 5kV was applied between the copper conductor and the terminal rail, which passed without break-down.

Since the IEC331 standard only partly dealt with the requirements of real-life situations, it was decided to conduct additional testing to an alternative standard – B56387/1983.

This test is performed in a similar way to IEC331/1970 with the specimen under test being suspended 75mm (approximately 3") above a flame, the temperature of which is maintained at 950°C (1742°F) for 3 hours. During this period the cable and junction box is supplied with power. In order to pass the test, both components must be fully functioning after the period has elapsed.



On the successful conclusion of this test, which is designated "fire-alone" BS6387'C', the next test is to mount the sample (still powered-up) on a flat vertical surface and to apply flame at a temperature of 950°C (1742°F) (by means of a flame gun) whist at the same time striking the board on which the sample is mounted with a 25mm (1") diameter iron bar every 30 seconds for a period of 15 minutes. This is designated the "impact test" BS6387 'Z'.

Finally, a "fire with water test" is applied but only at a temperature of 650°C (1202°F). The sample is subjected to flame at 650°C for 15 minutes after which a water spray is applied for 15 minutes and at the culmination of this test the system is required to be completely functional, this test being designated BS6387 'W'.


The SX range of enclosures passed all the tests applicable to BS6387 i.e. C, Z & W however, it was decided that the BPG range would only be submitted to the flame test 'C', which it passed.

In conclusion, the ABTECH SX and BPG ranges, when fitted with ceramic terminals, are suitable for use in areas which are designated to require fire resistant cables. The type of enclosure to be used will depend on the individual circumstances of the area and advice on the most suitable enclosure should be sought from the ABTECH Technical Department.

| Enclosure Type | IEC 331 750°C (1382°F) for 3 hours (Flame Only) | BS6387 'C' 950°C(1742°F) for 3 hours (Flame Only) | BS6387 'Z' 950°C (1742°F) for 3 hours (External Impact) | BS6387 'W' 950°C (1742°F) for 3 hours (Water Spray) |
|----------------|--|--|--|--|
| SX Range | Pass | Pass | Pass | Pass |
| BPG Range | Pass | Pass | Not Tested | Not Tested |



SX Range Enclosure and Cables after IEC331 Fire Testing



SX Range Enclosure after BS6387 Testing



SX and BPG Range Enclosures after BS6387 Testing



ABS and Polycarbonate Enclosures



The ABTECH ZP range of enclosures comprises of 19 different sizes which are injection moulded in either ABS plastic or polycarbonate material. There is also an option of a clear polycarbonate lid which can be fitted to either base.

The enclosures are lightweight yet extremely robust and offer good protection against both corrosion and oil based contamination. The enclosure shares the labyrinth seal arrangement which is common to both the ZAG and BPG ranges and can offer protection up to IP65.

Stainless steel captive quick release quarter turn screws are fitted as standard offering a quick yet reliable method of securing the lid. This can provide a considerable cost saving in assembly times with on-average savings of 2 minutes per enclosure over conventional screws. As an option conventional threaded screws may be fitted if required.



The ZP range is an extremely versatile enclosure with many uses and applications including junction boxes, instrument enclosures and a multitude of OEM applications. The addition of the clear lid makes the ZP range particularly suitable for housing instruments and indicators where a visual indication is required without the need for opening the enclosure. The range can be machined, drilled and tapped with various thread forms and can also be silk screen printed. The ZP range can also be moulded in almost any colour, subject to minimum quantities. At our factories in England, Germany and the United States we have specialist machining centres for the ZP range of enclosure.

These machines use the dedicated tooling and programming which is specific to the requirements of the material and reflect the increasing usage of this enclosure range, especially in small batch production.



Internal components are located via a series of moulded pillars which can be fitted with threaded-inserts or alternatively can accept self tapping screws and these are used for the fitment) of a component mounting plate or DIN standard terminal mounting rails such as 15, 15, TS 32 or TS 35.

Earthing can be accomplished through various means. For example, an internal / external earth stud, which in turn can be connected to the terminal mounting rail or component plate can be used as well as various rail mounted earth terminals or proprietary earth bars which can be fitted inside the enclosure.



The screening against RFI (radio frequency interference) is achieved by the use of a metalised coating of 50 micron thickness to the internal surfaces of the enclosure and the fitment of an RFI gasket. The ABTECH Sales team can give advice on suitable RFI gaskets and finishing techniques which will provide optimum following protection but typically the characteristics are achievable:


Electrical Attenuation: 55 – 65dB @ 500MHz to 1000MHz

Magnetic Attenuation: 35dB @ 40KHz to 300MHz

ZP Range Features

- Wide Operating Temperature
- Ingress Protection up to IP65
- Available in Polycarbonate and ABS
- · Optional Transparent lid
- Can be moulded any colour (subject to minimum quantities)
- Can be easily machined and silk screen printed
- Ideal for Instrument housings and junction boxes





Accessories and Options


The following table is a list of the available accessories suitable for particular sizes of ZP enclosure.

| Part Number | Width (mm) | Length (mm) | Depth (mm) | P (or no suffix) Polycarbonate | ABS - ABS | T - Transparent Lid (moulded polycarbonate) | TS - Threaded Lid Fixing Screws (see note 1) | MP - Component Mounting Plate | EH - External Hinges | EB - internal Earthing Bar | MF - External Mounting Feet | MR - DIN Standard Mounting Rail | RF - RFI Protection (see note 2) |
|-------------|------------|-------------|------------|--|-----------|---|---|---|----------------------|--------------------------------------|---------------------------------------|------------------------------------|----------------------------------|
| ZP1 | 52 | 50 | 35 | • | | | | • | | | | | |
| ZP2 | 65 | 50 | 35 | | | | | P | | | | | |
| ZP3 | 82 | 80 | 55 | | | | \$ | | <i>J</i> | | | | |
| ZP4 | 82 | 80 | 85 | | | | | | | | | | |
| ZP5 | 120 | 80 | 55 | | | 9 | | - | | | | | |
| ZP6 | 120 | 80 | 85 | | | | J | | | | | | |
| ZP7 | 160 | 80 | 55 | % | ~•// | | • | | | | | | |
| ZP8 | 160 | 80 | 85 | | | • | | • | • | • | • | | |
| ZP9 | 122 | 120 | 55 | | | • | | • | • | • | • | | |
| ZP10 | 122 | 120 | 85 | | • | • | | • | | | | | |
| ZP11 | 200 | 120 | 75 | | | | | | | | | | |
| ZP12 | 200 | 150 🤇 | 75 | • | | | | | | | | | |
| ZP13 | 240 | 120 | 100 | | | | | | | | | | |
| ZP14 | 240 | 160 | 90 | | | | | | | | | | |
| ZP15 | 250 | 160 | 90 | | | | | | | | | | |
| ZP16 | 240 | 160 | 120 | | | | | | | | | | |
| ZP17 | 300 | 230 | 85 | | | | | | | | | | |
| ZP18 🗘 | 360 | 200 | 150 | | | | | | | | | | |
| ZP19 | 300 | 230 | 110 | | | | | | | | | | |


ZP12 ABS MF (ZP12 moulded in ABS material with External Mounting Feet)

^{1.} Standard lid fixing screws are ¼ turn quick release type.

^{2.} Radio Frequency Interference (RFI) gasket may reduce IP rating. Enclosure may also be internally coated with RFI material.



Component Mounting Plate (tufnol as standard, steel an option)



Internal Earthing Bar (can be fitted with clamps)




External Mounting Feet (stainless steel 316)



RFI Shielding (metalised spray coating to interior)




External Hinges



Transparent Lid (moulded in polycarbonate)



Lid Seal Gasket



¼ Turn or Threaded Lid Fixing Screws



DIN Standard Mounting Rail (TS 15, TS 32 or TS 35)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 0)

Entrelec

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | | |
|---------------|-----|---|
| BK4 (4 way) | 1 | |
| BK6 (6 way) | 0 | |
| BK12 (12 way) | 0 | |
| MK 6/3 | 0 | |
| MK 6/4 | 0 | |
| MK 6/6 | 0 | |
| SAK 2.5 | 0 | |
| SAK 4 | 0 | |
| SAK 6N | 0 | |
| SAK 10 | 0 | < |
| SAK 16 | 0 < | _ |
| SAK 35 | Q | 1 |
| | | |
| | | |
| | | |
| | | |
| | / > | |

| MA2.5/5 | 9/ | | G5\4 (4 way) | 1 |
|-------------------|-----|---|----------------|---|
| M4/6 | <0(| | G5\6 (6 way) | 0 |
| M6/8 | 0 | Ę | G5\12 (12 way) | 0 |
| M10/10 | 0 ^ | | ÚK3 N | 0 |
| M16/12 | 0 | | UK5 N | 0 |
| M35/16 | 9 | | UK10 N | 0 |
| 47 | | | UK16 N | 0 |
| | | | UK35 N | 0 |
| | | | | |
| | | | | |
| | | | | |
| \Rightarrow | | | | |
| $\langle \rangle$ | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | l | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 28 | 26 |
| Height | 22 | 22 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M12 | 1 | 1 |
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |
| | | |

* Using standard gland clearances

Specifications

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| I | ZP1 | Polycarbonate (RAL7035) | 52 | 50 | 35 | 40 |
| 1 | ZP1 ABS | ABS (RAL7035) | 52 | 50 | 35 | 38 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions:

-40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 1 |
| BK6 (6 way) | 0 |
| BK12 (12 way) | 0 |
| MK 6/3 | 0 |
| MK 6/4 | 0 |
| MK 6/6 | 0 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 < |
| SAK 35 | Q |
| ^ | |
| | |
| ^ | / 0 |
| ~ | |
| | \Diamond |

| Entrelec | | | Phoenix | |
|----------|-------|---|----------------|---|
| MA2.5/5 | 9/ | | G5\4 (4 way) | 1 |
| M4/6 | <0(| | G5\6 (6 way) | 0 |
| M6/8 | 6 | _ | G5\12 (12 way) | 0 |
| M10/10 | 0 ^ | | UK3 N | 0 |
| M16/12 | //0 ~ | | UK5 N | 0 |
| M35/16 | 9 | | UK10 N | 0 |
| 7 | | | UK16 N | 0 |
| | | | UK35 N | 0 |
| | | | | |
| | | | | |
| | | | | |
| \geq | | | | |
| \geq | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 41 | 26 |
| Height | 22 | 22 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M12 | 12 2 1 | |
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

Specifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP2 | Polycarbonate (RAL7035) | 65 | 50 | 35 | 50 |
| ZP2 ABS | ABS (RAL7035) | 65 | 50 | 35 | 48 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 1 |
| BK12 (12 way) | 0 |
| MK 6/3 | 0 |
| MK 6/4 | 0 |
| MK 6/6 | 0 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 ~ |
| SAK 35 | 0 \ |
| | |
| | |
| / | |
| \Diamond | 11. |
| | \Diamond |

| | | | Phoenix | |
|---------|-----|---|----------------|--|
| MA2.5/5 | 0_ | | G5 4 (4 way) | |
| M4/6 | 0 | | G5\6 (6 way) | |
| M6/8 | 8 | | G5\12 (12 way) | |
| M10/10 | 0 | \ | AK3 N | |
| M16/12 | 0 < | > | ŬK5 N | |
| M35/16 | 10 | | UK10 N | |
| | ` | | UK16 N | |
| | / | | UK35 N | |
| (12) | | | | |
| 77/ | | | | |
| | | | | |
| 3) | | | | |
| \ | | | | |
| 7 | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 56 | 36 |
| Height | 29 | 29 |


Gland Entry Matrix *

0

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M12 | 3 | 1 |
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |



| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP3 | Polycarbonate (RAL7035) | 82 | 80 | 55 | 150 |
| ZP3 ABS | ABS (RAL7035) | 82 | 80 | 55 | 148 |



Industrial areas

Protection Degree

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 1 |
| BK12 (12 way) | 0 |
| MK 6/4 | 1 |
| MK 6/6 | 0 |
| SAK 2.5 | 5 |
| SAK 4 | 5 |
| SAK 6N | 4 |
| SAK 10 | 3 |
| SAK 16 | 2 |
| SAK 35 | 0 / |
| ^ | |
| | |
| | |
| | / // |
| | |

| | | ١. | |
|---------|----|----|----------------|
| MA2.5/5 | 6 | | G5\4 (4 way) |
| M4/6 | 5 | | G5\6 (6 way) |
| M6/8 | 3 | | G5\12 (12 way) |
| M10/10 | 3 | \ | ЯŔЗ И |
| M16/12 | 1 | > | UK5 N |
| M35/16 | 70 | | UK10 N |
| | , | | UK16 N |
| | / | | UK35 N |
| (12) | | | |
| | | | |
| | | | |
| 7 | | | |
| | | | |
| 7 | | | |
| | | | |
| | | | |
| | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 56 | 36 |
| Height | 59 | 59 |


Gland Entry Matrix *

1

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 1 | 1 |
| M20 | 1 | 0 |
| M25 | 1 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

| $\wedge \wedge$ | // | ノノ |
|-----------------|---------|----------|
| × ~ | a aleia | . Atlana |
| 15 | жесть | :átions |

| Width (n | nm) Length (mm) |) Depth (mm) | Weight (g) |
|----------|-----------------|--------------|------------|
| 7035) 82 | 80 | 85 | 175 |
| 82 | 80 | 85 | 156 |
| 82 | 80 | | 85 |



Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| BK4 (4 way) | 2 |
|---------------|---|
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 |
| SAK 35 | 0 |

| | | | 1 |
|---|---------|-----|---|
| | MA2.5/5 | 0 | \ |
| | M4/6 | 0 | |
| | M6/8 | 8 | |
| | M10/10 | 0 | \ |
| | M16/12 | 0 < | > |
| | M35/16 | 70 | |
| | | | |
| | ~ [] |) | |
| | (64) | | |
| K | 7/ | | |
| / | | | |
| - | 7/ | | |
| 7 | | | |
| | 7 | | |
| | | | |
| | | | |
| | | | |

| Phoenix | |
|----------------|---|
| G5\4 (4 way) | 2 |
| G5\6 (6 way) | 2 |
| G5\12 (12 way) | 1 |
| nks n | 0 |
| ŨK5 N | 0 |
| UK10 N | 0 |
| UK16 N | 0 |
| UK35 N | 0 |
| | |
| | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 94 | 36 |
| Height | 29 | 29 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

| $\wedge \wedge$ | // | // |
|-----------------|----------|--------|
| ~ ∠ | 1 | -/. |
| 2 ~ST | secific. | ations |

| 7 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| / | ZP5 | Polycarbonate (RAL7035) | 120 | 80 | 55 | 175 |
| / | ZP5 ABS | ABS (RAL7035) | 120 | 80 | 55 | 165 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Application

Industrial areas

Protection Degree

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/4 | 1 |
| MK 6/6 | 1 |
| SAK 2.5 | 14 |
| SAK 4 | 13 |
| SAK 6N | 10 |
| SAK 10 | 8 |
| SAK 16 | 7 |
| SAK 35 | 5 |
| | |
| | |
| | |
| 7 | / // |

| | | | (| Phoenix |
|---|---------|-----|---|--------------|
| | MA2.5/5 | 17 | \ | G5\4 (4 wa |
| | M4/6 | 14 | | G5\6 (6 wa |
| | M6/8 | 8 | | G5\12 (12 wa |
| | M10/10 | 8 | \ | AK3 N |
| | M16/12 | 7 < | > | UK5 N |
| | M35/16 | 75 | | UK10 N |
| | | \ | | UK16 N |
| | | / | | UK35 N |
| | (12) | | | |
| A | | | | |
| / | | | | |
| - | 7/ | | | |
| 7 | | | | |
| | 7 | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 94 | 36 |
| Height | 59 | 59 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 1 |
| M20 | 2 | 0 |
| M25 | 2 | 0 |
| M32 | 1 | 0 |
| M40 | 0 | 0 |



| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| | ZP6 | Polycarbonate (RAL7035) | 120 | 80 | 85 | 225 |
| \ | ZP6 ABS | ABS (RAL7035) | 120 | 80 | 85 | 205 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions:

-40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable

BK4 (4 way)

BK6 (6 way)

MK 6/4

MK 6/6

SAK 2.5

SAK 4

SAK 6N

SAK 10

SAK 16

SAK 35

BK12 (12 way)



Terminal Populations (Maximum Number of Rails = 1)

separators. Check С and that the earth stud and entry location will permit the required number of terminals to be fitted

| | \sim |
|---|--------|
| Calculations do not include the use of end stops, end plates a | ind s |
| Calculations do not include the use of end stops, end plates a hat the enclosure can accommodate the cable bending rac | a suit |
| N 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 | V. DI |

3

2

1

2

1

0

0

0

0

0

0

| MA2.5/5 | 0 | / | G5\4 (4 way) | 3 |
|---------|-----|---|----------------|---|
| M4/6 | Ø | | G5\6 (6 way) | 2 |
| M6/8 | S | | G5\12 (12 way) | 1 |
| M10/10 | 0 | \ | fik3 N | 0 |
| M16/12 | 0 < | > | ŬK5 N | 0 |
| M35/16 | 20 | | UK10 N | 0 |
| |) | | UK16 N | 0 |
| | | | UK35 N | 0 |
| (12) | | | | |
| | | | | |
| | | | | |
| 7/ | | ĺ | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 134 | 36 |
| Height | 29 | 29 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 0 | 0 |
| M20 | 0 | 0 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |



| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| | ZP7, | Polycarbonate (RAL7035) | 160 | 80 | 55 | 225 |
| Į | ZP7 ABS | ABS (RAL7035) | 160 | 80 | 55 | 205 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | |
|---------------|-----|
| BK4 (4 way) | 3 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 20 |
| SAK 4 | 19 |
| SAK 6N | 15 |
| SAK 10 | 12 |
| SAK 16 | 10 |
| SAK 35 | 7 _ |
| | |
| (| |
| | |
| | |

| | Entrelec | | Phoens | |
|---|----------|------|--------|---------|
| | MA2.5/5 | 24 | / | G5\4)(|
| | M4/6 | 20 | | G5\6 (|
| | M6/8 | 15 | | G5\12 (|
| | M10/10 | 12 | \ | MK3 N |
| | M16/12 | 10 < | > | ŬK5 N |
| | M35/16 | 78 | | UK10 N |
| | | 7 | | UK16 N |
| | | | | UK35 N |
| | (12) | | | |
| K | | | | |
| / | | | | |
| - | 2) | | | |
| 7 | | | | |
| | 7 | | | |
| | | | | |
| | | | | |
| | | | | |

| dilugiz to be litted | | |
|----------------------|----|--|
| Phoenix | | |
| G5\4 (4 way) | 3 | |
| G5\6 (6 way) | 2 | |
| G5\12 (12 way) | 1 | |
| nk3 N | 23 | |
| ŬK5 N | 19 | |
| UK10 N | 11 | |
| UK16 N | 9 | |
| UK35 N | 7 | |
| | | |
| | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 59 | 59 |
| Height | 134 | 36 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 6 | 1 |
| M20 | 3 | 0 |
| M25 | 2 | 0 |
| M32 | 2 | 0 |
| M40 | 0 | 0 |

| < ' (| ١. | |
|-------------|----|-----|
| √Specifical | id | าทร |
| 4 9 P O O | ~ | |

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP8 | Polycarbonate (RAL7035) | 160 | 80 | 85 | 250 |
| ZP8 ABS | ABS (RAL7035) | 160 | 80 | 85 | 235 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of terminals to be fitted

| Weidmuller | |
|---------------|----------|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 0 |
| SAK 4 | 0 |
| SAK 6N | 0 |
| SAK 10 | 0 |
| SAK 16 | 0 |
| SAK 35 | 0 |
| | <u> </u> |
| < | |
| | |
| | |
| \wedge | 7 |

| | Entrelec | | () |
|---|----------|-----|-----|
| | MA2.5/5 | 0 | \ |
| | M4/6 | 0 | |
| | M6/8 | Ø | |
| | M10/10 | 0 | \ |
| | M16/12 | 0 < | > |
| | M35/16 | 20 | |
| | | } | |
| | | | |
| | (12) | | |
| K | | | |
| / | | | |
| - | 2) | | |
| 7 | \ | | |
| | 7 | | |
| | | | |
| | | | |
| | | | |

| intlinais to be litted | | | |
|------------------------|---|--|--|
| Phoenix | | | |
| G5\4 (4 way) | 2 | | |
| G5\6 (6 way) | 2 | | |
| G5\12 (12 way) | 1 | | |
| ńk3 N | 0 | | |
| ŬK5 N | 0 | | |
| UK10 N | 0 | | |
| UK16 N | 0 | | |
| UK35 N | 0 | | |
| | | | |
| | | | |
| | | | |

Drilling Envelope Dimensions (mm)


| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 96 | 76 |
| Height | 29 | 29 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D | |
|-------|------------|------------|--|
| M16 | 0 | 0 | |
| M20 | 0 | 0 | |
| M25 | 0 | 0 | |
| M32 | 0 | 0 | |
| M40 0 | | 0 | |



| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP9 | Polycarbonate (RAL7035) | 122 | 120 | 55 | 240 |
| ZP9 ABS | ABS (RAL7035) | 122 | 120 | 55 | 220 |



Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | |
|---------------|----|
| BK4 (4 way) | 2 |
| BK6 (6 way) | 2 |
| BK12 (12 way) | 1 |
| MK 6/4 | 2 |
| MK 6/6 | 1 |
| SAK 2.5 | 14 |
| SAK 4 | 13 |
| SAK 6N | 10 |
| SAK 10 | 8 |
| SAK 16 | 7 |
| SAK 35 | 5 |
| | < |
| | |
| | |
| | 1 |

| | Entrelec | | (| Phoenix |
|---|----------|-----|---|--------------|
| | MA2.5/5 | 17_ | \ | G5\4 (4 wa |
| | M4/6 | 14 | | G5\6 (6 wa |
| | M6/8 | 8/ | | G5\12 (12 wa |
| | M10/10 | 8 | \ | nk3 n |
| | M16/12 | 7 < | > | UK5 N |
| | M35/16 | 25 | | UK10 N |
| | |) | | UK16 N |
| | | | | UK35 N |
| | (12) | | | |
| K | | | | |
| \ | | | | |
| | 2) | | | |
| 7 | | | | |
| | 7 | | | |
| | | | | |
| | | | | |
| | | , | | |

| | Drilling Envelope | Dimensions | (mm) |
|--|-------------------|------------|------|
| | | | |

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 96 | 76 |
| Height | 59 | 59 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 2 |
| M20 | 2 | 1 |
| M25 | 2 | 1 |
| M32 | 1 | 1 |
| M40 | 0 | 0 |

* Using standard gland clearances

| ~~ \ \ \ | 7.) |
|----------|---------|
| Specific | :ations |

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP10 | Polycarbonate (RAL7035) | 122 | 120 | 85 | 295 |
| ZP10 ABS | ABS (RAL7035) | 122 | 120 | 85 | 270 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | |
|---------------|-----|
| BK4 (4 way) | 5 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 2 |
| MK 6/4 | 3 |
| MK 6/6 | 2 |
| SAK 2.5 | 28 |
| SAK 4 | 28 |
| SAK 6N | 21 |
| SAK 10 | 16 |
| SAK 16 | 14 |
| SAK 35 | 7 _ |
| ^ | |
| | |
| | |
| | |

| MA2.5/5 | 33_ | \ | G5 4 (4 way) |
|---------------------|------|---|----------------|
| M4/6 | 28 | | G5\6 (6 way) |
| M6/8 | 21 | L | €5\12 (12 way) |
| M10/10 | 16 | / | лkз и |
| M16/12 | 14 | Ì | ŬK5 N |
| M35/16 | 7,10 | | UK10 N |
| | | | UK16 N |
| | | | UK35 N |
| (12) | | | |
| | | | |
| | | | |
| $\langle z \rangle$ | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | 1 | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 174 | 76 |
| Height | 48 | 48 |


Gland Entry Matrix *

| _ | | | |
|---|------|------------|------------|
| | Size | Side A - C | Side B - D |
| | M16 | 5 | 2 |
| | M20 | 4 | 1 |
| | M25 | 3 | 1 |
| | M32 | 0 | 0 |
| | M40 | 0 | 0 |

* Using standard gland clearances

| | M1 11 |
|---|----------------|
| | Specifications |
| 1 | Specifications |
| | |

| ß | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|----|-------------|-------------------------|------------|-------------|------------|------------|
| 12 | ZP1T | Polycarbonate (RAL7035) | 200 | 120 | 75 | 400 |
| 7 | ZP1,1 ABS | ABS (RAL7035) | 200 | 120 | 75 | 380 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions:

-40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of

| Weidmuller | |
|---------------|----|
| BK4 (4 way) | 5 |
| BK6 (6 way) | 3 |
| BK12 (12 way) | 2 |
| MK 6/4 | 3 |
| MK 6/6 | 2 |
| SAK 2.5 | 28 |
| SAK 4 | 28 |
| SAK 6N | 21 |
| SAK 10 | 16 |
| SAK 16 | 14 |
| SAK 35 | 7 |
| | < |
| | |
| | |
| | |

| Entrelec | | (- | Phoenix | |
|----------|------|-----|----------------|----|
| MA2.5/5 | 33_ | / | G5\4 (4 way) | 5 |
| M4/6 | 28 | | G5\6 (6 way) | 3 |
| M6/8 | 21 | | G5\12 (12 way) | 2 |
| M10/10 | 16 | \ | UK3 N | 32 |
| M16/12 | 14 🗘 | > | UK5 N | 27 |
| M35/16 | 7,10 | | UK10 N | 16 |
| |) | | UK16 N | 13 |
| | | | UK35 N | 11 |
| (54) | | | | |
| | | | | |
| | | | | |
| 7/ | | | | |
| | | | | |
| -/ | | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)

| Side A - C | | Side B - D | | |
|------------|-----|------------|--|--|
| Width | 174 | 106 | | |
| Height | 49 | 49 | | |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 5 | 3 |
| M20 | 4 | 2 |
| M25 | 3 | 2 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

\$pecifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP12 | Polycarbonate (RAL7035) | 200 | 150 | 75 | 475 |
| ZR12 ABS | ABS (RAL7035) | 200 | 150 | 75 | 440 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | | |
|---------------|------|----|
| BK4 (4 way) | 6 | |
| BK6 (6 way) | 4 | |
| BK12 (12 way) | 2 | |
| MK 6/4 | 4 | |
| MK 6/6 | 3 | |
| SAK 2.5 | 34 | |
| SAK 4 | 34 | |
| SAK 6N | 25 | |
| SAK 10 | 20 | |
| SAK 16 | 17 | ١. |
| SAK 35 | 11 ~ | l |
| | | 1 |
| | | 1 |
| | | |

| | | () | Phoenix | |
|---------|-------|-----|----------------|----|
| MA2.5/5 | 41_ | / | G5\4 (4 way) | 6 |
| M4/6 | 34 | \ | G5\6 (6 way) | 4 |
| M6/8 | 25 | | G5\12 (12 way) | 2 |
| M10/10 | 20 | \ | UK3 N | 39 |
| M16/12 | \ 17♦ | ŀ | UK5 N | 33 |
| M35/16 | Z 1,2 | | UK10 N | 20 |
| |) | | UK16 N | 16 |
| | | | UK35 N | 13 |
| (54) | | | | |
| | | | | |
| | | | | |
| 7/ | | | | |
| \ | | | | |
| 7 | | | | |
| | | | | |
| | , | | | |

Drilling Envelope Dimensions (mm)

| Side A - C | | Side B - D |
|------------|-----|------------|
| Width | 214 | 76 |
| Height | 64 | 64 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 4 |
| M20 | 6 | 1 |
| M25 | 4 | 1 |
| M32 | 3 | 1 |
| M40 | 0 | 0 |

* Using standard gland clearances

Specifications (

| 4 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| 1 | ZP13 | Polycarbonate (RAL7035) | 240 | 120 | 100 | 550 |
| l | ZP13 ABS | ABS (RAL7035) | 240 | 120 | 100 | 495 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions:

-40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check this enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (am

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 34 |
| SAK 4 | 34 |
| SAK 6N | 25 |
| SAK 10 | 20 |
| SAK 16 | 17 |
| SAK 35 | 11 ~ |
| | |
| | |
| | |
| | |

| Entreice | | () | THECHN | |
|----------|-------|-----|----------------|----|
| MA2.5/5 | 41 | \ | G5 4 (4 way) | 6 |
| M4/6 | 34 | \ | G5\6 (6 way) | 4 |
| M6/8 | 25 | | 65\12 (12 way) | 2 |
| M10/10 | 20 | \ | NK3 N | 39 |
| M16/12 | \ 17♦ | ŀ | ŬK5 N | 33 |
| M35/16 | 212 | | UK10 N | 20 |
| | 7 | | UK16 N | 16 |
| | | | UK35 N | 13 |
| (64) | | | | |
| 71/2 | | | | |
| | | | | |
| 3) | | | | |
| \ | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 100 | 106 |
| Height | 64 (x2) | 64 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 6 |
| M20 | 4 | 2 |
| M25 | 4 | 2 |
| M32 | 2 | 2 |
| M40 | 0 | 0 |

* Using standard gland clearances

| < \ |
|-----------------|
| √Specifications |
| . / |

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP14 | Polycarbonate (RAL7035) | 240 | 160 | 90 | 645 |
| ZR74 ABS | ABS (RAL7035) | 240 | 160 | 90 | 575 |



$ZP15\ /\ ZP15\ ABS\ {}_{ABS\ and\ Polycarbonate\ Enclosures}$

Application

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F)

ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 36 |
| SAK 4 | 36 |
| SAK 6N | 27 |
| SAK 10 | 21 |
| SAK 16 | 18 |
| SAK 35 | 12 _ |
| ^ | |
| | |
| | |
| | |
| \Diamond | 11 |

| | | | 1 1 |
|---|---------|------|-----|
| | MA2.5/5 | 43 | \ |
| | M4/6 | 36 | |
| | M6/8 | 27 | |
| | M10/10 | 21 | \ |
| | M16/12 | 18 | 2 |
| | M35/16 | 7 13 | |
| | | \ | |
| | ~ [] | / | |
| | (64) | | |
| K | 7/ | | |
| / | | | |
| - | 7/ | | |
| 7 | \ | | |
| | J | | |
| | | | |
| | | | |
| | | | |

| Drilling Envelope Dimensions (| mm) |
|--------------------------------|-----|
| | |

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 104 | 116 |
| Height | 65 (x2) | 65 |

Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 6 |
| M20 | 4 | 2 |
| M25 | 4 | 2 |
| M32 | 2 | 2 |
| M40 | 0 | 0 |

* Using standard gland clearances

Specifications

| 1 | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-------------------------|------------|-------------|------------|------------|
| 1 | ZP15 | Polycarbonate (RAL7035) | 250 | 160 | 90 | 550 |
| ĺ | ZR75 ABS | ABS (RAL7035) | 250 | 160 | 90 | 495 |

G5\4 (4 way) G5\6 (6 way)

G5\12 (12 way)

NK3 N

ŬK5 N

UK10 N

UK16 N

UK35 N

4

2


42

42

21

17

14



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 2)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of

| Weidmuller | |
|---------------|----|
| BK4 (4 way) | 6 |
| BK6 (6 way) | 4 |
| BK12 (12 way) | 2 |
| MK 6/4 | 4 |
| MK 6/6 | 3 |
| SAK 2.5 | 34 |
| SAK 4 | 34 |
| SAK 6N | 25 |
| SAK 10 | 20 |
| SAK 16 | 17 |
| SAK 35 | 11 |
| | |
| | |
| | |
| | |
| \wedge | |

| Entrelec | | (| Pr |
|----------|------|---|-------------|
| MA2.5/5 | 41_ | / | Œ |
| M4/6 | 34 | | G |
| M6/8 | 25 | |) Ģ5 |
| M10/10 | 20 | \ | ЛŔ |
| M16/12 | 17 🛇 | > | йĸ |
| M35/16 | 7,15 | | UK |
| | ` | | UK |
| | / | | UK |
| (12) | | | |
| | | | |
| | | | |
| 3 | | | |
| | | | |
| ~ | | | |
| | | | |
| | | | |
| | | | |

| G5\4 (4 way) | 6 |
|----------------|----|
| G5\6 (6 way) | 4 |
| G5\12 (12 way) | 2 |
| NK3 N | 39 |
| ŬK5 N | 33 |
| UK10 N | 20 |
| UK16 N | 16 |
| UK35 N | 13 |
| | |
| | |
| | |
| | |
| | |

Drilling Envelope Dimensions (mm)

| Side A - C | | Side B - D |
|------------|---------|------------|
| Width | 100 | 106 |
| Height | 64 (x2) | 64 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 12 | 6 |
| M20 | 4 | 3 |
| M25 | 4 | 2 |
| M32 | 2 | 2 |
| M40 | 0 | 0 |

* Using standard gland clearances

\$pecifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP16 | Polycarbonate (RAL7035) | 240 | 160 | 120 | 805 |
| ZP16 ABS | ABS (RAL7035) | 240 | 160 | 120 | 720 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates and separators. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number or

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 10 |
| BK6 (6 way) | 6 |
| BK12 (12 way) | 4 |
| MK 6/4 | 6 |
| MK 6/6 | 4 |
| SAK 2.5 | 56 |
| SAK 4 | 56 |
| SAK 6N | 42 |
| SAK 10 | 34 |
| SAK 16 | 28 |
| SAK 35 | 18 _ |
| | |
| < | // |
| | |
| | |
| \Diamond | |
| | ^ |

| | | () | Phoe |
|---------|------|-----|-------|
| MA2.5/5 | 68_ | / | G5\4 |
| M4/6 | 56 | | G5\6 |
| M6/8 | 42 | | G5\12 |
| M10/10 | 34 | \ | MK3 N |
| M16/12 | 28 🔾 | > | ŬK5 N |
| M35/16 | 220 | | UK10 |
| | (| | UK16 |
| ~ ~ | / | | UK35 |
| | | | |
| | | | |
| | | | |
| 77 | | | |
| \ | | | |
| 3 | | | |
| | | | |
| | | | |
| | | | |

| Phoenix | |
|----------------|----|
| G5\4 (4 way) | 6 |
| G5\6 (6 way) | 4 |
| G5\12 (12 way) | 2 |
| UK3 N | 39 |
| ŬK5 N | 33 |
| UK10 N | 20 |
| UK16 N | 16 |
| UK35 N | 13 |
| | |
| | |
| | |
| | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 130 | 186 |
| Height | 44 (x2) | 44 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 8 | 5 |
| M20 | 6 | 4 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

\$pecifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP17 | Polycarbonate (RAL7035) | 300 | 230 | 85 | 930 |
| ZR17 ABS | ABS (RAL7035) | 300 | 230 | 85 | 875 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree IP65

Certification

NEMA Types 1, 4X, 12 UL

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions: -40° to 120° C (-94° to 248° F) ABS versions: -40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | |
|---------------|------|
| BK4 (4 way) | 18 |
| BK6 (6 way) | 12 |
| BK12 (12 way) | 6 |
| MK 6/4 | 14 |
| MK 6/6 | 8 |
| SAK 2.5 | 110 |
| SAK 4 | 110 |
| SAK 6N | 82 |
| SAK 10 | 66 |
| SAK 16 | 54 |
| SAK 35 | 36 _ |
| | |
| | |
| | |
| | |
| \Diamond | |

| | 211110100 | | 1 | |
|------------|-----------|-----|---|---|
| | MA2.5/5 | 132 | / | S |
| | M4/6 | 110 | | 1 |
| | M6/8 | 82 | | J |
| | M10/10 | 66 | / | 7 |
| | M16/12 | 54 | 2 | ι |
| | M35/16 | 36 | | _ |
| | | | | - |
| | | | | Į |
| | 157 | | | |
| <i>(</i> * | | | | |
| | | | | |
| 7 | 1) | | | |
| 7 | | | | |
| | 7 | | | |
| | | , | | |

| Phoenix | |
|----------------|-----|
| 55\4 (4 way) | 18 |
| \$5\6 (6 way) | 12 |
| 35\12 (12 way) | 6 |
| JĶ3 N | 126 |
| JK5 N | 106 |
| JK10 N | 64 |
| JK16 N | 54 |
| JK35 N | 42 |
| | |
| | |
| | |
| | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 150 | 136 |
| Height | 85 (x2) | 85 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 18 | 9 |
| M20 | 12 | 6 |
| M25 | 8 | 4 |
| M32 | 4 | 2 |
| M40 | 4 | 2 |

* Using standard gland clearances

Specifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP18 | Polycarbonate (RAL7035) | 360 | 200 | 150 | 1850 |
| ZP18 ABS | ABS (RAL7035) | 360 | 200 | 150 | 1625 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)

Industrial areas

Protection Degree

IP65

Certification

NEMA Types 1, 4X, 12

Material

Moulded Polycarbonate - grey (RAL7035) or Moulded ABS - grey (RAL7035)

Temperature Rating

Polycarbonate versions:

-40° to 120° C (-94° to 248° F) ABS versions:

-40° to 65° C (-94° to 149° F)

Power Rating

Not Applicable



Terminal Populations (Maximum Number of Rails = 1)

Calculations do not include the use of end stops, end plates ánd separátors. Check that the enclosure can accommodate the cable bending radius and that the earth stud and entry location will permit the required number of (aminfails, to be fitted

| Weidmuller | | |
|---------------|------|-----|
| BK4 (4 way) | 10 | |
| BK6 (6 way) | 6 | |
| BK12 (12 way) | 4 | |
| MK 6/4 | 6 | |
| MK 6/6 | 4 | |
| SAK 2.5 | 56 | |
| SAK 4 | 56 | |
| SAK 6N | 42 | |
| SAK 10 | 34 | |
| SAK 16 | 28 | K |
| SAK 35 | 18 | _ \ |
| | | 7 |
| (| | 7, |
| | | |
| | / // | |

| | Entrelec | | | Phoenix |
|---|----------|------|---|--------------|
| | MA2.5/5 | 68 | / | G5\4 (4 wa |
| | M4/6 | 56 | | G5\6 (6 wa |
| | M6/8 | 42 | | G5\12 (12 wa |
| | M10/10 | 34 | \ | лкз и |
| | M16/12 | 28 < | > | ŬK5 N |
| | M35/16 | ∑29 | | UK10 N |
| | | 1 | | UK16 N |
| | | / | | UK35 N |
| | (69) | | | |
| K | | | | |
| / | | | | |
| - | 7) | | | |
| 7 | | | | |
| | 7 | | | |
| | | | | |
| | | | | |
| | | | | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 130 | 186 |
| Height | 44 (x2) | 44 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 8 | 5 |
| M20 | 6 | 4 |
| M25 | 0 | 0 |
| M32 | 0 | 0 |
| M40 | 0 | 0 |

* Using standard gland clearances

\$pecifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|-------------|-------------------------|------------|-------------|------------|------------|
| ZP19 | Polycarbonate (RAL7035) | 300 | 230 | 110 | 1250 |
| ZR19 ABS | ABS (RAL7035) | 300 | 230 | 110 | 1025 |



All blue dimensions in mm, all green dimensions in decimal inches (drawing not to scale)



Other Products

GRN Junction Boxes

BPC Control Stations

SXC Control Stations

Submersible Enclosures

GRN Enclosures

The ABTECH GRN8 enclosure has been designed as a cost-effective junction box for use in hazardous areas. There are a number of terminal and entry configurations available, resulting in a highly versatile enclosure which is suitable for a wide variety of installations. The enclosure is manufactured in a UL approved UV stabilised polycarbonate and is available as a preassembled terminal box or as an empty enclosure for OEM applications.

Additionally, there is the facility to mount an earth bar inside the box which can be used to terminate and connect as many earthing wires as there are cable entries. This method is useful for the equi-potential bonding of metal cable glands and an additional equi-potential wire can be linked to the internal/external earth stud to facilitate a positive connection to the 'plant dirty' earthing system. The earth bar can alternatively be used as a clean earth for instrumentation as it can be electrically isolated from the dirty earth.




It can be supplied with the option of acterminal rail, an internal chassis plate of directly mounted terminals for cables up to 4 sq. min.

The GRN8 is ATEX certified for use in Zone 1 hazardous areas EEx'e' to BS EN 50019:2000 for Zone 1 and Zone 2 applications, BS EN 50281-1 for Zone 21 and Zone 22 applications and EEx'nA' to BS EN 50021 for Zone 2 applications.

The GRN8 is a competitive product for lower risk applications in both safe and hazardous areas. It is designed to operate within the ambient temperature range of 20°C to + 40°C (-4°F to 104°F) but for non hazardous application the upper ambient temperature range can be extended to 120°C (248°F). As well as being UV stable, polycarbonate is resistant to a wide variety of chemicals. The use of silicone rubber lid gasket and 316 stainless steel lid fixings ensures that the chemical resistance of the GRN8 is not compromised.




Earthing can be accomplished by various means. The provision of an internal/external earth/ground stud is optional or one of the terminals can be dedicated to earthing / grounding functions.



GRN8-1


Up to 8 post / mantle type EEx'e (erminals (up to 2 x 4mm² conductors per terminal) Star configuration



GRN8-2

Up to 33 screw/clamp type EEx'e' terminals (for conductors up to 2.5mm²) See table on page 200 for other terminal types

Horizontal / Vertical configuration



GRN8-3

Up to 17 screw/clamp type EEx'e' terminals (for conductors up to 2.5mm²) See table on page 200 for other terminal types

Diagonal configuration

GRN8 Range Polycarbonate Junction Boxes

Industrial and Hazardous areas

IP65

ATEX EEx e T6 (Zone 1 & Zone 2) to BS EN 50019 ATEX EEx e T85°C (Zone 1 & Zone 2) to BS EN 50281-1-1

Moulded Polycarbonate (Black)

Standard: -40° to 80° C (-40° to 176° F) Option: -40° to 120° C (-48° to 248° F) ATEX Certified Version -20° to 40° C (-4°F to 104°F)

10.0W

BK-

ВК



Terminal Populations (Maximum Number of Rails = 1)

17

| 4 (4 way) | 3 | MA2.5/5 | |
|-------------|---|---------|--|
| 6 (6 way) | 2 | M4/6 | |
| 12 (12 way) | 1 | M6/8 | |
| < 6/4 | 2 | M10/10 | |
| | _ | 144/40 | |

| BK12 (12 way) | 1 | | M6/8 | 14 |
|---------------|-----|---|------------|----|
| MK 6/4 | 2 | | M10/10 | 11 |
| MK 6/6 | 1 | | M16/12 | 9 |
| SAK 2.5 | 17 | | M35/16 | ∕6 |
| SAK 4 | 17 | | | |
| SAK 6N | 14 | | ~ | |
| SAK 10 | 11 | | | 1 |
| SAK 16 | 9 | | | |
| SAK 35 | 5 | / | | |
| WDU 2.5 | 20 | | | |
| WDU 4 | 17८ | | | |
| WDU 6 | 14 | / | \bigcirc | |
| WDU 10 | 11 | 1 | | |
| WDU 16 | 8 | | | |

| G514 (4 way) | 3 |
|----------------|----|
| G5\6 (6)way) | 2 |
| G5\12 (12 way) | 1 |
| NK 3N | 21 |
| UK 5N | 17 |
| UK 10N | 11 |
| UK 16N | 9 |
| UK 35N | 7 |
| | |
| | |
| | |
| | |
| | |
| | |

Drilling Envelope Dimensions (mm)

| | Side A - C | Side B - D |
|--------|------------|------------|
| Width | 54 (x2) | 48 (x2) |
| Height | 75 | 75 |


Gland Entry Matrix *

| Size | Side A - C | Side B - D |
|------|------------|------------|
| M16 | 4 | 4 |
| M20 | 4 | 4 |
| M25 | 2 | 2 |
| M32 | 0 | 2 |
| M40 | 0 | 0 |

^{*} Using standard gland clearances

Specifications

| Ì | Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) |
|---|-------------|-----------------------|------------|-------------|------------|------------|
| J | GRN8-1 | Moulded Polycarbonate | 160 | 160 | 90 | 500 |
| 1 | GRN8-2 | Moulded Polycarbonate | 160 | 160 | 90 | 500 |
| | GRN8-3 | Moulded Polycarbonate | 160 | 160 | 90 | 500 |



ABCS Range

Application

Hazardous areas

Protection Degree

IP66

Certification

ATEX II 2 GD Ex ed IIC T4

IEC Ex

Materia

Carbon Loaded Glass Reinforced Polyester (Black)

Temperature Rating

-20° to 55° C (-4° to 131° F)

Maximum Voltage

415V

Maximum Switching Current

6A



Specifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) * |
|-------------|----------------------------|------------|-------------|------------|--------------|
| ABCS6 xx | Glass Reinforced Polyester | 1/22 | 120 | 90 | 750 |
| ABCS 7 xx | Glass Reinforced Polyester | 220 | 120 | 90 | 1060 |
| ABCS 8 xx | Glass Reinforced Polyester | Y60 | 160 | 90 | 1060 |
| ABCS 9 xx | Glass Reinforced Polyester | 260 | 160 | 90 | 1170 |
| ABCS 10 xx | Glass Reinforced Polyester | 360 | 160 | 90 | 2150 |
| ABCS 11 xx | Glass Reinforced Polyester | 560 | 160 | 90 | 3200 |
| ABCS 12 xx | Glass Reinforced Polyester | 255 | 250 | 120 | 3200 |
| ABCS 13 xx | Glass Reinforced Rolyester | 400 | 250 | 120 | 3650 |
| ABCS 14 xx | Glass Reinforced Polyester | 600 | 250 | 120 | 5235 |
| ABCS 15 xx | Glass Reinforced Polyester | 400 | 405 | 120 | 5580 |

* Weight specified is enclosure only. Total weight depends on actuator configuration

Notes 🔷

The ABCS range of control stations have been designed for use in potentially explosive atmospheres and are suitable for most das groups including hydrogen. Based on the popular BPGC range of enclosures, they are manufactured from carbon-loaded glass reinforced polyester (GRP). This material gives excellent mechanical strength and life expectancy, making these control stations particularly suitable for use in harsh environmental conditions. Additionally, the anti-static properties of the enclosure material make them ideal for use in dust hazard environments. A number of common actuator types can be fitted, including Start, Stop, Emergency Stop and rotary type switches. Tag and individual actuator labels can be fitted as required.

Some typical arrangements of control station size and actuator layouts are shown on the page opposite, however, we are able to supply many other variants as dictated by your required design. Please contact our Sales office for further details.



(400 x 150 x 120mm). Glands: 2 x M25

SXCS Range

Applicatio

Hazardous areas

Protection Degree

IP66

Certification

ATEX II 2 GD Ex de IIC T4 IEC Ex

Material

Stainless steel 316 (1.4404)

Temperature Rating

-20° to 55° C (-4° to 131° F)

Maximum Voltage

415V

Maximum Switching Current

6A



Specifications

| Part Number | Material | Width (mm) | Length (mm) | Depth (mm) | Weight (g) * |
|-------------|--------------------------------|------------|-------------|------------|--------------|
| SXCS66 xx | Stainless steel 316 (1.4404) | 152 | 152 | 102 | 2200 |
| SXCS0 xx | Stainless steel 316 (1.4404) | 152 | 229 | 140 | 3200 |
| SXCS0.5 xx | Stainless steel 316 (1.4404) | 184 | 274 | 140 | 5000 |
| SXCS1 xx | Stainless steel 316 (1.4404) (| 234 | 324 | 140 | 6300 |
| SXCS1.5 xx | Stainless steel 316 (1.4404) | 306 | 306 | 140 | 7300 |
| SXCS2 xx | Stainless steel 316 (1.4404) | 372 | 324 | 140 | 9500 |
| SXCS3 xx | Stainless steel 316 (1.4404) | 372 | 448 | 140 | 11300 |
| SXCS4 xx | Stainless steel 316 (1.4404) | 372 | 510 | 140 | 12700 |
| SXCS5 xx | Stainless steel 316 (1,4404) | 510 | 510 | 140 | 17000 |
| SXCS6 xx | Stainless steel 316 (1.4404) | 510 | 780 | 140 | 24000 |
| SXCS7 xx | Stainless steel 316 (1.4404) | 650 | 950 | 140 | 35000 |
| SXCS8 xx | Stainless stee 316 (1.4404) | 800 | 1250 | 140 | 40000 |

^{*} Weight specified is enclosure only. Total weight depends on actuator configuration

Notes

The SXCS range of control stations have been designed for use in potentially explosive atmospheres and are suitable for all gas groups including hydrogen. Based on the SX range of enclosures, they are manufactured from high quality 316 stainless steel. This material offers the highest degree of environmental protection and is suitable for even the most enduous of conditions. Additionally, stainless steel prevents the build up of static electricity, making these controls stations ideal for use in dust hazard applications.



XCS3 25

Control Elements, (x5) Key Switch, Start, Selector, Illuminated Green Indicator, Emergency Stop. Mounted in SX3 Enclosure (372 x 448 x 140mm). Glands: 2 x M25

Submersible Enclosures

By definition, a submersible enclosure is one which provides complete protection to live or moving parts within the enclosure. Such protection being against the ingress of dust (or other contaminants) as well as protection against the ingress of water.

There are two distinct IP rating for submersible enclosures. These are:

IPX7 - submersion in one metre of water for 30 minutes, and IPX8 - submersion depth and duration to be agreed between manufacturer and client. The degree of protection provided is normally specified to a maximum depth for a pre-determined duration and defined frequency of duration for example "up to 20 metres for 72 hours - weekly". IEC 529 - BS 5345 Part 1 relates to IP 68.



ABTECH designed their first submersible terminal box over 15 years ago. The IP Rating standard in use at the time was 855490:1977. This, like its modern replacement BS EN 60529:1992, lists both the test method for ingress protection and the acceptance criteria, in general, the acceptance criteria for water penetration is that the amount of water entering the enclosure, if any, shall be insufficient to interfere with the safety and operation of the equipment inside. However, if the operating requirements include indefinite submersion the only realistic amount of water that can be tolerated is none.

The difficulty in detecting small quantities of water is that water may be present as a vapour, and therefore invisible. In time limited tests water may enter an enclosure in quantities small enough to increase the humidity inside the box,

but this would not be apparent using a visual check since it would be invisible. A more objective measurement technique is required.

With the assistance of the University of Sheffield. ABTECH devised a method of detecting very small quantities of water. Two identical enclosures are required, one as a test box and one as a control. A conditioning room is set up in a location with constant humidity. The room must then be equipped with a calibrated high resolution analytical balance. Each box is left open in the same part of the conditioning room, close to the balance for 24 hours to ensure that they are both at the same temperature and both contain air at the same relative humidity. Using the batance one sachet of desiccant is weighed and quickly inserted into each box. The boxes are immediately closed and the lids secured. The weight of the desiccant in each box is recorded. The test box is then subject to the test as agreed with the client or as stated in the current British or international standard. The control box is left in the conditioning room.

When the test is completed the test box is thoroughly dried on the outside and left for several hours, preferably overnight, in a dry place outside of the conditioning room. This ensures that any extraneous water on the outside of the box has evaporated. The test box is then returned to the conditioning room. Both boxes are opened and quickly the desiccant is weighed again. The results are recorded. If no water has entered the test box the increase in weight of each sachet of desiccant will be the same. This is because they have both absorbed all the moisture in the air that was trapped inside the boxes. If any water has entered the test box the desiccant from that box will show a greater increase in weight. It should be noted, however. that it is only possible to measure the amount of water vapour absorbed by the desiccant within the accuracy limits of the balance.

ABTECH have devoted much development effort to the concept of submersible enclosures. Small enclosures are eminently suitable for submersible applications. They are relatively stiff and have little surface area for water pressure to act upon. For shallow depths (less than 1m) submersion is generally achievable using standard off the shelf enclosures e.g. the ABTECH ZAG, BPG and SX ranges of enclosures. However, boxes soon become large enough to require reinforcement. A box of only 300mm cube in 10 metres of water will experience over a tonne of pressure on each of its six sides.

The actual forces that will be experienced need to be calculated and reinforcement needs to be added whilst leaving as much internal volume as possible free for components, even if that means using external reinforcement.

Added to this is the problem of preventing the cover sealing edges from cutting through the gasket, and reinforced boxes can be very heavy so it may also be necessary to include lifting eyes.

Manufacturing must be of the highest quality. It is essential to ensure high quality welding on fabricated boxes, correctly specified for both the static and dynamic loading they may have to withstand. Water under pressure will find the tiniest pin hole and will leak into the box until the air pressure inside is equal to the water pressure outside.

Once the necessary calculations have been completed then rigorous testing must be endured to ensure that the design meets the pre-agreed requirements of enclosure submersion.



Where submersion over elongated periods of time are to be catered for then consideration must also be given to enclosure material. By far the most flexible material available for submersible applications is marine grade 316L stainless steel.

With non submersible applications, cable entry is usually through a proprietary cable gland which itself will normally qualify for an IP rating similar to that of the enclosure to which it is applied. However, due to the greater pressures present with submersible enclosures, cable entry is normally achieved through welded stainless steel hubs suitably positioned to receive incoming multi-core cables.

As with all enclosure applications reliance is placed on the equipment installer to ensure that proper engineering practices are adhered to in order to ensure that the siting and installation of ABTECH Submersible Enclosures is within agreed conditions.

ABTECH have designed submersible boxes for use in a wide variety of applications ranging from prestige projects such as the underwater lighting in Trafalgar Square to severe applications on the legs of unmanned offshore installations.

If you have a submersible box application, the ABTECH technical staff will be happy to advise further.



Cable Glands and Adaptors

ASG Non-Armoured Glands

AAG Armoured Glands

ABAD Adaptors

ABRE Reducers

ABSP Stopping Plugs

Accessories

Gland Type Unarmoured

Sealing Area

Cable Outer Sheath

Application

Industrial and Hazardous areas

Protection Degree

IP66 and 67 to IEC529

Certification

Zone1, Zone2, Zone21 and Zone22, Gas Groups IIA, IIB and IIC Baseefa09AATEX0187X IEC Ex: IECEx BAS 09.0089X


Material


Brass, Brass nickel plated or Stainless Steel

Temperature Rating -60° to 80° C (-76° to 176° F)



Technical Drawing





Accessories

Lock Nut, Sealing washer, serrated washer, Earth Tag and PVC Shroud are available

| Min Thread Length "C" | Metric NPT | | | ' | | 000 | 20.0 | | 15.0 | 79.0 | 25.6 | 26.0 | 040 | 0.72 | 40.0 | 7 | c. <u>1</u> | 44.0 | | | | | - |
|---|-------------------------|------|----------|----------|----------|----------|----------|---------|----------|----------|---------|---------|----------|----------|---------|---------|-------------|-----------|-----------|-----------|-----------|-----------|-----------|
| Jimension | Across Across Corners N | | 346 | 0.4.2 | 0 90 | 0.00 | 30.0 | 35.5 | 13 5 | 0.0 | 53.5 | 64.0 | 0 | 0.10 | 94.0 | 109.5 | 113.5 | 135.0 | 135.0 | 1520 | 152/9 | 1690 | 100.0 |
| Hexagon Dimension | | | 22.0 | | 24.0 | | 27.0 | 32.0 | 39.0 | | 48.0 | 58.0 | 73.0 | | 85.0 | 0.001 | 105.0 | (122.0) | (123.0 | 138.0 | 138.0 | 0.11 | 0.4.0 |
| | Alternative Seal (S) | Max | | 8.0 | | 8.0 | 13.0 | 15.0 | 21.0 | 24.0 | 28.0 | 35.0 | 7 44.0 | 50.0 | 0.88.) | 67,0 | 73.0 |) _ | | | | | |
| Cable Acceptance Details (Outer Sheath 'OD') | Alternative | Min. | | 4.0 | | 4.0 | 8.5 | 10.0 | 16.0 | 20.0 | 722.0 | 27.5 | /380 | 43.0 | 51.0 | 61.0 | 68.0 | | | | | | |
| Cable Accep (Outer SI | Seal May | | 6.0 | 10.0 | 6.0 | 10.0 | 15.0 | 18.0 | 23.0 | 26.0 | 32.0 | 40.0 | 47.0 | 54.0 | 65.0 | 71.5 | 9.77 | 86.0 | 92.0 | 98.0 | 102.0 | 110.0 | 116.0 |
| | Standard Seal | Min. | 3.0 | | 3.0 | 6.1 | 1/10:1 | 1/2/0/ | 18.1 | 22.1 | 26.1 | 32.1 | 40.1 | 47.1 | 55.1 | 65.1 | 71.6 | 73.5 | 80.0 | 86.0 | 92.0 | 97.0 | 104.0 |
| ead Size | NPT | | | | | 1/22/ | | 3/4" | ŧ | - | 1 1/4" | 1 1/2" | ā | 7 | 2 1/2" | ē | n | 4 | - | - | - | | - |
| Entry Thread Size | Metric | M16 | | | | M25 | M32 | | M40 | MS0 | M63 | | M75 | M80 | M90 | 00194 | 200 | M116 | 0 | 06.190 | OS IM | | |
| Cable Gland Sive | | | ASG-M16a | ASG-M16b | ASG-M20a | ASG-M20b | ASG-M20c | ASG-M25 | ASG-M32a | ASG-M32b | ASG-M40 | ASG-M50 | ASG-M63a | ASG-M63b | ASG-M75 | ASG-M80 | ASG-M90 | ASG-M100a | ASG-M100b | ASG-M115a | ASG-M115b | ASG-M130a | ASG-M130b |

AAG

Gland Type

Armoured (suitable for wire armour and wire braid cable types

Seal Type

Double Compression

Application

Industrial and Hazardous areas

Protection Degree

IP66 and 67 to IEC529

Certification

Zone1, Zone2, Zone21 and Zone22, Gas Groups IIA, IIB and IIC Flameproof Exd and Increased Safety Exe Baseefa09AATEX0186X IEC Ex: IECEX BAS 09.0088X

Material


Brass, Brass nickel plated or Stainless Steel

Temperature Rating

-60° to 80° C (-76° to 176° F)



Technical Drawing



Lock Nut, Sealing washer, serrated washer, Earth Tag and PVC Shroud are available

| د د د د د د د د د د د د د د د د د د د | gin C | TAN | | | | 20.0 | 25.0 25.6 26.0 27.0 27.0 27.0 27.0 27.0 40.0 40.0 | | | | | | | | | 40.0 | 41.5 | 42.7 | | 44.0 | | | |
|---------------------------------------|--------------------|-------------------------|---------|----------|---------|---------|--|--------|---------|-------|--------|---------|------|--------|--|---------|-----------|---------|-----------|-------------|--------|---------|---------|
| Theory | i nread Lengin C | Metric | | | | | | | | | | | | | | | | | 7 | 20.0 | | | |
| imonejone | nexagon Dimensions | Across | þ | 0 90 | 0.02 | 33.5 | 40.5 | 51.2 | | 4 | 3 | | 72.8 | ŝ | | u G | 2 | | 104.5 | , ((, , | 1,14,0 | 123.0 | 139.0 |
| T OCCUPATION OF | nexagon r | Across Flats | ¥ | 0.80 | 0.47 | 30.0 | 36.0 | 45.8 | | 0 44 | 3 | 65.0 | | | | | | | 35.0 |) } | 107.0 | 115.0 | 128.0 |
| | Size | × | Min/Max | | | | 2 | 0,0.0 | | | | | | (| | | 0.110 | \$ | | | | | |
| | Armour Size | W | MinMax | | 20 000 | 3 | 1.25/1.6 | | 1.6/2.0 | | (| 252 | | | \\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\ |) 4 | 0.750 | | | | | 1.8/3.2 | |
| Cable Acceptance Details | | Outer Sheath 'OD' | Max | 12.0 | 16.0 | 20.0 | 26.0 | 33.0 | 25.0 | | 47.9 | 52.6 | 7 | 52.6 | | 96.0 | 65.5 | 67.0 | 70,7 | 2:01 | 89.5 | | 104.5 |
| ible Accept | | Outer SI | Min | 7.0 | 11.0 | 14.3 | 18.5 | 24.0 | 28.0 | < | 30.0 | 42.0 | | 42.0 | | 46.0 | 52.0 | 67.0 | 0.79 | 0.4.0 | 75.0 | | 88.0 |
| ů | | ve Seal | Max | | 8.0 | 12.0 | 15.4 | 21/2 | 30.0 | > | 28.0 | 41.0 | | 36.5 | | 53.0 | 47.0 | 64.3 | 202 | 2.0 | 68.0 | | 81.0 |
| | eath 'ID' | Alternative Seal (S) | Min | | 5.5 | 85 | 10.57 | 15.0 | 25.0 | | 22.0 | 31.5 | | 27.5 | | 42.5 | 39.0 | 54.5 | 900 | 9.0 | 0.09 | | 70.0 |
| | Inner Sheath 'ID' | d Size | Max | 8.0 | 0.6/ | 13.7/ | 16.7 | 23.5 | 28.0 | | 30.0 | 36.5 | | 41.0 | | 47.0 | 53.0 | 58.3 | 64.3 | 2 | 70.0 | 75.0 | 89.5 |
| | | Standard Size | Min | 5,5 | 7.5/ | 0.11 | 13.0 | 20.0 | 22.0 | | 25.0 | 27.5 | | 31.5 | | 39.0 | 42.5 | 49.0 | 2 7 2 | 3 | 67.0 | | 76.5 |
| SE! O | azic z | TAN | | < | 1/2" | .,, | ŧ, | - | 11/4" | 1 1/2 | 11/4" | 7/1 | 5". | 1 1/2" | | 2 1/2" | 2" 2 1/2" | 2 1/2" | 2 1/2" | 3" | 3 1/2" | | .4 |
| Finder Thross | znry inread size | Metric | | M20.0416 | 011070 | M20 | M25 | M32 | M40 | | M40 | M50 | | M50 | | M63 | M63 | M75 | 1475 | | M80 | M90 | M100 |
| | | Size | | AAG-20a | AAG-20b | AAG-20d | AAG-25a | AAG-32 | AAG-40a | | AAG-40 | AAG-50a | | AAG-50 | | AAG-63a | AAG-63 | AAG-75a | A A C. 75 | 2.500 | AAG-80 | AAG-90 | AAG-100 |

ABAD

Application

Industrial and Hazardous areas

Protection Degree

IP66 and 67 to IEC529

Certification


II2 GD EExd IIC / Exe II Zone1, Zone2, Zone21 and Zone22, Baseefa 09ATEX0188X IEC Ex: IECEx BAS 09.0090X

Material

Brass or Brass nickel plated or Stainless Steel



Technical Drawing



Lock Nut, Sealing washer, serrated washer, Earth Tag and PVC Shroud are available

| | | | _ | _ | | | _ | _ | | | | | | | _ | | | | | | | | _ | | | | | | | _ | _ | _ | _ | _ | _ | _ | _ |
|---------|-------------|---|-------------|---------------------------|------------|------------|-------------|-------------|----------------------------|---|---------------------|---------------------|---------------|------------------------|-----------------|---------------------------------------|---------------|-------------|-------------------------|-------------------|--------------|--------------|---------------|-----------------------------|-------------|-----------------|------------|-------------|----------------------|---------------|----------------------------|-------------|-----------------|------------------------------------|------------|--------------|----------------------|
| Glond | Thread | Size M20 | M25 | M32 | 3/4 | ï. | M25 | M32 | 0999 | | 11/4" | M32 | 0990 | WEO | :- | 11/4" | W40 | WE0 | M63 | 11/4" | 11/2" | WEO | M63 | M75 | 11/2" | Z | M63 | M75 | 788 | 84 | 21/2 | M75 |)W85 | /21/2" | :6 | M85 | :4 |
| | Min o | | | | | | | | | | | | | | | | | | , | 2 | | | | | | | | | | | | Ĉ | 1 | \ | | | |
| | | | | Ξ | | | | | 15 | | | | | 20.2 | | | | | 26.5 | | | | | 32.5 | | | | | 44.5 | | $\stackrel{\checkmark}{=}$ | | | 56.5 | _ | | 88 |
| gon | ۰ | 56.8 | 33.5 | 40.5 | 33.5 | 98 | 33.5 | 40.5 | 51.2 | 38 | 4 | 40.5 | 51.2 | 61.5 | 4 | 51.2 | 51.2 | 61.5 | 77 | 51.2 | 51.2 | 61.5 | 77 | 88.5 | 51.2 | 72 | 77 | 88.5 | 66 | (A | 89.5 | 10 mg | 8 | 89.5 | 110 | 8 | 13.7 |
| Hexagon | | - 2 | 8 | % | 8 | 88 | 98 | % | 45.8 | 35 | 9 | % | 45.8 | 88 | 9 | 45.8 | 45.8 | 88 | 22 | 45.8 | 45.8 | 8 | 2 | 90 | 45.8 | 8 | 20 | \$ (| 8 | 58 | 8 | 8 | 8 | 8 | 100 | 8 | 125 |
| | Ξ | (£) | W25 | M32 | 1/2 | 3/4" | M25 | WB2 | WWO | 3/4" | L | WB2 | NA0 | WEO | L | 11/4" | MAO | MSO | W63 | 11/4" | 11/2" | WEO | W63 | M75 | 11/2" | 2. | W63 | M75 |)/sav(| 1.2 | 21/2 | M75 | M85 | 21/2" | 50 | W85 | ţ, |
| Thread | | 2 | _ | MI6 | | _ | | | MZO | | | | | M25 | _ | | | | M32 | | | | | \ \delta | 7 | 6 | | 5) | > ogw | _ | | | _ | W63 | | | M75 |
| | z | 3 | _ | 2 | _ | | L | _ | × | | | | _ | × | _ | | | _ | × | | | | | \$` | | | \ \ \ \ \ | / — | × | _ | | | _ | 2 | _ | | 2 |
| | Part Number | ABAD-M1620 | ABAD-M1625 | ABAD-M1632 | ABAD-M1612 | ABAD-M1634 | ABAD-M2025 | ABAD-M2032 | ABAD-M2040 | ABAD-M2034 | ABAD-M201 | ABAD-M2532 | ABAD-M2540 | ABAD-M2550 | ABAD-M251 | ABAD-M25114 | ABAD-M3240 | ABAD-M3250 | ABAD-M3263 | ABAD-M32114 | ~ABAD-M32112 | ABAQ-1/44050 | (ABAD-MADES | ABAC-M4075 | ABAD-MAD112 | ABAD-MA92 | ABAD-M5063 | ABAD-M5075 | ABAD-M5085 | ABAD-M502 | ABAD-M50212 | ABAD-M6375 | ABAD-M6385 | ABAD-M63212 | ABAD-M633 | ABAD-M7585 | ABAD-M754 |
| Labor | Hole Size | (metric) | | M16 | | | | | WED | | | | | M25 | | | | () | ZW32 | \ \{ | 7 | | <u>)</u> ク | 0440 | | | | | WEO | | | | | W63 | | | M75 |
| | | | | | | | | | | | | | | | | | | | | \ \ \ | > | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | _ | _\ | | | / | | | | | | | | | | | | | | | | | |
| Cland | Thread | Size | W25 | M32 | 3/4" | | M25 | M32 | MAD | | 11/4" | M32 | NAMO | MSO | 175 | 1/1/2 | (MAD) | | W63 | 11/2" | 2 | MSO | W63 | M75 | 2,, | 21/2" | W63 | M75 | W85 | 21/2" | .0 | M75 | M85 | 3. | -4 | M85 | .4 |
| Н | Min Thread | | W25 | 15.5 MB2 | 3/4" | 1 | M25 | M32 | 16 MA0 | - | 11/4" | M32 | 7 NA0 | 20 NB0 | 3/4 | (JUL) \ | (MAD) | | 20 M63 | 11/2" | 2 | WEO | M63 | 20.5 M75 | 2" | 21/2" | W63 | M75 | 21 M85 | 21/2" | | N/75 | W85 | | 4" | | 33.5 |
| Н | | | M25 | | 3/4 | | M25 | M32 | | | 11/4" | | NA40 | 26.4 / 26 NBO | 1 | () Marin | OBM | | | 11/2" | 2". | NSO | M63 | | 2,, | 2 1/2" | W63 | M75 | | 21/2" | | N75 | | 8 | .4 | | |
| | ų o | | 33.5 M25 | 15.5 | 35 3/4" | 1 | 33.5 M25 | 40.5 M32 | 16 | ======================================= | 11/4" | 46.5 N | 51.2 / / NWO | 61.5 26.5 NBO | 51.2 | 51.2 | 51.2 | 61.5 | 8 | 51.2 | 72 2" | 61.5 M50 | 77 M63 | 20.5 | 72 | 89.5 21/2" | 77 M63 | 88.5 M75 | 21 | 89.5 | 3" | 88.5 M75 | 200 | 8 | | | 33.5 |
| Н | ų o | 26.8 | | 14.5 15.5 | | | | | 20 16 | | | | | /Se/4/ /2/2/ | 7 | \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ | > | | 32.5 20 | | | | | 42.5 20.5 | | | | | 54.5 21 | | | | 200 | 78 | | | 65.4 33.5 |
| | ų o | 24 26.8 | 33.5 | 40.5 14.5 15.5 | 35 | 44 | 33.5 | 40.5 | 51.2 20 16 | 7 | 163/ 61-2 | | 512// | (1.5) 26.9/ 20 | 45.8 51.2 | 45.8 51.2 | 51.2 | 5.19 | 77 32.5 20 | 45.8 51.2 | 72 | 61.5 | 77 | 88.5 42.5 20.5 | 72 | 80 89.5 | 77 | 88.5 | 99 54.5 21 | 80 89.5 | 110 | 5.88 | 99 | % 010 010 010 | 137 | 66 | 137 65.4 33.5 |
| | NI II | (f) | 30 33.5 | 36 40.5 14.5 15.5 | 32 35 | 40 44 | 30 33.5 | 36 40.5 | 45.8 51.2 20 16 | 7 | 1 61-2 | () Mes () Mes () | 45.8 51.2 | 02 1.5 26.5 20 | 512 | 51.2 | 45.8 51.2 | 5.16 88 | 70 77 32.5 20 | 51.2 | 22 22 | 5.16 81.5 | 77 07 | 80 88.5 42.5 20.5 | 65 72 | 89.5 | 77 07 | 80 88.5 | 90 99 54.5 21 | 89.5 | 110 011 | 80 88.5 | 8 99 | 3" 100 110 00.4 32 | 125 137 | 8 | 4" 125 137 65.4 33.5 |
| Hexpoor | NI H IN | (f) | M25 30 33.5 | M82 36 40.5 14.5 15.5 | 32 35 | 40 44 | 30 33.5 | 36 40.5 | glado 45.8 51.2 20 16 | 7 | 163/ 61-2 | () Mes () Mes () | 45.8 51.2 | NBO 55 61.5/ 26.5/ 20 | 45.8 51.2 | 45.8 51.2 | 45.8 51.2 | 5.16 88 | M63 70 77 32.5 20 | 2 11/2" 45.8 51.2 | 22 22 | 5.16 81.5 | M63 70 77 | 11/2" M75 80 88.5 42.5 20.5 | 65 72 | 2 21/2" 80 89.5 | M63 70 77 | M75 80 88.5 | 2" M85 90 99 54.5 21 | 80 89.5 | 110 011 | 80 88.5 | AMS5 90 99 cc.1 | 3" 100 110 00.4 32 | 125 137 | M85 90 99 | 4" 125 137 65.4 33.5 |
| Thread | N N N | (M) (f) " (f) " 5 (M) | M25 30 33.5 | 1/2 M32 36 40.5 14.5 15.5 | 3/4" 32 35 | 1" 40 44 | M25 30 33.5 | MSQ 36 40.5 | 3/4 / 4/40 45.8 51.2 20 16 | 4 | V1/4" / 45,8 1 61.2 | M32 (56) 46(5) | M40 45.8 51.2 | 1" M50 55 61.5 26.5 20 | 11/4" 45.8 51.2 | 11/2" 45.8 51.2 | M40 45.8 51.2 | M60 55 61.5 | 11/4" M63 70 77 32.5 20 | 11/2" 45.8 51.2 | 2" 85 72 | M60 55 61.5 | M63 70 77 | 11/2" M75 80 88.5 42.5 20.5 | 2" 85 72 | 21,2" 80 89.5 | M63 70 77 | M75 80 88.5 | 2" M85 90 99 54.5 21 | 21/2" 80 89.5 | 3" 100 110 | M75 80 88.5 | M85 90 99 cc. 4 | ABAD-N2123 21/2 3" 100 110 00.4 32 | 4" 125 137 | 3" AMS 90 99 | ABAD-N34 33.5 |

Industrial and Hazardous areas

Protection Degree

IP66 and 67 to IEC529

Certification

II2 GD EExd IIC / Exe II Zone1, Zone2, Zone21 and Zone22, Baseefa 09ATEX0188X IEC Ex: IECEx BAS 09.0090X


Material

Brass or Brass nickel plated or Stainless Steel



Technical Drawing

Accessories



Lock-Nut, Sealing washer, serrated washer, Earth Tag and PVC Shroud are available

| | Size | M16 | 1/2 | M16 | M20 | 1/2" | 3/4" | M16 | WDO | W25 | 1/2 | 3/4 | 1. | M32 | W25 | 1/2" | 3/4" | <u>:</u> _ | M32 | W40 | 3/4 | 11/2" | V440 | MEO | 1,, | 11/2" | | WEO | W63 | 11/2" | 1,51 | 12112 | M63 | M75 | |
|--------------------------|--------------------|-------------------------|-----------------|------------------------|----------------|------------|---|------------|--------------------|------------------|-----------------------|---------------|-------------------|----------------|--------------|--------------------------|----------------------|--|------------|----------------|-----------------|--------------|---------------|---------------|----------------|-------------|----------------|-------------|----------------|-----------------|--------------|-------------|----------------|---------------|----------------|
| Min | | | | | | | | | | | | | | | | | | 20 | | | | _ | _ | | | | | | _ | | 1 | | , — | _ | |
| uexagon | ۰ ت | 24 26.8 | 30 33,5 | 30 33.5 | 30 33.5 | 36 40.5 | 36 40.5 | 36 40,5 | 36 40.5 | 36 40.5 | 45.8 51.2 | 45.8 51.2 | 45.8 51.2 | 45.8 51.2 | 45.8 51.2 | 55 61.5 | 55 61.5 | 55 61.5 | + | + | 0 00 | + | + | 77 07 | 80 88.5 | 88.5 | 80 88.5 | 38.5 | 80 88/5 | 8 | 06 | 8 | + | + | |
| H | E | M16 2 | 1/2 3 | M16 3 | 0ZW | 1/2" 3 | 3/4" 3 | M16 3 | 3 WZ0 | M25 3 | 1/2 45 | 3/4" 45 | 1" 45 | M25 45 | M32 45 | 3/4" 5 | 1. | 11/4" 5 | + | + | 7 7 | + | - | M50 7 | 11/4" 8 | 110. | (J | WEO S | N63 | 11/2" | 2" | 21/2" 9 | + | + | |
| - | | | _ | | ~ | - | 60 | | 2 | 2 | | 6 | | 2 | 2 | 6 | | _ | 2 | 2 | | + | | | = | | | $ \leq $ | 2 | = | | - | _ | 2 | - |
| ŀ | z á | WZO | | W25 | | | | M32 | | | | | WAO | | | | | 09W | | | | Z4W63 | | | / |) | M75 | | | | | W85 | | | |
| Port Nimber | Part Number | ABRE-M2016 | ABRE-M2512 | ABRE-M2516 | ABRE-M2520 | ABRE-M3212 | ABRE-M3234 | ABRE-M3216 | ABRE-M3220 | ABRE-M3225 | ABRE-M4012 | ABRE-M4034 | ABRE-M401 | ABRE-M4025 | ABRE-M4032 | ABRE-M5034 | ABRE-M501 | ABRE-M50114 | ABRE-M5032 | ABRE-M5040 | ABRE-M631 | ABRE-MESHIZ | ABRE-M6340 | ABRE-M6350 | ABRE-M75K14 | ABRE-M75112 | ABRE-M752 | ABRE-M7550 | ABRE-M7563 | ABRE-M85112 | ABRE-M852 | ABRE-M85212 | ABRE-M8563 | ABRE-M8575 | |
| | | П | | SSW SS | | Г | | M32 | | | | | W40 | | | | | 09W \ | 5 | | <u> </u> |) Sww |) | | | | M75 | | | | | W85 | | | |
| Entry Hole Size | Hole Size (metric) | WDO | | ~ | | | | | | | | | | | | (| | | | > | | | | | | | | | | | | | | | |
| | | | | | 8 | | | 2 93 | | | | 92 | | | | (45) | | | | > | 9 | 03 | | | 8 | 2 | 2 | | .23 | 2 | 9. | | 5- | | 2 |
| Thread | Size | MI6 | 8 1/2 | M16 | 1 | 1/2 | + | + | + | 0 3/4" | - | o wes | 28% | (5) 3/4" | | (5) | | 2/4 1990 11 12 12 13 13 13 13 13 | + | + | 1 7440 | + | 11/4" | + | F | 2 M63 | .5 11/2" | .5 2" | .5 21/2" | .5 M63 | .5 M75 | 6 2" | 6 2 15" | | \$ NV5 |
| Min Thread | Size | 15 M16 | 91 | 16 M16 | 92 | 8 8 | R 8 | 3 8 | 8 | 8 | 8 | 00 | 1/8/ | Js/bc | 378 | 20.5 | 20.5 Ng6 | 20.5 AM0 | 20 21 11/4 | 22 | 70 21 MAD | 21 | 88 8 | 8 8 | 32 | 35 | 105 33.5 11/2" | 105 33,5 2" | 105 33.5 21/2" | 105 33,5 M63 | 105 33.5 MØ5 | 139 36 2" | 139 36 2.M" | 139 36 3" | 139 36 M75 |
| Min Gland | C Integd | MI6 | 4 | 33.5 16 M16 | 33.5 16 | 8 8 | 80.5 | 40.5 | 51.2 | 8 | 1512 30 | 1 | 45.8 51.2 yel yes | \bigvee | | | 57.5 20.5 M9Z | 57.5 20.5 MM0 | 5 5 | 70 21 | 23 | 70 21 | + | 28.5 | - | | 33.5 | 33.5 | 33.5 | 33.5 | 33.5 | 36 | 98 | % | % |
| Hexagon Min Thread | P C Inredd | 26.8 15 M16 | 33.5 16 | 30 33.5 16 M16 | 30 33.5 16 | 86 88 | S 8 | 8 8 | 49.8 51.2 20 | \$1.2 20 | 1512 30 | 51.2 20 | 51.2/ 38/ | 15/2 20/5 | 57.5 20.8 | 57.5 20.5 | 52 57.5 20.5 M92 | 57.5 20.5 MM0 | 8 8 8 | 63 70 21 | 70 21 | 63 70 21 | 8.5 | 85.5 | 88.5 32 | 88.5 32 | 105 33.5 | 105 33,5 | 105 33.5 | 105 33.5 | 105 33.5 | 139 36 | 139 36 | 139 36 | 139 36 |
| Inread nexagon Min Gland | H P C Integd | 24 26.8 15 M16 | 30 33.5 16 | 30 33.5 16 M16 | 30 33.5 16 | 86 88 | 90 402 | 8 8 | 49.8 51.2 20 | A5.8 \$1.2 20 | 02/2/2/20 | 45,6 1812 120 | 45.8 51.2 30/ | 25 57.50 20/5/ | 52 57.5 20.8 | 52 57.5 20.5 | 52 57.5 20.5 N92 | 52 57.5 20.5 MM0 | 8 8 8 | 11/2" 63 70 21 | 63 70 21 | 63 70 21 | 8 3 3 3 3 3 3 | 85.5 | 80 88.5 32 | 80 88.5 32 | 95 105 33.5 | 95 105 33.5 | 95 105 33.5 | 95 105 33.5 | 95 105 33.5 | 128 139 36 | 128 139 36 | 128 139 36 | 128 139 36 |
| Inread nexagon Min Gland | (M) (F) H P C Size | 1/2" M16 24 26.8 15 M16 | 1/2" 30 33.5 16 | 3/4 M16 30 33.5 16 M16 | MZO 30 33.5 16 | 86 88 | SS 44 | 2 8 8 | 1/17 /43.8 51.2 20 | 3/4 15.8 51.2 20 | 11/4 1" 195/8 51/2 20 | 45,6 1812 120 | 45.8 51.2 30/ | 25 57.50 20/5/ | 52 57.5 20.8 | 11/2" 11/4" 52 57.5 20.5 | MS2 82 57.5 20.5 Mp2 | 00 MARO 522 57.5 20.5 MARO | 8 8 8 | 11/2" 63 70 21 | 2" 500 53 70 21 | M60 63 70 21 | 8 3 3 3 3 3 3 | 2" 80 88.5 32 | M50 80 88.5 32 | 80 88.5 32 | 95 105 33.5 | 95 105 33.5 | 95 105 33.5 | M63 95 105 33.5 | 95 105 33.5 | 128 139 36 | 2 5 128 139 36 | 3" 126 139 36 | M75 128 139 36 |

Application

ABSP

Industrial and Hazardous areas

Protection Degree

IP67 and IEC529

Certification

IZ GD EExd IIC / Exe II Zone1, Zone2, Zone21 and Zone22, Baseefa 09ATEX0189U IEC Ex: IECEx BAS 09.0091U


Material


Brass or Brass nickel plated or Stainless Steel




Lock-Nut and Sealing washer are available


NPT H Series








NPT RH Series




| Part Number | | | agon | Min |
|----------------|-----------|------|------------|------|
| Part Number | Size M | Н | _ <u>P</u> | С |
| ABSP H-N12 | 1/2" | 26 | 29 | 15.5 |
| ABSP H-N34 | 3/4 | 30 | 33.5 | 16 |
| ABSP H-N1 | 1" | 36 | 40.5 | 20 |
| ABSP H-N114 | 1 1/4" | 45.8 | 51.2 | 20 |
| ABSP H-N112 | 1 1/2" | 52 | 57.5 | 20.5 |
| ABSP H-N2 | 2" | 63 | 70 | 21 |
| ABSP H-N212 | 2 1/2" | 80 | 88.5 | 32 |
| ABSP H-N3 | 3" | 95 | 104.5 | 33.5 |
| ABSP H-N4 | 4" | 125 | 137 | 36 |


| Part Number | Thread Size M | Head Dimensions R | Min C | |
|-----------------|----------------------------|--------------------------------|----------|--|
| ABSP RH-N12 | 1/2" | 22.5 | 15.5 | |
| ABSP RH-N34 | 3/4" | 26.5 | 16 | |
| ABSP RH-N1 | 1" | 32 | 20 | |
| ABSP RH-N114 | 1 1/4" | 39.5 | 20 | |
| ABSP RH-N112 | 1 1/2" | 48 | 20.5 | |
| ABSP RH-N2 | 2" | 58 | 21 | |
| ABSP RH-N212 | 2 1/2" | 73 | 32 | |
| ABSP RH-N3 | 3" | 85 | 33.5 | |
| ABSP RH-N4 | 4" | 95 | 36 | |







| | 15 |
|-----|------------------|
| W. | |
| | "C" |
| (Mi | n Thread Length) |



| Part Number | Thread Size | | Min | |
|---------------|----------------|------|------|----|
| raitivumbei | M | Н | Р | С |
| ABSP H-M16 | M16x1.5 | 20 | 22 | |
| ABSP H-M20 | M20x1.5 | 24 | 26.8 | |
| ABSP H-M25 | M25x1.5 | 30 | 33.5 | |
| ABSP H-M32 | M32x1.5 | 35 | 40.5 | |
| ABSP H-M40 | M40x1.5 | 45.8 | 51.2 | 15 |
| ABSP H-M50 | M50x1.5 | 55 | 61.5 | |
| ABSP H-M63 | M63x1.5 | 70 | 77 | |
| ABSP H-M75 | M75x1.5 | 80 | 88.5 | |
| ABSP H-M85 | M85x1.5 | 90 | 99 | |

| | Part Number | Thread Size M | Head Dimensions R | Min C |
|----|----------------|---------------------|--------------------------------|----------|
| | ABSP RH-M16 | M16x1.5 | 22.5 | |
| | ABSP RH-M20 | M20x1.5 | 26.5 | |
| | ABSP RH-M25 | M25x1.5 | 32 | |
| , | ABSP RH-M32 | M32x1.5 | 39.5 | |
| / | ABSP RH-M40 | M40x1.5 | 48 | 15 |
| // | ABSP RH-M50 | M50x1.5 | 58 | |
|) | ABSP RH-M63 | M63x1.5 | 73 | |
| | ABSP RH-M75 | M75x1.5 | 85 | |
| | ABSP RH-M85 | M85x1.5 | 95 | |

Accessories

Earth Tag

Material: Brass/Brass nickel plated



| Part N | umber |
|-----------|-----------|
| Metric | NPT |
| ABET-M16 | ABET-N12 |
| ABET-M20 | ABET-N34 |
| ABET-M25 | ABET-N1 |
| ABET-M32 | ABET-N114 |
| ABET-M40 | ABET-N112 |
| ABET-M50 | ABET-N2 |
| ABET-M63 | ABET-N212 |
| ABET-M75 | ABET-N34 |
| ABET-M80 | ABET-N312 |
| ABET-M85 | ABET-N4 |
| ABET-M90 | |
| ABET-M100 | |

Serrated Washer

Material: Stainless Steel 316 or 316L




| Part N | umber |
|------------|------------|
| Metric | NPT |
| ABSSW-M16 | ABSSW-N12 |
| ABSSW-M20 | ABSSW-N34 |
| ABSSW-M25 | ABSSW-N1 |
| ABSSW-M32 | ABSSW-N114 |
| ABSSW-M40 | ABSSW-N112 |
| ABSSW-M50 | ABSSW-N2 |
| ABSSW-M63 | ABSSW-N212 |
| ABSSW-M75 | ABSSW-N34 |
| ABSSW-M80 | ABSSW-N312 |
| ABSSW-M85 | ABSSW-N4 |
| ABSSW-M90 | |
| ABSSW-M100 | |

Lock Nut


Material: Brass/Brass nickel plated

| Part N | umber |
|-----------|-----------|
| Metric | NPT |
| ABLN-M16 | ABLN-N12 |
| ABLN-M20 | ABLN-N34 |
| ABLN-M25 | ABLN-N1 |
| ABLN-M32 | ABLN-N114 |
| ABLN-M40 | ABLN-N112 |
| ABLN-M50 | ABLN-N2 |
| ABLN-M63 | ABLN-N212 |
| ABLN-M75 | ABLN-N34 |
| ABLN-M80 | ABLN-N312 |
| ABLN-M90 | ABLN-N4 |
| ABLN-M100 | |





| Part Number | | | | | |
|-------------|-----------|--|--|--|--|
| Metric | NPT | | | | |
| ABSW-M16 | ABSW-N12 | | | | |
| ABSW-M20 | ABSW-N34 | | | | |
| ABSW-M25 | ABSW-N1 | | | | |
| ABSW-M32 | ABSW-N114 | | | | |
| ABSW-M40 | ABSW-N112 | | | | |
| ABSW-M50 | ABSW-N2 | | | | |
| ABSW-M63 | ABSW-N212 | | | | |
| ABSW-M75 | ABSW-N34 | | | | |
| ABSW-M80 | ABSW-N312 | | | | |
| ABSW-M85 | ABSW-N4 | | | | |
| ABSW-M90 | | | | | |
| ABSW-M100 | | | | | |



PVC Shroud

| Part Number | | | | | |
|--|--|--|--|--|--|
| Туре А | Туре В | | | | |
| ABSD-A20a | ABSD-B16 | | | | |
| ABSD-A20d | ABSD-B20a | | | | |
| ABSD-A25 | ABSD-B20b | | | | |
| ABSD-A32 | ABSD-B25 | | | | |
| ABSD-A40 | ABSD-B32 | | | | |
| ABSD-A50 | ABSD-B40 | | | | |
| ABSD-A63 | ABSD-B50 | | | | |
| ABSD-A75 | ABSD-B63 | | | | |
| | ABSD-B75 | | | | |
| | ABSD-B80 | | | | |
| | ABSD-B90 | | | | |
| | · | | | | |
| ABSD-A25 ABSD-A32 ABSD-A40 ABSD-A50 ABSD-A63 | ABSD-B20b ABSD-B25 ABSD-B32 ABSD-B40 ABSD-B50 ABSD-B63 ABSD-B75 ABSD-B80 | | | | |



Appendix

Technical Information

Gland Clearances

Abtech Project List

Selecting the Correct Enclosure

It is vital that the enclosure selected is suitable for the required application. The enclosure should be mechanically robust enough to contain cables and cable glands which will be fitted and the IP rating of the enclosure should be adequate to deal with the environmental conditions likely to be encountered. The enclosure should also be large enough to accommodate the terminals or components fitted and it should be considered at this stage whether or not future expansion will be necessary and to allow room for this. The ABTECH Enclosure Calculator Software can be used to select the correct enclosure by quickly calculating if the required terminals will fit.



Cable entry points must also be considered i.e. how many and where are they to be placed. If all the cable entry points are to be on the bottom face, for instance, this may necessitate a larger enclosure than would be necessary just to accommodate the terminals.

Terminals

Any type or make can be fitted inside ABTECH enclosures except in the case of enclosures intended for use in hazardous areas. The terminal should be matched to the type and size of cable being used and attention should be paid to the current (and voltage ratings of both the terminal and cable. Any manufacturer's instructions in relation to the fitment and necessary clearance required around the terminal should be strictly adhered to. Modular terminals can be fitted to DIN standard terminal rails and these can be fitted directly to the inside of the enclosure using the fixing points which are a standard feature of ABTECH enclosures or by mounting onto a component mounting plate which is available as an option for all enclosure types and sizes.

Cable Glands

Cable glands should be selected according to the cable type, screen or armour earthing requirements and the IP rating required.

Using the ABTECH Enclosure Calculator Software will quickly let you see whether your chosen enclosure can accommodate the required number of cable glands and provide a drawing automatically. Designers_should always allow enough clearance around multiple gland entries to allow for fixing nuts etc. Please refer to the drawing at the end of this section which shows ABTECH's suggested clearance dimensions for common entry sizes Cable glands are a specialised field and the cable aland manufacturers should be contacted technical information and help regarding the correct selection of these items.

ABTECH can supply and fit cable glands if required or we can machine the enclosure or gland plates for fitting on site. We can provide a number of different thread forms e.g. metric, NPT, PG etc. or clearance holes.

Hazardous Areas


ABTECH specialises in the design and production of junction boxes and enclosures for use in potentially hazardous areas. The SX, BPG and ZAG enclosure ranges are all certified for use in Zone 1 and Zone 2 hazardous areas. We also specialise in high voltage junction boxes for up to 11kV in Zone 1 and 35kV in Zone 2 areas. The following gives a brief guide to the protection methods used for electrical equipment in hazardous areas.

Definition

A Hazardous Area is defined as "An Area containing a potentially explosive atmosphere, which, if ignited, could give rise to damage of property or injury to persons". Hazardous areas can be found in almost every industry and even in daily life, the best example being a petrol station or a gas station.

Protection

How do we protect hazardous areas? i.e., how do we stop a potentially explosive atmosphere from igniting and destroying the installation? In order to prevent an explosion we must first understand the conditions required to cause an explosion. There are three conditions which must co-exist in order to create an explosion, fuel, air and an ignition source. This is normally known as the Ignition Triangle.



With this knowledge, it is possible to protect the equipment from one of the three elements required to cause an explosion i.e. in the case of increased safety (EEx'e') the ignition source is removed by ensuring that there are no hot surfaces or sparking components which could ignite a fuel and oxygen mixture which may enter the enclosure.

Zone Classification

Codes of practice exist for the classification of areas according to the probability or likelihood of the existence of a flammable atmosphere. This is known as Area Classification and in accordance with EN 60079-14 is typically as follows:-

Zone 0

Where a Flammable Atmosphere is continuously present or present for long periods. Permitted forms of protection: Ex 'ia', Ex 's' (for Zone 0)

Zone 1

Where a Flammable Atmosphere is likely to occur during normal operation. Permitted forms of protection; any type of protection suitable for Zone 0 and Ex 'd', Ex 'ib', Ex 'p', Ex 'e', Ex 's', Ex 'm', Ex 'q'.

Zone 2

Where a Flammable Atmosphere is not likely to occur during normal operation and if it does will only exist for a short period of time. Typically less than 10 hours per year and is often referred to as the "Remotely Hazardous Area"

Permitted forms of protection: Any type of protection suitable for Zone 0 and 1 and Ex 'nA', Ex 'nR', Ex 'o'

Zone 20

A place in which an explosive atmosphere, in the form of a cloud of combustible dust in air, is present continuously, or for long periods or frequently for short periods.

Zone 21

A place in which an explosive atmosphere, in the form of a cloud of combustible dust in air, is likely to occur occasionally in normal operation.

Zone 22

A place in which an explosive atmosphere, in the form of a cloud of combustible dust in air, is not likely to occur in normal operation but, if it does occur, will persist for a short period only.

For all dust hazard areas (the permitted forms of protection include: mD (encapsulation), iaD (intrinsically safe), pD (purged), tD (protection by enclosure). Where protection type tD is selected a plastics enclosure should only be used if the material has anti-static properties.

Types of Protection

Intrinsically Safe - Ex 'ia' (EN 50020)

This type of protection is afforded by the electrical circuit or components having insufficient energy to ignite a flammable atmosphere. Ex 'ia' equipment is safe under two fault conditions and permissible for use in Zone 0 areas. Intrinsically safe components or circuitry is normally housed in an enclosure having Ex 'e' protection although this is not always necessary. In this case it is important that the integrity of the enclosure is adequate for the area of use.

Intrinsically Safe - Ex 'ib' (EN 50020)

As above, except Ex 'ib' equipment is safe under one fault condition permissible in Zone 1 areas.

Flameproof - Ex 'd' (EN 50018)

Equipment may include arching and sparking (or incendive) devices and flammable mixtures may enter the enclosure. The enclosure construction is designed to contain an internal explosion and prevent transmission of sufficient energy to ignite a potentially flammable atmosphere outside the enclosure.

Increased Safety Ex 'e' (EN 50019)

Explosive mixtures may enter the equipment but the likelihood of a fault condition, which could result in ignition of this mixture, is significantly reduced. The components used in the apparatus shall not produce arcs or sparks or temperatures above that of ignition temperature of the surrounding atmosphere in normal working conditions. Creepage and clearance distances for electrical insulation are increased over that of industrial equipment and insulation material must be reliable over long periods of time. A minimum ingress protection of IP54 must be provided by any enclosure containing increased safety equipment and it must also be capable of withstanding a 7Nm impact.

Pressurised - Ex 'p' (EN 50016)

Pressurised or purged apparatus Type 'p' rely on a combination of a positive static pressure applied inside the enclosure and a continuous flow of air or inert gas to expel any explosive mixture which may have entered. A monitoring system is an important part of the apparatus to ensure correct operation.

Encapsulation - Ex 'm' (EN 50028)

Encapsulation of arching and sparking components or apparatus to ensure no exposure to explosive mixtures which may be present. The surface temperature is also controlled under normal and fault conditions, thus preventing ignition from occurring.

Powder Filled - Ex 'q' (EN 50017)

Powder or sand filled enclosures housing arching, and sparking devices. Often used to contain the energy released from the failure of electrical or electronic components such as the breaking of a fuse.

Non Sparking - Ex 'nA' (EN 50021)

This protection method is very similar to that of Ex 'e' and although to a higher level than industrial standards, it is less than that of Ex 'e'. Can only be used in Zone 2 areas but allows the use of fuses, disconnect terminals and other components not allowed in Ex 'e'.

Restricted Breathing - Ex 'nR' (EN 50021)

In this concept, protection is afforded by the sealing properties of the enclosure in which either not or sparking equipment may be fitted. It is assumed that the likelihood of a flammable atmosphere being present whilst the enclosure is breathing is yery remote and the sealing of the enclosure should be sufficient to protect against this.

Oil Immersion - Ex 'O' (EN 50015)

Where the sparking components are immersed in oil and controlled venting is also used. Most commonly found in older type switchgear.

Special - Ex 's'

No formal standard exists for this type of protection and it is the responsibility of the manufacturer and the relevant test authority to ensure that the apparatus is safe to use in the intended zone



Temperature Classification & Gas Groupings

Flammable mixtures can be classified under two main characteristics in respect of explosion protection; temperature of ignition by hot surfaces and the spark energy required to ignite the mixture. The spark energy of the ignition is also related to the intensity of the explosion.

Classification of maximum surface temperatures in both North America and Europe are similar but vary slightly in the nomenclature used. The temperature classification is important to ensure that the correct equipment is matched to the flammable atmospheres that could potentially exist in an area. This will take into account such things as maximum ambient temperature and maximum operating voltage with a + 10% over voltage or an overload condition applied.

In some types of protection such as Ex 'd' or Ex 'nR' the temperature classification is based on the outside temperature of the enclosure where as in other types of protection such as Ex 'e' or Ex 'nA' the temperature classification is based on the temperature of the internal components.

It follows that equipment with a higher temperature rating and, therefore, lower operating temperature is suitable for use in a wider range of hazardous areas.

Equipment rated T6 is suitable for use with all gases and vapourised mists

All Gases are grouped according to their physical properties and details of their grouping can be found in either National or International codes of practice. Some examples of gas groups are shown on the next page.

Temperature Classification Table

| Maximum Surface Temperature | US (NEC 505) IEC CENELEC | US (NEC 500) |
|-----------------------------------|--------------------------------|-----------------|
| 450°C (842°F) | T1 | T1 |
| 300°C (572°F) | T2 | T2 |
| 280°C (536°F) | | T2A |
| 260°C (500°F) | | T2B |
| 230°C (446°F) | | T2C (|
| 215°C (419°F) | | T2D |
| 200°C (392°F) | Т3 | T3 |
| 180°C ((356°F) | | ТЗА 🤇 |
| 165°C (329°F) | | ТЗВ |
| 160°C (320°F) | | 136 |
| 135°C (275°F) | T4 | T4 |
| 120°C (248°F) | | T4A |
| 100°C (212°F) | T5 | T5 |
| 85°C (185°F) | Т6 | T6 |

Unless otherwise specified on the rating plate it is assumed that the operating ambient temperature is in the range -20°C to + 40°C (-4°F to 104°F) in accordance with European Standards.

Gas Grouping For Electrical Apparatus (EN 50014)

| | _ /> |
|----------|--|
| Group | Gas |
| (Mining) | Methane (firedamp) |
| HA | Industrial methane, Propane, Petrol & most industrial gases. |
| В | Ethylene, Town Gas & other industrial gases |
| II С | Hydrogen, Acetylene & Carbon Di-sulphide. |

Ambient Temperature

The ambient temperature is the surrounding temperature of the environment in which the equipment is installed, whether indoors or outdoors.

For electrical equipment certified in Europe it is assumed that the ambient temperature in which the equipment may be operated is between -20°C and + 40°C (-4°F to 104°F). Some types of equipment are certified for operation outside this range and if so must be stated on the equipment label or certificate.

North American Standards

In North America all, electrical installations are governed by the National Electric Code (NEC).

Electrical equipment used in ordinary, wet and hazardous (or classified) locations must be 'listed' by an accredited approval agency for use in the intended location. The hazardous locations include areas in which flammable, combustible or ignitable substances may occur in hazardous quantities. Article 501 Codes of the NEC use a different way of categorising the hazardous locations, which is by Class and Division, compared with the European and IEC standards, which have adopted the Zonal method. Electrical apparatus approved in North America for use in hazardous locations must be categorised with an Equipment Class and suitable for a specified Division and Gas Group.

Classifications are made in line with the type of combustible material as follows;

Class I – Flammable gases, vapours or mists

Class II - Combustible dusts

Class III - Ignitable fibres and flyings


In 1996 article 505 was introduced to the NEC which allowed Zonal classification of hazardous areas. This now means that products can be approved as follows:

Fither.

Class, Division & Gas Group For example: Class 1, Division 2, A,B,C,D

or

Class, Zone & Gas Group For example: Class 1, Zone 2, IIA, IIB, IIC. Although this code change permits the use of products that have a Zonal classification, in a similar way to European practice, the mixing of different forms of equipment approval across zones or divisions is not acceptable. For example products approved for Zone 1 do not necessarily meet the requirements of Division 1, which also encompasses Zone 0.



Although no direct equivalents exist between European/IEC and American codes ∧ of protection and Area Classification there are similarities and there is а devélopina acceptance of European/IEC methods in North America and vice versa. The following (table) shows the basic relationships between the North American and European Classifications

Equivalent Division/Zone

| NEC | European / IEC |
|------------|----------------|
| Division 1 | Zone 0 |
| DIVISION 1 | Zone 1 |
| Division 2 | Zone 2 |

As can be seen from the above table, Division 1 covers both the European / IEC Zones 0 & 1. Therefore, care must be taken when using zone classified equipment in a Division 1 area to ensure the suitability of the protection employed.

Underwriters Laboratory (UL) and Factory Mutual (FM) are the two main certification bodies in North America and in some cases electrical equipment may also need to meet certain Marine Standards and be separately approved by the US Coast Guards, before it can be used e.g. on an offshore oil rig.

Ingress Protection

A major secondary protection parameter is the ingress protection of the electrical equipment. Moisture or dust, if allowed to come into contact with electrical circuits, could led to either sparking or physical breakdown of the components and interfere with the protection method being used. In some cases the IP rating forms part of the explosion protection method. All IP ratings for products in this catalogue have been carried out in accordance with EN 60529 (IEC 529) and have been witness tested by independent test laboratories.

IP Requirements to EN 60529(IEC 529)

| | _ | Degree of Protection (Dust) | | Degree of Protection (Water) |
|-----|---|---|---|--|
| | 0 | No Protection | 0 | No protection |
| 7/2 | | Protection against ingress of large solid particles | 1 | Protection against ingress of vertically dripping water |
| > | 2 | Protection against ingress of medium solid particles | 2 | Protection against ingress of water dripping at an angle of 75 - 90 degrees |
| | 3 | Protection against ingress of solid particles greater in thickness than 2.5mm | 3 | Protection against ingress of sprayed water |
| | 4 | Protection against ingress of small foreign bodies greater in thickness than 1mm | 4 | Protection against ingress of splashed water |
| | 5 | Protection against ingress of dust in an amount sufficient to interfere with enclosed equipment | 5 | Protection against ingress of water jets |
| | 6 | Complete protection against ingress of dust | 6 | Protection against ingress of water in heavy seas |
| | | | 7 | Protection against effects temporary immersion |
| | | | 8 | Protection against effects of indefinite immersion |

It will be noted that some products have both IP66 and IP67 ratings. This is because in some instances the IP66 requirement is more onerous than the IP 67 equivalent.

Both the SX range and BPG ranges have also been tested to the Shell/ERA deluge specification. This is one of the most onerous water ingress tests and was designed specifically for electrical equipment which would be subject to deluge conditions, e.g. ships decks and fire deluge areas.

ATEX Directive

The ATEX directive (94/9/EC) came into force in April 1994 and was enacted into UK law in March 1996. It became a mandatory requirement in July 2003. All of the products in this catalogue have an EC type examination certificate to the ATEX directive. ATEX covers both electrical and mechanical ignition hazards.

Apparatus are divided into Equipment groups (I for mining and II non-mining), source of ignition Gas (G) and Dust (D) and Categories 1, 2 and 3. The Categories provide respectively, very high, high and normal levels of protection against ignition. The Categories deliver the level of protection which is currently obtained by applying the existing protection techniques (Ex 'd', Ex 'e' etc) and they also take into account other protection concepts proposed by manufacturers and considered by the notified (certification) bodies who produce EC type examination (ATEX) certificates.

The Categories in practice are equated to suitability for Zones. The actual category of apparatus specified for a Zone depends on the overall risk assessment for a Zone. The Zoning considers only the probability of the existence of an explosive atmosphere. It does not consider the consequential effects of an ignition taking place. Apparatus are marked with the grouping and Category in addition to the marking required by the individual protection standards.

All ABTECH products are certified for use in Group II industrial applications, most are certified for both Gas (G) and Dust (D) hazards and are suitable for classification in Categories 2 and 3. This means that they are or will generally be suitable for use in Zone 1 and Zone 2 areas. Guidance is given by the codes of practice such as EN 60079-10 and EN 60079-14 etc. These codes of practice provide the user with guidance in selecting apparatus to obtain the degree of safety that is required for the particular hazardous area application.

An EC type examination by a notified body is required for Category 1 and 2 equipment but not for Category 3 where the certification is supplied by the manufacturer.

Junction Boxes in Hazardous Areas

Junction boxes and terminal enclosures for use in hazardous areas mainly contain from incendive devices i.e. terminals. For Ex e' certified apparatus there are two main critéria when specifying the apparatus.

- Are the components acceptable for use in the enclosure i.e. non sparking, and
- Will any components or wiring be hotter than the temperature classification of the apparatus allows.

To comply with the first requirement, only terminals of other components which are specifically allowed for in the certificate of compliance, and post July 2003 only ATEX certified components may be fitted (apparatus constructed prior to July 2003 need not meet this requirement).

To ensure compliance with the second criteria for safe use, all low voltage ABTECH enclosures are certified using the dissipated power method.

Through testing it has been determined what the maximum power dissipation can be from the components and wiring inside each enclosure size to ensure that the temperature of any of the components does not exceed the temperature classification of the apparatus.

This figure is shown for each of the products throughout the catalogue and can be found on each of the product certificates.

By knowing the total current through the enclosure and the total resistance of the terminals and wiring, using Ohms Law it is possible to calculate the dissipation power of the circuit.

Power Dissipation;

P (Watts) = I^2 (Amps) x R (Ohms)

Where I is the total current through the enclosure, and R is the total resistance of the terminals and conductor contained within the enclosure.

Where I is the total current through the enclosure, and R is the total resistance of the terminals and conductor contained within the enclosure.

The resistance of the terminals can be sought from the terminal manufacturers and the resistance of the conductors is available in reference books or from the cable manufacturers.

Alternatively, the ABTECH Enclosure Calculator software will calculate this automatically for a given combination of enclosure and terminals.

For high current applications the terminal resistance can vary depending on the cable size, cable quantity, crimping method for cable lugs and the actual current flow. Correct installation is essential in order to limit the overall temperature rise and the maximum operating temperature of the terminals.

In all Ex certified enclosures it is important that an earth facility is provided. In plastic enclosures this may be by means of an internal/external earth stud or by an earth terminal fitted inside. Additional earthing for cable glands can be provided by an earth continuity plate fitted inside the enclosure wall.

Plastic enclosures carry a risk of static discharge which could lead to a spark being produced if rubbed with a dry cloth. Plastic enclosures should only ever be cleaned using a damp cloth. Optionally, plastic enclosures with a graphite filling are available which reduces this risk.

For metallic enclosures the earth facility must earth the enclosure body and can be provided by earth terminals connected to the body through the terminal mounting rail and/or by means of an internal/external earth stud.

Cable Glands for use in Hazardous Areas


Cable glands used in enclosures intended for use in a hazardous area must meet with the same criteria as the enclosure to which they are connected. For example, cable glands used on an EEx'e' enclosure must meet the requirements for the enclosures of the EEx'e' standard i.e. must be capable of withstanding a 7Nm impact and capable of maintaining an ingress protection of at least P54.

If a plastic of non-metallic cable gland is used it must be capable of passing these tests after having undergone an accelerated conditioning period. Most reputable cable gland manufacturers have their products approved by a suitably notified body and will carry the certification markings on the body of the gland.

Cable glands are a very important element in the protection of electrical equipment and should not be underestimated. There are a vast array of different cables in use today and it is important that advice is sought from a cable gland manufacturer regarding selection.







Abtech Major Project List

Agbami Discovery Well, Niger Delta, Nigeria Alba Phase II, North Sea Northern, United Kingdom Alvheim North Sea Northern, Norway Azeri-Chirag-Gunashii (ACG) Oil Field, Caspian Sea, Azerbaijan

Balder, North Sea Northern, Norway
Banff, North Sea Central, United Kingdom
Barracuda and Caratinga Fields, Campos Basin, Brazil
Bijupira and Salema Fields, Campos Basin, Brazil
Bonga Deepwater Project, Niger Delta, Nigeria
Britannia, North Sea Central, United Kingdom
Bruce, North Sea, United Kingdom
Bunga Orchid-A, Malaysia
Buzzard Field North Sea Central, United Kingdom

Caister Murdoch Phase 3, North Sea Southern, United Kingdom
Captain, North Sea Central, United Kingdom
Chermingat-A, Malaysia
Chinguetti Oil Field, Mauritania
Clair Field, Shetlands, United Kingdom
Corrib Gas Field, Republic of Ireland
Curlew, North Sea Central, United Kingdom

Dalia Field Development of Block 17, Angola Dunbar Phase II, North Sea Central, United Kingdom

E11PB, Sarawak

Easington Catchment Area (ECA), North Sea Southern, United Kingdom East Belumut, Malaysia
Eastern Trough Area Project (ETAP), North Sea Central, United Kingdom Ekofisk II, North Sea Central, Norway
Elgin Franklin, North Sea Central, United Kingdom Erskine, North Sea Central, United Kingdom Espadarte, Campos Basin, Brazil

F23VLAP, Sarawak Foinaven Oil Field, United Kingdom

Gannet, North Sea Central, United Kingdom Girassol, Luanda, Angola Goldeneye Gas Platform, North Sea Northern, United Kingdom Greater Plutonio, Block 18, Depwäter Drillship Pride, Angola Gullfaks, North Sea Northern, Norway

Hanze F2A, Dutch North Sea, Netherlands Hibernia, Jeanne d'Arc Basin, Canada

Jade Oil and Gas Platform, North Sea Central, United Kingdom Janice, North Sea Central, United Kingdom Jotun, North Sea Northern, Norway

K5F Gas Field, Netherlands Kashagan, Cappian Sea, Kazakhstan kilkeh, Malaysia Kizomba Deepwater Project, Angola Kristin Deepwater Project, Norweglan Sea, Norway

Leadon, North Sea Northern, United Kingdom Liverpool Bay Oil and Gas Fields, United Kingdom Lukoil's Kravtsovskoye (D-6) Oil Field Ice-Resistant Stationary Platform, Russia

Abtech Major Project List cont.

MacCulloch, North Sea Central, United Kingdom Mad Dog Drilling Unit Field Gulf of Mexico, USA Magnolia Field, Gulf of Mexico, USA Magnus EOR, Shetlands, United Kingdom Marco Polo Field Gulf of Mexico, USA Marlim Oil Field, Campos Basin, Brazil Marlim Sul, Campos Basin, Brazil Mars, Gulf of Mexico, USA Matterhorn Field. Gulf of Mexico, USA

Okume Complex, Equatorial Guinea Oseberg Sør, North Sea Northern, Norway

Pierce, North Sea Central, United Kingdom Prirazlomnoye Oilfield - Barents Sea, Russia Puteri, Malaysia

R Block Development, North Sea Central, United Kingdom Rivers Fields, East Irish Sea, United Kingdom Roncador, Campos Basin, Brazil Ross, North Sea Central, United Kingdom Ruby FPSO, Malaysia

Sable Offshore Energy Project, Sable Island, Canada Sakhalin II, Sea of Okhotsk, Russia Sanha / Bomboco, LPG FPSO Floating Production Facility, Angola Scarab and Saffron Gas Fields, Eastern Mediterranean Egypt Schiehallion Oil Field, United Kingdom Serampang-A, Malaysia Shah Deniz South Caspian Sea, Azerbaijan Shearwater, North Sea Central, United Kingdom Siri, North Sea Northern, Denmark Snøhvit Gas Field, Barents Sea, Norway Snorre, North Sea Central, Norway South Arne, Danish North Sea, Denmark South Pars, Qatar North Field, Iran St. Joseph, Sarawak Sumandak Selatan, Malaysia

Terra Nova, Jeanne d'Arc Basin, Canada Thunder Horse Field, Gulf of Mexico, USA Triton, North Sea Central, United Kingdom Troika, Gulf of Mexico, USA Troll West, North Sea Northern, Norway Typhoon, Gulf of Mexico, USA


Ursa, Gulf of Mexico, USA

Valhall Flank Water Injection Platform, Norwegian North Sea, Norway Viking B, North Sea Southern, United Kingdom

West Patrica, Malaysia White Rose Oil and Gas Field, Jeanne d'Arc Basin, Canada

Xikomba Oil Field Deepwater Development, Angola

Yoho Oil Field, Nigeria





| AAG-100 212 ABAD-N134 214 AAG-2016 212 ABAD-N1434 214 AAG-20a 212 ABAD-N2112 214 AAG-20b 212 ABAD-N21114 214 AAG-20c 212 ABAD-N212112 214 AAG-20d 212 ABAD-N21212 214 AAG-25a 212 ABAD-N3212 214 AAG-32 212 ABAD-N3212 214 AAG-32 212 ABAD-N321 214 AAG-63 212 ABAD-N321 214 AAG-63 212 ABAD-N3212 214 AAG-80 212 ABAD-N4212 214 AAG-90 212 ABAD-N43 214 ABAD-M2516 214 ABET-M30 219 ABAD-M3216 214 ABET-M32 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M50 219 ABAD-M3032 214 ABET-M50 219 ABAD-M3032 214 ABET-M50 219 ABAD-M5035 214 ABET-M50 219 ABAD-M5035 214 ABET-M90 219 ABAD-M5035 214 ABET-M90 219 ABAD-M5032 214 ABET-M12 219 ABAD-M6340 214 ABET-N11 219 ABAD-M6340 214 ABET-N11 219 ABAD-M6350 214 ABET-N11 219 ABAD-M6350 214 ABET-N11 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N31 219 ABAD-M6550 214 ABET-N31 219 ABAD-M5563 214 ABET-N34 219 | Α | | ABAD-N12114 | 214 |
|--|---------------|----------|----------------|-----|
| AAG-20a 212 ABAD-N2112 214 AAG-20b 212 ABAD-N2114 214 AAG-20c 212 ABAD-N212112 214 AAG-20d 212 ABAD-N21212 214 AAG-25a 212 ABAD-N3112 214 AAG-32 212 ABAD-N321 214 AAG-30 212 ABAD-N321 214 AAG-50 212 ABAD-N321 214 AAG-63 212 ABAD-N3412 214 AAG-63 212 ABAD-N3412 214 AAG-63 212 ABAD-N3412 214 AAG-75 212 ABAD-N3412 214 AAG-90 212 ABAD-N3210 214 AAG-90 212 ABET-M100 219 ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M60 219 ABAD-M3220 214 ABET-M60 219 ABAD-M3225 214 ABET-M60 219 ABAD-M3200 214 ABET-M85 219 ABAD-M3200 214 ABET-M10 219 ABAD-M3200 214 ABET-N11 219 ABAD-M3032 214 ABET-N11 219 ABAD-M3032 214 ABET-N11 219 ABAD-M60340 214 ABET-N12 219 ABAD-M60350 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M7560 214 ABET-N12 219 ABAD-M7560 214 ABET-N12 219 ABAD-M7560 214 ABET-N12 219 ABAD-M7560 214 ABET-N14 219 ABAD-M7560 214 ABET-N34 219 ABAD-M8560 214 ABET-N34 219 ABAD-M8560 214 ABET-N34 219 ABAD-M8560 214 ABET-N34 219 ABAD-M8560 214 ABET-N34 219 | AAG-100 | 212 | ABAD-N134 | 214 |
| AAG-20b 212 ABAD-N2114 214 AAG-20c 212 ABAD-N212112 214 AAG-20d 212 ABAD-N2122 214 AAG-25a 212 ABAD-N3112 214 AAG-32 212 ABAD-N32 214 AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3212 214 AAG-63 212 ABAD-N3212 214 AAG-63 212 ABAD-N3212 214 AAG-63 212 ABAD-N3212 214 AAG-75 212 ABAD-N4212 214 AAG-80 212 ABAD-N4212 214 AAG-90 212 ABAD-N43 214 ABAD-M2016 214 ABET-M10 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3216 214 ABET-M50 219 ABAD-M3220 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M63 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5025 214 ABET-M80 219 ABAD-M5025 214 ABET-M80 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N2 219 ABAD-M5050 214 ABET-N2 219 ABAD-M5063 214 ABET-N2 219 ABAD-M5063 214 ABET-N31 219 ABAD-M5063 214 ABET-N34 219 ABAD-M5075 214 ABET-N34 219 | AAG-2016 | 212 | ABAD-N1434 | 214 |
| AAG-20C 212 ABAD-N212112 214 AAG-20d 212 ABAD-N2122 214 AAG-25a 212 ABAD-N3112 214 AAG-32 212 ABAD-N32 214 AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3212 214 AAG-63 212 ABAD-N3212 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N4212 214 AAG-80 212 ABAD-N43 214 AAG-90 212 ABAD-N43 214 ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3220 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M63 219 ABAD-M4025 214 ABET-M85 219 ABAD-M5025 214 ABET-M85 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6360 214 ABET-N1 219 ABAD-M6360 214 ABET-N1 219 ABAD-M6360 214 ABET-N1 219 ABAD-M6360 214 ABET-N2 219 ABAD-M6360 214 ABET-N2 219 ABAD-M6563 214 ABET-N31 219 ABAD-M7560 214 ABET-N31 219 ABAD-M8575 214 ABET-N34 219 | AAG-20a | 212 | ABAD-N2112 | 214 |
| AAG-20d 212 ABAD-N2122 214 AAG-25a 212 ABAD-N3112 214 AAG-32 212 ABAD-N32 214 AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3412 214 AAG-63 212 ABAD-N3412 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N43 214 AAG-80 212 ABEF-M100 219 AAG-90 212 ABEF-M16 219 ABAD-M2016 214 ABEF-M25 219 ABAD-M2516 214 ABEF-M25 219 ABAD-M3216 214 ABEF-M32 219 ABAD-M3216 214 ABEF-M32 219 ABAD-M3220 214 ABEF-M63 219 ABAD-M4020 214 ABEF-M63 219 ABAD-M4020 214 ABEF-M63 219 ABAD-M4020 214 ABEF-M63 219 ABAD-M4020 214 ABEF-M63 219 ABAD-M4025 214 ABEF-M85 219 ABAD-M5032 214 ABEF-M85 219 ABAD-M5032 214 ABEF-M85 219 ABAD-M5032 214 ABEF-M90 219 ABAD-M5032 214 ABEF-N11 219 ABAD-M5034 214 ABEF-N11 219 ABAD-M5040 214 ABEF-N11 219 ABAD-M5040 214 ABEF-N11 219 ABAD-M5040 214 ABEF-N11 219 ABAD-M6340 214 ABEF-N11 219 ABAD-M5050 214 ABEF-N1 219 | AAG-20b | 212 | ABAD-N2114 | 214 |
| AAG-25a 212 ABAD-N3112 214 AAG-32 212 ABAD-N32 214 AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3412 214 AAG-63 212 ABAD-N3412 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N43 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M10 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3216 214 ABET-M32 219 ABAD-M3216 214 ABET-M50 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3220 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4020 214 ABET-M80 219 ABAD-M4020 214 ABET-M80 219 ABAD-M4032 214 ABET-M80 219 ABAD-M5032 214 ABET-M80 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-M1 219 ABAD-M5034 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6330 214 ABET-N1 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M5563 214 ABET-N2 219 ABAD-M5563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8555 214 ABET-N34 219 ABAD-M8555 214 ABET-N34 219 ABAD-M8555 214 ABET-N34 219 ABAD-M85563 214 ABET-N34 219 ABAD-M85563 214 ABET-N34 219 ABAD-M85575 214 ABET-N34 219 | AAG-20c | 212 | ABAD-N212112 | 214 |
| AAG-32 212 ABAD-N32 214 AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3412 214 AAG-63 212 ABAD-N4212 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N42 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3216 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M50 219 ABAD-M4020 214 ABET-M50 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5032 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-M1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6330 214 ABET-N1 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7563 214 ABET-N31 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N46 219 | AAG-20d | 212 | ABAD-N2122 | 214 |
| AAG-40 212 ABAD-N3212 214 AAG-50 212 ABAD-N3412 214 AAG-63 212 ABAD-N4212 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N43 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3220 214 ABET-M63 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 274 ABET-M80 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M80 219 ABAD-M5035 214 ABET-M90 219 ABAD-M5035 214 ABET-N1 219 ABAD-M5035 214 ABET-N1 219 ABAD-M6336 214 ABET-N1 219 ABAD-M6350 214 ABET-N2 219 ABAD-M5630 214 ABET-N3 219 | AAG-25a | 212 | ABAD-N3112 () | 214 |
| AAG-50 212 ABAD-N3412 214 AAG-63 212 ABAD-N4212 214 AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N43 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3216 214 ABET-M32 219 ABAD-M3220 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M50 219 ABAD-M4020 214 ABET-M50 219 ABAD-M4020 214 ABET-M50 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5025 214 ABET-M80 219 ABAD-M5025 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M7563 214 ABET-N1 219 ABAD-M7563 214 ABET-N1 219 ABAD-M5640 214 ABET-N1 219 ABAD-M5650 214 ABET-N34 219 | AAG-32 | 212 | ABAD-N32 | 214 |
| AAG-63 212 ABAD-N4212 214 AAG-75 212 ABAD-N43 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M20 219 ABAD-M2516 214 ABET-M25 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4020 214 ABET-M80 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5032 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5030 214 ABET-N1 219 ABAD-M6340 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M6350 214 ABET-N1 219 ABAD-M5040 214 ABET-N12 219 ABAD-M5050 214 ABET-N312 219 ABAD-M5050 214 ABET-N34 219 | AAG-40 | 212 | ABAD-N3212 | 214 |
| AAG-75 212 ABAD-N43 214 AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M20 219 ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M50 219 ABAD-M4020 214 ABET-M50 219 ABAD-M4025 214 ABET-M50 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5025 214 ABET-M85 219 ABAD-M5032 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M7560 214 ABET-N12 219 ABAD-M7560 214 ABET-N12 219 ABAD-M7560 214 ABET-N31 219 ABAD-M7560 214 ABET-N31 219 ABAD-M7560 214 ABET-N31 219 ABAD-M8560 214 ABET-N34 219 ABAD-M8560 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 | AAG-50 | 212 | ABAD-N3412 🔷 | 214 |
| AAG-80 212 ABET-M100 219 AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 274 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M50 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5035 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6340 214 ABET-N11 219 ABAD-M6350 214 ABET-N1 219 ABAD-M7560 214 ABET-N1 219 ABAD-M7560 214 ABET-N2 219 ABAD-M7560 214 ABET-N31 219 ABAD-M7560 214 ABET-N31 219 ABAD-M7563 214 ABET-N31 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 | AAG-63 | 212 | ABAD-N4212 | 214 |
| AAG-90 212 ABET-M16 219 ABAD-M2016 214 ABET-M20 219 ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 214 ABET-M32 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5032 214 ABET-M85 219 ABAD-M5032 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N12 219 ABAD-M6330 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M7563 214 ABET-N2 219 ABAD-M7563 214 ABET-N31 219 ABAD-M7563 214 ABET-N31 219 ABAD-M7563 214 ABET-N31 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 | AAG-75 | 212 | ABAD-N43 | 214 |
| ABAD-M2016 214 ABET-M25 219 ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M63 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M50025 214 ABET-M90 219 ABAD-M50032 214 ABET-N1 219 ABAD-M5040 214 ABET-N1 219 ABAD-M6332 214 ABET-N11 219 ABAD-M6340 214 ABET-N11 219 ABAD-M6350 214 ABET-N12 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N2 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8565 214 ABET-N34 219 ABAD-M8565 214 ABET-N34 219 ABAD-M8565 214 ABET-N34 219 ABAD-M8565 214 ABET-N34 219 | AAG-80 | 212 | ABET-M100 | 219 |
| ABAD-M2516 214 ABET-M25 219 ABAD-M2520 214 ABET-M32 219 ABAD-M3216 214 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M80 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N12 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N12 219 ABAD-M7563 214 ABET-N2 219 ABAD-M7563 214 ABET-N31 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N40 219 | AAG-90 | 212 | ABET-M16 | 219 |
| ABAD-M2520 214 ABET-M32 219 ABAD-M3216 234 ABET-M40 219 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M75 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6332 214 ABET-N1 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N21 219 ABAD-M7563 214 ABET-N31 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8575 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 | ABAD-M2016 | 214 | ABET-M20 | 219 |
| ABAD-M3216 ABAD-M3220 214 ABET-M50 219 ABAD-M3225 ABAD-M4020 ABAD-M4020 ABAD-M4025 ABAD-M4032 ABAD-M5025 ABAD-M5025 ABAD-M5032 ABAD-M5040 ABAD-M5040 ABAD-M6332 ABAD-M6332 ABAD-M6332 ABAD-M6350 ABAD-M7563 ABAD-M7563 ABAD-M7563 ABAD-M85563 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M100 ABAD-M100 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M8575 ABAD-M1121 ABAD-M100 ABAD-M1121 ABAD-M100 ABAD-M100 ABAD-M1121 ABAD-M100 ABAD-M100 ABAD-M1121 ABAD-M100 ABAD-M100 ABAD-M11121 ABAD-M116 | ABAD-M2516 | 214 | ABET-M25 | 219 |
| ABAD-M3220 214 ABET-M50 219 ABAD-M3225 214 ABET-M63 219 ABAD-M4020 214 ABET-M75 219 ABAD-M4025 214 ABET-M80 219 ABAD-M5032 214 ABET-M85 219 ABAD-M5035 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N112 219 ABAD-M63340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M2520 | 214/2 // | ABET-M32 | 219 |
| ABAD-M3225 214 ABET-M63 219 ABAD-M4020 2)4 ABET-M75 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5032 214 ABET-N1 219 ABAD-M6332 214 ABET-N112 219 ABAD-M6332 214 ABET-N112 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N21 219 ABAD-M7563 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABEN-M100 219 | ABAD-M3216 | 214 | ABET-M40 | 219 |
| ABAD-M4020 214 ABET-M75 219 ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N312 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M3220 | (214) | ABET-M50 | 219 |
| ABAD-M4025 214 ABET-M80 219 ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7563 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABEN-M100 219 | ABAD-M3225 | 214 | ABET-M63 | 219 |
| ABAD-M4032 214 ABET-M85 219 ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6350 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7563 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABEN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M4020 | 214 | ABET-M75 | 219 |
| ABAD-M5025 214 ABET-M90 219 ABAD-M5032 214 ABET-N1 219 ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N212 219 ABAD-M7563 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M4025 | 214 | ABET-M80 | 219 |
| ABAD-M5032 214 ABET-N1 219 ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7550 214 ABET-N212 219 ABAD-M7563 214 ABET-N312 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M4032 | 214 | ABET-M85 | 219 |
| ABAD-M5040 214 ABET-N112 219 ABAD-M6332 214 ABET-N114 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N2 219 ABAD-M7563 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M5025 | 214 | ABET-M90 | 219 |
| ABAD-M6332 214 ABET-N114 219 ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N212 219 ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N34 219 ABAD-M8575 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M5032 | 214 | ABET-N1 | 219 |
| ABAD-M6340 214 ABET-N12 219 ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N212 219 ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M5040 | 214 | ABET-N112 | 219 |
| ABAD-M6350 214 ABET-N2 219 ABAD-M7540 214 ABET-N212 219 ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M6332 | 214 | ABET-N114 | 219 |
| ABAD-M7540 214 ABET-N212 219 ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M6340 | 214 | ABET-N12 | 219 |
| ABAD-M7550 214 ABET-N312 219 ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M6350 | 214 | ABET-N2 | 219 |
| ABAD-M7563 214 ABET-N34 219 ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | ABAD-M7540 | 214 | ABET-N212 | 219 |
| ABAD-M8550 214 ABET-N34 219 ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | | 214 | ABET-N312 | 219 |
| ABAD-M8563 214 ABET-N4 219 ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 | | 214 | ABET-N34 | 219 |
| ABAD-M8575 214 ABLN-M100 219 ABAD-N1121 214 ABLN-M16 219 |), / / / / | 214 | ABET-N34 | 219 |
| ABAD-N1121 214 ABLN-M16 219 | | 214 | ABET-N4 | 219 |
| | \rightarrow | | ABLN-M100 | 219 |
| ABAD-N1141 214 ABLN-M20 219 | > | | - | |
| | ABAD-N1141 | 214 | ABLN-M20 | 219 |

| ABLN-M25 | 219 | ABRE-N1112 | 216 |
|------------|-------|--------------|-----|
| ABLN-M32 | 219 | ABRE-N1114 | 216 |
| ABLN-M40 | 219 | ABRE-N1122 | 216 |
| ABLN-M50 | 219 | ABRE-N112212 | 216 |
| ABLN-M63 | 219 | ABRE-N1123 | 216 |
| ABLN-M75 | 219 | ABRE-N114112 | 216 |
| ABLN-M80 | 219 | ABRE-N11412 | 216 |
| ABLN-M90 | 219 | ABRE-N1142 | 216 |
| ABLN-N1 | 219 | ABRE-N12 | 216 |
| ABLN-N112 | 219 | ABRE-N121 | 216 |
| ABLN-N114 | 219 | ABRE-N12114 | 216 |
| ABLN-N12 | 219 | ABRE-N1234 | 216 |
| ABLN-N2 | 219 | ABRE-N2123 | 216 |
| ABLN-N212 | 219 | ABRE-N2124) | 216 |
| ABLN-N312 | 219 | ABRE-N2212 | 216 |
| ABLN-N34 | 219 | ABRE-N23 | 216 |
| ABLN-N34 | 219 | ABRE-N24 | 216 |
| ABLN-N4 | 219 🤇 | ABRE-N34 | 216 |
| ABRE-M1625 | 216 | ABRE-N341 | 216 |
| ABRE-M1632 | 216 | ABRE-N34112 | 216 |
| ABRE-M2025 | 216 | ABRE-N34114 | 216 |
| ABRE-M2032 | 216 | ABSD-A20a | 220 |
| ABRE-M2040 | 216 | ABSD-A20d | 220 |
| ABRE-M2532 | 216 | ABSD-A25 | 220 |
| ABRE-M2540 | 216 | ABSD-A32 | 220 |
| ABRE-M2550 | 216 | ABSD-A40 | 220 |
| ABRE-M3240 | 216 | ABSD-A50 | 220 |
| ABRE-M3250 | 216 | ABSD-A63 | 220 |
| ABRE-M3263 | 216 | ABSD-A75 | 220 |
| ABRE-M4050 | 216 | ABSD-B16 | 220 |
| ABRE-M4063 | 216 | ABSD-B20a | 220 |
| ABRE-M4075 | 216 | ABSD-B20b | 220 |
| ABRE-M5063 | 216 | ABSD-B25 | 220 |
| ABRE-M5075 | 216 | ABSD-B32 | 220 |
| ABRE-M5085 | 216 | ABSD-B40 | 220 |
| ABRE-M6375 | 216 | ABSD-B50 | 220 |
| ABRE-M6385 | 216 | ABSD-B63 | 220 |
| ABRE-M7585 | 216 | ABSD-B75 | 220 |

| ABSD-B80 | 220 | ABSSW-M16 | 219 |
|--------------|------|-------------|-----|
| ABSD-B90 | 220 | ABSSW-M20 | 219 |
| ABSP H-M16 | 218 | ABSSW-M25 | 219 |
| ABSP H-M20 | 218 | ABSSW-M32 | 219 |
| ABSP H-M25 | 218 | ABSSW-M40 | 219 |
| ABSP H-M32 | 218 | ABSSW-M50 | 219 |
| ABSP H-M40 | 218 | ABSSW-M63 | 219 |
| ABSP H-M50 | 218 | ABSSW-M75 | 219 |
| ABSP H-M63 | 218 | ABSSW-M80 | 219 |
| ABSP H-M75 | 218 | ABSSW-M85 | 219 |
| ABSP H-M85 | 218 | ABSSW-M90 🔷 | 219 |
| ABSP H-N1 | 217 | ABS\$W-N1 | 219 |
| ABSP H-N112 | 217 | ABSSW-N112 | 219 |
| ABSP H-N114 | 217 | ABSSW-N114 | 219 |
| ABSP H-N12 | 217 | ABSSW-N12 | 219 |
| ABSP H-N2 | 217 | ABS\$W-N2 | 219 |
| ABSP H-N212 | 217 | ABSSW-N212 | 219 |
| ABSP H-N3 | 2177 | ABSSW-N312 | 219 |
| ABSP H-N34 | 217 | ABSSW-N34 | 219 |
| ABSP H-N4 | 217 | ABSSW-N34 | 219 |
| ABSP RH-M16 | 218 | ABSSW-N4 | 219 |
| ABSP RH-M20 | 218 | ABSW-M100 | 220 |
| ABSP RH-M25 | 218 | ABSW-M16 | 220 |
| ABSP RH-M32 | 218 | ABSW-M20 | 220 |
| ABSP RH-M40 | 218 | ABSW-M25 | 220 |
| ABSP RH-M50 | 218 | ABSW-M32 | 220 |
| ABSP RH-M63 | 218 | ABSW-M40 | 220 |
| ABSP RH-M75 | 218 | ABSW-M50 | 220 |
| ABSP RH-M85 | 218 | ABSW-M63 | 220 |
| ABSP RH-N1 | 217 | ABSW-M75 | 220 |
| ABSP RH-N112 | 217 | ABSW-M80 | 220 |
| ABSP RH-N114 | 217 | ABSW-M85 | 220 |
| ABSP RH-N2 | 217 | ABSW-M90 | 220 |
| ABSP RH-N212 | 217 | ABSW-N1 | 220 |
| ABSP RH-N3 | 217 | ABSW-N112 | 220 |
| ABSP RH-N34 | 217 | ABSW-N114 | 220 |
| ABSP RH-N4 | 217 | ABSW-N12 | 220 |
| ABSSW-M100 | 219 | ABSW-N2 | 220 |
| | | | |

| ABSW-N212 | 220 | BPGA160 | 86 |
|-----------|-----|--------------|-----|
| ABSW-N312 | 220 | BPGC1 | 47 |
| ABSW-N34 | 220 | BPGC10 | 67 |
| ABSW-N34 | 220 | BPGC11 | 69 |
| ABSW-N4 | 220 | BPGC12 | 71 |
| ASG-M16a | 210 | BPGC13 | 73 |
| ASG-M16b | 210 | BPGC13.5 | 75 |
| ASG-M20a | 210 | BPGC14 | 77 |
| ASG-M20b | 210 | BPGC15 | 79 |
| ASG-M20c | 210 | BPGC2 | 49 |
| ASG-M25 | 210 | BPGC3 | 51 |
| ASG-M32a | 210 | BPGC4 | 53 |
| ASG-M32b | 210 | BPGC4.5 | 55 |
| ASG-M40 | 210 | BPGC5 | 57 |
| ASG-M50 | 210 | BPGC6 | 59 |
| ASG-M63a | 210 | BPGC7) | 61 |
| ASG-M63b | 210 | BPGC8 | 63 |
| ASG-M75 | 210 | BPGC9 | 65 |
| ASG-M80 | 210 | D | |
| ASG-M90 | 210 | DPJB1 | 137 |
| В | | DPJB11 | 137 |
| BPG1 | 47) | DPJB2 | 137 |
| BPG10 | 67 | DPJB3 | 137 |
| BPG11 | 69 | DPJB5 | 137 |
| BPG12 | 71 | DPJB7 | 137 |
| BPG13 | 73 | DPJB9 | 137 |
| BPG13.5 | 75 | G | |
| BPG14 | 77 | GRN8 | 197 |
| BPG15 | 79 | Н | |
| BPG4 | 53 | HVJBx3 (0-2) | 139 |
| BPG4.5 | 55 | HVJBx3 (0-3) | 139 |
| BPG5 | 57 | HVJBx3 (1-1) | 139 |
| BPG6 | 59 | HVJBx3 (1-2) | 139 |
| BPG7 | 61 | HVJBx3 (1-3) | 139 |
| BPG8 | 63 | HVJBx3 (2-0) | 139 |
| BPG9 | 65 | HVJBx3 (2-1) | 139 |
| BPGA120 | 84 | HVJBx3 (2-2) | 139 |
| BPGA125 | 85 | HVJBx3 (2-3) | 139 |
| | | | |

| HVJBx3 (3-0) | 139 | MSX1.5.200 | 25 |
|--------------|-------|------------|------|
| HVJBx3 (3-1) | 139 | MSX1.5.300 | 25 |
| HVJBx3 (3-2) | 139 | MSX2.140 | 27 |
| HVJBx3 (3-3) | 139 | MSX2.200 | 27 |
| HVJBx4 (0-2) | 139 | MSX2.300 | > 27 |
| HVJBx4 (0-3) | 139 | MSX3.140 | 29 |
| HVJBx4 (1-1) | 139 | MSX3.200 | 29 |
| HVJBx4 (1-2) | 139 | MSX3.300 | 29 |
| HVJBx4 (1-3) | 139 | MSX4.140 | 31 |
| HVJBx4 (2-0) | 139 | MSX4.200 | 31 |
| HVJBx4 (2-1) | 139 | MSX4.300 | 31 |
| HVJBx4 (2-2) | 139 | MSX45 | 13 |
| HVJBx4 (2-3) | 139 | MSX5.140 | 33 |
| HVJBx4 (3-0) | 139 | MSX5.200 | 33 |
| HVJBx4 (3-1) | 139 | MSX5.300 | 33 |
| HVJBx4 (3-2) | 139 | MSX6.140 | 35 |
| HVJBx4 (3-3) | 139 | M\$X6.200 | 35 |
| L | | MSX6.300 | 35 |
| LR52(200) | 141 | MSX64 | 15 |
| LR52(300) | (141) | MSX66 | 17 |
| LR73(200) | 141 | MSX7.140 | 37 |
| LR73(300) | 1/41 | MSX7.200 | 37 |
| M | | MSX7.300 | 37 |
| MJB5 | 135 | MSX8.140 | 39 |
| MJB5/3 | 135 | MSX8.200 | 39 |
| MJB6 | 135 | MSX8.300 | 39 |
| MJB6/3 | 135 | S | |
| MJB7 | 135 | SX0.140 | 19 |
| MJB7/3 | 135 | SX0.200 | 19 |
| MJB8 | 135 | SX0.5.140 | 21 |
| MJB8/3 | 135 | SX0.5.200 | 21 |
| MSX0.140 | 19 | SX1.140 | 23 |
| M\$X0.200 | 19 | SX1.200 | 23 |
| MSX0.5.140 | 21 | SX1.5.140 | 25 |
| M\$X0.5.200 | 21 | SX1.5.200 | 25 |
| MSX1.140 | 23 | SX1.5.300 | 25 |
| MSX1.200 | 23 | SX2.140 | 27 |
| MSX1.5.140 | 25 | SX2.200 | 27 |
| | | | |

| SX2.300 | 27 | ZAG1R | 93 |
|---------|------|----------|----------|
| SX3.140 | 29 | ZAG2 | 95 |
| SX3.200 | 29 | ZAG21 | 129 |
| SX3.300 | 29 | ZAG21R | 129 |
| SX4.140 | 31 | ZAG2R | 95 |
| SX4.200 | 31 | ZAG3 | 97 |
| SX4.300 | 31 | ZAG3R | 97 |
| SX45 | 13 | ZAG4 | (()) 99 |
| SX5.140 | 33 | ZAG4R | 99 |
| SX5.200 | 33 | ZAG5 | 101 |
| SX5.300 | 33 | ZAG5R |) 101 |
| SX6.140 | 35 | ZAG6 | 103 |
| SX6.200 | 35 | ZAG6R | 103 |
| SX6.300 | 35 | ZAG7(()) | 105 |
| SX64 | 15 | ZAG7R | 105 |
| SX66 | 17 | ZAG8 | 107 |
| SX7.140 | 37 | ZAG8R | 107 |
| SX7.200 | 37 🤇 | ₹ZAG9 | 109 |
| SX7.300 | 37 | ZAG9R | 109 |
| SX8.140 | 39 | ZP1 | 157 |
| SX8.200 | 39 | ZP10 | 175 |
| SX8.300 | 39) | ZP10ABS | 175 |
| Z | | ZP10T | 175 |
| ZAG1 | 93 | ZP11 | 177 |
| ZAG10 | 113 | ZP11ABS | 177 |
| ZAG10R | 113 | ZP11T | 177 |
| ZAG11 | 117 | ZP12 | 179 |
| ZAG11R | 117 | ZP12ABS | 179 |
| ZAG12 | 119 | ZP12T | 179 |
| ZAG12R | 119 | ZP13 | 181 |
| ZAG13 | 121 | ZP13ABS | 181 |
| ZAG13R | 121 | ZP13T | 181 |
| ZAG14 | 123 | ZP14 | 183 |
| ZAG14R | 123 | ZP14ABS | 183 |
| ZAG15 | 125 | ZP14T | 183 |
| ZAG15R | 125 | ZP15 | 185 |
| ZAG16 | 127 | ZP15ABS | 185 |
| ŽAG16R | 127 | ZP15T | 185 |
| | | | |

| ZP16 ZP16ABS | 187 |
|---|---|
| | |
| | 187 |
| ZP16T | 187 |
| ZP17 | 189 |
| ZP17ABS | 189 |
| ZP17T | 189 |
| ZP18 | 191 |
| ZP18ABS | 191 |
| ZP18T | 191 |
| ZP19 | 193 |
| ZP19ABS | 193 |
| ZP19T | 193 |
| ZP1ABS | 157 |
| ZP1T | 157 |
| ZP2 | 159 |
| ZP2ABS | 159 |
| ZP2T | 159 |
| | 161/2 |
| ZP3 | ~ 7~ |
| ZP3 ZP3ABS | 161 |
| | 161 |
| ZP3ABS | |
| ZP3ABS ZP3T | 161 |
| ZP3ABS ZP3T ZP4 | 161 |
| ZP3ABS ZP3T ZP4 ZP4ABS | 161 163 163 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T | 161 163 163 163 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 | 161 163 163 163 165 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS | 161 163 163 163 165 165 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T | 161 163 163 163 165 165 165 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 | 161 163 163 165 165 165 165 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS | 161 163 163 165 165 165 167 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T | 161 163 163 165 165 165 167 167 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS ZP7I | 161 163 163 165 165 165 167 167 167 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS | 161 163 163 165 165 165 167 167 167 169 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS ZP7I | 161 163 163 165 165 165 167 167 167 169 169 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS ZP7I ZP8 | 161 163 163 165 165 165 167 167 167 169 169 169 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS ZP7I ZP8 ZP8ABS | 161 163 163 165 165 165 167 167 167 169 169 171 |
| ZP3ABS ZP3T ZP4 ZP4ABS ZP4T ZP5 ZP5ABS ZP5T ZP6 ZP6ABS ZP6T ZP7 ZP7ABS ZP7I ZP8 ZP8ABS ZP8T | 161 163 163 165 165 165 167 167 167 169 169 171 171 |



www.abtech.eu